


WFF 120 BL**Weidmüller Interface GmbH & Co. KG**

Klingenbergstraße 26

D-32758 Detmold

Germany

www.weidmueller.com**Product image****Klippon® Connect with stud Technology**

Our stud terminals are an established, robust connection alternative for particularly harsh environments. The extensive accessories and quality workmanship ensure high productivity in planning and installation – and sustainable safety in operation..

General ordering data

Version	Bolt-type screw terminals, Feed-through terminal, Rated cross-section: 120 mm ² , Threaded stud connection
Order No.	1028580000
Type	WFF 120 BL
GTIN (EAN)	4008190121808
Qty.	5 pc(s).

WFF 120 BL

Weidmüller Interface GmbH & Co. KG

Klingenbergstraße 26

D-32758 Detmold

Germany

www.weidmueller.com

Technical data

Dimensions and weights

Depth	88.5 mm	Depth (inches)	3.484 inch
Depth including DIN rail	88.5 mm	Height	132 mm
Height (inches)	5.197 inch	Net weight	243.12 g
Weight	265.69 g	Width	42 mm
Width (inches)	1.654 inch		

Temperatures

Storage temperature		Operating temperature range	For operating temperature range see EC Design Test Certificate / IEC Ex-Certificate of Conformity
	-25 °C...55 °C		
Continuous operating temp., min.	-50 °C	Continuous operating temp., max.	120 °C

Material data

Material	Wemid	Colour	blue
UL 94 flammability rating	V-0		

Rating data IECEx/ATEX

Certificate No. (ATEX)	KEMA98ATEX1684U	ATEX certificate	KEMA98ATEX1684U_e.pdf
ATEX certificate	IECExKEM07.0053U	Certificate No. (IECEx)	IECExKEM07.0053U
IEC Ex certificate	IECExKEM07.0053U_e.pdf	Max. voltage (ATEX)	1100 V
Current (ATEX)	234 A	Wire cross section max. (ATEX)	120 mm ²
Max. voltage (IECEx)	1100 V	Current (IECEx)	234 A
Wire cross section max. (IECEx)		Operating temperature range	For operating temperature range see EC Design Test Certificate / IEC Ex-Certificate of Conformity
	120 mm ²		
Marking EN 60079-7	Ex eb II C Gb	Ex 2014/34/EU label	II 2 G D

System specifications

End cover plate required	No	Number of levels	1
Number of clamping points per level	2	Levels cross-connected internally	No
PE connection	No	Rail	TS 35

Additional technical data

Explosion-tested version	Yes	Number of similar terminals	1
Open sides	closed	Type of mounting	Snap-on

CSA rating data

Certificate No. (CSA)	200039-1244019	Current size C (CSA)	310 A
Voltage size C (CSA)	600 V	Wire cross section max. (CSA)	250 kcmil
Wire cross section min. (CSA)	10 AWG		

WFF 120 BL

Weidmüller Interface GmbH & Co. KG

Klingenbergstraße 26

D-32758 Detmold

Germany

www.weidmueller.com

Technical data

Conductors for clamping (rated connection)

2 x cable lugs DIN 46 234	6 to 120 mm ²
Cable lug to DIN 46234	6...150 mm ²
Clamping range, max.	150 mm ²
Number of connections	2
Tightening torque, max.	20 Nm
Type of connection	Threaded stud connection

2 x cable lugs DIN 46 235	16...120 mm ²
Cable lug to DIN 46235	16...150 mm ²
Clamping range, min.	6 mm ²
Stud size for spade connection	M 10
Tightening torque, min.	10 Nm

General

Rail	TS 35
------	-------

Rating data

Power loss in accordance with IEC 60947-7-x	8.61 W	Rated cross-section	120 mm ²
Rated voltage	1,000 V	Rated current	269 A
Current at maximum wires	309 A	Volume resistance according to IEC 60947-7-x	0.12 mΩ
Rated impulse withstand voltage	8 kV	Pollution severity	3

UL rating data

Certificate No. (UR)	E60693	Conductor size Factory wiring max. (UR)	250 kcmil
Conductor size Factory wiring min. (UR)	10 AWG	Conductor size Field wiring max. (UR)	250 kcmil
Conductor size Field wiring min. (UR)	10 AWG	Current size C (UR)	310 A
UL_current_Print	310 A	UL_voltage_Print	1,000 V
UL_wire_max_Print	250 kcmil	UL_wire_min_Print	10 AWG
Voltage size C (UR)	1000 V		

Classifications

ETIM 6.0	EC000897	ETIM 7.0	EC000897
ECLASS 9.0	27-14-11-20	ECLASS 9.1	27-14-11-20
ECLASS 10.0	27-14-11-20	ECLASS 11.0	27-14-11-20

Approvals

Approvals



ROHS	Conform
UL File Number Search	E60693

WFF 120 BL

Weidmüller Interface GmbH & Co. KG

Klingenbergstraße 26

D-32758 Detmold

Germany

www.weidmueller.com

Technical data

Downloads

Approval/Certificate/Document of
Conformity

[Attestation of Conformity](#)
[IECEX Certificate](#)
[ATEX Certificate](#)
[CB Certificate](#)
[EAC certificate](#)
[DNVGL certificate](#)
[MARITREG Certificate](#)
[POLSKIREJ certificate](#)
[CCC Ex Certificate](#)
[Declaration of Conformity](#)
[Declaration of Conformity](#)

Engineering Data

[STEP](#)

Engineering Data

[EPLAN, WSCAD, Zuken E3.S](#)

User Documentation

[StorageConditionsTerminalBlocks](#)
[WFF range for 1500 VDC applications](#)
[DIRECT MOUNTING WFF TERMINAL BLOCKS](#)