

VG M63 EXE MS**Weidmüller Interface GmbH & Co. KG**

Klingenbergstraße 26

D-32758 Detmold

Germany

www.weidmueller.com

Similar to illustration

Brass cable glands which are suitable for usage in explosion risk zone Ex e (Increased safety). They have been tested to the latest norms and standards IEC/EN 60079-0, and also achieved the necessary ATEX certificate.

General ordering data

Version	VG Ex MS (Ex brass cable gland), Cable glands, M 63, 18 mm, OD min. 46 - OD max. 56 mm, IP66, IP68, Brass, nickel-plated
Order No.	1460110000
Type	VG M63 EXE MS
GTIN (EAN)	4050118266092
Qty.	5 pc(s).

VG M63 EXE MS

Weidmüller Interface GmbH & Co. KG

Klingenbergstraße 26

D-32758 Detmold

Germany

www.weidmueller.com

Technical data

Dimensions and weights

Length	69.5 mm	Length (inches)	2.736 inch
Net weight	726.4 g		

Environmental Product Compliance

REACH SVHC	Lead 7439-92-1
------------	----------------

Certificate numbers cable gland

Certificate no. cable gland (ATEX)	IMQ 11 ATEX 038 X	Certificate no. cable gland (GOST)	POCC TR.05.B04161
Identification	Ex d IIC Gb, Ex e IIC Gb, Ex tb IIIC Db IP66/68		

General information

AF size 1	80 mm	AF size 2	75 mm
Clamp insert	Neoprene	External thread	M 63
Installation guidelines	See assembly instructions	Length of thread	18 mm
Material		Note: protection class	Please observe the information in the installation instructions.
	Brass, nickel-plated		
O-Ring	NBR	Operating temperature range, max.	100 °C
Operating temperature range, min.	-40 °C	Outer cable diameter, max.	56 mm
Outer cable diameter, min.	46 mm	Pitch of thread	1.5 mm
Protection degree	IP66, IP68 - 6 bar (30 min.)	Protection degree with GWDR	IP66, IP68
Seal insert		Standards	EN 60079-0, EN 60079-1, EN 60079-7, EN 60079-11, EN 60079-31
	CR		

Classifications

ETIM 6.0	EC000441	ETIM 7.0	EC000441
ECLASS 9.0	27-14-44-32	ECLASS 9.1	27-14-44-34
ECLASS 10.0	27-14-44-32	ECLASS 11.0	27-14-44-32

Important note

Product information	In combination with Klippon STB enclosures an additional flat gasket must be used - GWDR NP.
---------------------	--

Approvals

Approvals



Approvals	EAC; ATEX
ROHS	Conform

Downloads

Engineering Data	STEP
Engineering Data	EPLAN, WSCAD

Creation date March 23, 2021 11:53:26 PM CET

Catalogue status 12.03.2021 / We reserve the right to make technical changes.