

SIMOTICS GP - 160 M - IM B3 - 6p

Client order no.	Item-No.	Offer no.
Order no.	Consignment no.	Project

Remarks

Safe Area

U	Δ / Y	f	P	P	I	n	M	η ³⁾			cosφ ³⁾			I _A /I _N	M _A /M _N	M _K /M _N	IE-CL
[V]		[Hz]	[kW]	[hp]	[A]	[1/min]	[Nm]	4/4	3/4	2/4	4/4	3/4	2/4	I _I /I _N	T _I /T _N	T _B /T _N	
440	Δ	60	8.60	-/-	17.50	1170	70.0	86.0	86.0	84.5	0.75	0.68	0.57	5.9	2.2	2.9	IE1
IM B3 / IM 1001			FS 160 M		72 kg		IP55			IEC/EN 60034		IEC, DIN, ISO, VDE, EN					

Locked rotor time (hot / cold) : 14.7 s | 23.3 s

Sound level (SPL / SWL) at 50Hz 60Hz	67.0 / 79.0 dB(A) ²⁾	70.0 / 82.0 dB(A) ²⁾	External earthing terminal	No
Moment of inertia	0.0560 kg m²		Vibration severity grade	A
Bearing DE NDE	6209 2Z C3	6209 2Z C3	Insulation	155(F) to 130(B)
bearing lifetime			Duty type	S1
L _{10mh} F _{Rad min} for coupling operation 50 60Hz ¹⁾	40000 h	32000 h	Direction of rotation	bidirectional
Lubricants	Unirex N3		Frame material	aluminum
Regreasing device	No		Coating (paint finish)	Standard paint finish C2
Grease nipple	-/-		Color, paint shade	RAL7030
Type of bearing	Locating bearing NDE		Motor protection	(F) 1 temperature sensor KTY84-130 (2 terminals)
Condensate drainage holes	-/-		Method of cooling	IC411 - self ventilated, surface cooled

Terminal box position	top	Max. cross-sectional area	16.0 mm²
Material of terminal box	Aluminium	Cable diameter from ... to ...	19.0 mm - 28.0 mm
Type of terminal box	TB1 J00	Cable entry	2xM40x1,5-1xM16x1,5
Contact screw thread	M5	Cable gland	3 plugs

Notes:

I_A/I_N = locked rotor current / current nominal
 M_A/M_N = locked rotor torque / torque nominal
 M_K/M_N = break down torque / nominal torque

1) L10mh according to DIN ISO 281 10/2010
2) at rated power / at full load

3) Value is valid only for DOL operation with motor design IC411

responsible dep.	technical reference	created by	approved by	Technical data are subject to change! There may be discrepancies between calculated and rating plate values.			
DI MC LVM		DT Configurator					
	document type			document status		customer	
	datasheet			released			
	title			document number			
	1LE1002-1DC29-0AF4-Z						
	B02+F01+F11+G04+M1D			rev.	creation date	language	Page
© Siemens AG 2021				01	2021-04-23 16:08	en	1/2


SIMOTICS GP - 160 M - IM B3 - 6p

B02	Acceptance test certificate 3.1 acc. to EN 10204	G04	Mounted rotary pulse encoder LL 861 900 220
F01	Mounting a brake	M1D	440 VD for 60 Hz, 60-Hz power
F11	Brake supply voltage, 230 V AC, 50/60 Hz		

Brake:

Description:	BFK458-20	Current:	.5 A
Voltage:	AC 230 V	Moment of inertia:	.0073 Nm

responsible dep.	technical reference	created by	approved by	Technical data are subject to change! There may be discrepancies between calculated and rating plate values.
------------------	---------------------	------------	-------------	--

	document type	document status		customer	
	datasheet	released			
	title	document number			
	1LE1002-1DC29-0AF4-Z				
© Siemens AG 2021	B02+F01+F11+G04+M1D	rev.	creation date	language	Page
		01	2021-04-23 16:08	en	2/2