

SIMOTICS GP - 160 M - IM B3 - 4p

Client order no.	Item-No.	Offer no.
Order no.	Consignment no.	Project

Remarks

Safe Area

U	Δ / Y	f	P	P	I	n	M	η ³⁾			cosφ ³⁾			I _A /I _N	M _A /M _N	M _K /M _N	IE-CL
[V]		[Hz]	[kW]	[hp]	[A]	[1/min]	[Nm]	4/4	3/4	2/4	4/4	3/4	2/4	I _I /I _N	T _I /T _N	T _B /T _N	
DOL duty (S1) - 155(F) to 130(B)																	
380	Δ	50	11.00	-/-	22.50	1470	71.0	91.4	91.9	91.9	0.82	0.76	0.65	8.0	2.5	3.5	IE3
660	Y	50	11.00	-/-	12.80	1470	71.0	91.4	91.9	91.9	0.82	0.76	0.65	8.0	2.5	3.5	IE3
440	Δ	60	12.60	-/-	21.50	1765	68.0	92.4	92.9	92.6	0.83	0.78	0.68	8.1	3.3	3.5	IE3
440	Δ	60	11.00	-/-	19.30	1775	59.0	92.4	92.6	92.0	0.81	0.75	0.63	9.0	3.8	4.0	IE3
IM B3 / IM 1001			FS 160 M			IP55	UKCA	IEC/EN 60034		IEC, DIN, ISO, VDE, EN						Grade 3	
Environmental conditions : -20 °C - +40 °C / 1,000 m									Locked rotor time (hot / cold) : 26.5 s 34.3 s								

Sound level (SPL / SWL) at 50Hz 60Hz	65 / 77 dB(A) ^{2) 3)}	69 / 81 dB(A) ^{2) 3)}	Vibration severity grade	A
Moment of inertia	0.0583 kg m²		Thermal class	F
Bearing DE NDE	6209 2Z C3	6209 2Z C3	Duty type	S1
bearing lifetime			Direction of rotation	bidirectional
L _{10mh} F _{Rad min} for coupling operation 50 60Hz ¹⁾	40000 h	32000 h	Frame material	aluminum
Regreasing device	No		Net weight of the motor (IM B3)	78 kg
Grease nipple	-/-		Coating (paint finish)	Standard paint finish C2
Type of bearing	Locating bearing NDE		Color, paint shade	RAL7030
Condensate drainage holes	No		Motor protection	1/3 Bi-metallic sensors (opener) for tripping (2 terminals)
External earthing terminal	No		Method of cooling	IC411 - self ventilated, surface cooled

Terminal box position	top	Max. cross-sectional area	16 mm²
Material of terminal box	Aluminium	Cable diameter from ... to ...	19 mm - 28 mm
Type of terminal box	TB1 J00	Cable entry	2xM40x1,5-1xM16x1,5
Contact screw thread	M5	Cable gland	3 plugs

Notes:

I_r/I_n = locked rotor current / current nominal	1) L10mh according to DIN ISO 281 10/2010	3) Value is valid only for DOL operation with motor design IC411
M_r/M_n = locked rotor torque / torque nominal	2) at rated power / at full load	
M_b/M_n = break down torque / nominal torque		

responsible dep.	technical reference	created by	approved by	Technical data are subject to change! There may be discrepancies between calculated and rating plate values.		Link documents	
DI MC LVM		DT Configurator					
	document type			document status			
	datasheet			released			
	title			document number			
	1LE1003-1DB23-3AZ4-Z						
	B02+D34+Q3A			rev.	creation date	language	Page
© Siemens AG 2023				942	2023-02-27	en	1/2

SIMOTICS GP - 160 M - IM B3 - 4p

Special design

B02	Acceptance test certificate 3.1 acc. to EN 10204	Q3A	1/3 Bi-metallic sensors (opener) for tripping (2 terminals)
D34	China Energy Efficiency Label		

Notes:

responsible dep. DI MC LVM	technical reference	created by DT Configurator	approved by	Technical data are subject to change! There may be discrepancies between calculated and rating plate values.		Link documents	
SIEMENS	document type datasheet			document status released			
	title 1LE1003-1DB23-3AZ4-Z			document number			
© Siemens AG 2023	B02+D34+Q3A			rev. 942	creation date 2023-02-27	language en	Page 2/2