

SIMOTICS GP - 132 S - IM B5 - 2p

Client order no.	Item-No.	Offer no.
Order no.	Consignment no.	Project

Remarks

Safe Area

U [V]	Δ / Y	f [Hz]	P [kW]	P [hp]	I [A]	n [1/min]	M [Nm]	η ³⁾			cosφ ³⁾			I _A /I _N I _I /I _N	M _A /M _N T _I /T _N	M _K /M _N T _B /T _N	IE-CL
IM B5 / IM 3001			FS 132 S		57 kg	IP55	CC032A	IEC/EN 60034			IEC, EN, UL, CSA, NEMA MG1-12-12			kVA Code: M			
Environmental conditions : -20 °C - +40 °C / 1,000 m									Locked rotor time (hot / cold) : 12.6 s 17.2 s								

Sound level (SPL / SWL) at 50Hz 60Hz	68.0 / 80.0 dB(A) ²⁾	72.0 / 84.0 dB(A) ²⁾	External earthing terminal	No
Moment of inertia	0.0310 kg m ²		Vibration severity grade	A
Bearing DE NDE	6208 2Z C3	6208 2Z C3	Insulation	155(F) to 130(B)
bearing lifetime			Duty type	S1
L _{10mh} F _{Rad min} for coupling operation 50 60Hz ¹⁾	40000 h	32000 h	Direction of rotation	bidirectional
Lubricants	Unirex N3		Frame material	aluminum
Regreasing device	No		Coating (paint finish)	Standard paint finish C2
Grease nipple	-/-		Color, paint shade	RAL7030
Type of bearing	Preloaded bearing DE		Motor protection	(A) without (Standard)
Condensate drainage holes	-/-		Method of cooling	IC411 - self ventilated, surface cooled

Terminal box position	top	Max. cross-sectional area	6.0 mm²
Material of terminal box	Aluminium	Cable diameter from ... to ...	11.0 mm - 21.0 mm
Type of terminal box	TB1 H00	Cable entry	2xM32x1,5
Contact screw thread	M4	Cable gland	2 plugs

Notes:

I_A/I_N = locked rotor current / current nominal
 M_A/M_N = locked rotor torque / torque nominal
 M_K/M_N = break down torque / nominal torque

1) L10mh according to DIN ISO 281 10/2010
2) at rated power / at full load

3) Value is valid only for DOL operation with motor design IC411

responsible dep.	technical reference	created by	approved by	Technical data are subject to change! There may be discrepancies between calculated and rating plate values.			
DI MC LVM		DT Configurator					
	document type			document status		customer	
	datasheet			released			
	title			document number			
	1LE1023-1CA19-0FA4-Z						
	B02+M1Y			rev.	creation date	language	Page
© Siemens AG 2021				01	2021-04-22 18:00	en	1/2

SIMOTICS GP - 132 S - IM B5 - 2p

Special design

B02	Acceptance test certificate 3.1 acc. to EN 10204	M1Y	Non-standard winding:
-----	--	-----	-----------------------

Notes:

responsible dep.		technical reference		created by		approved by		Technical data are subject to change! There may be discrepancies between calculated and rating plate values.			
DI MC LVM				DT Configurator							
		document type				document status			customer		
		datasheet				released					
© Siemens AG 2021		title				document number					
		1LE1023-1CA19-0FA4-Z									
		B02+M1Y				rev.	creation date		language	Page	
						01	2021-04-22 18:00		en	2/2	