

SIMOTICS SD - 160 M - IM B3 - 4p

Client order no.	Item-No.	Offer no.
Order no.	Consignment no.	Project

Remarks

Safe Area

U	Δ / Y	f	P	P	I	n	M	η ³⁾			cosφ ³⁾			I _A /I _N	M _A /M _N	M _K /M _N	IE-CL
[V]		[Hz]	[kW]	[hp]	[A]	[1/min]	[Nm]	4/4	3/4	2/4	4/4	3/4	2/4	I _I /I _N	T _I /T _N	T _B /T _N	
460	Δ	60	12.60	-/-	20.50	1770	68.0	91.0	91.7	91.1	0.85	0.83	0.75	7.0	2.2	2.8	IE2
IM B3 / IM 1001			FS 160 M		96 kg		IP55	IEC/EN 60034			IEC, DIN, ISO, VDE, EN						

Locked rotor time (hot / cold) : 17.9 s | 28.8 s

Mechanical data

Sound level (SPL / SWL) at 50Hz 60Hz	75.0 / 79.0 dB(A) ²⁾	75.0 / 79.0 dB(A) ²⁾	External earthing terminal	No
Moment of inertia	0.0550 kg m ²		Vibration severity grade	A
Bearing DE NDE	6209 2Z C3	6209 2Z C3	Insulation	155(F) to 130(B)
bearing lifetime			Duty type	S1
L _{10mh} F _{Rad,min} for coupling operation 50 60Hz ¹⁾	40000 h	32000 h	Direction of rotation	bidirectional
Lubricants	Unirex N3		Frame material	cast iron
Regreasing device	No		Coating (paint finish)	Standard paint finish C2
Grease nipple	-/-		Color, paint shade	RAL7030
Type of bearing	Locating bearing NDE		Motor protection	(F) 1 temperature sensor KTY84-130 (2 terminals)
Condensate drainage holes	Yes (standard)		Method of cooling	IC416 - separately ventilated, surface cooled

Terminal box

Terminal box position	left	Max. cross-sectional area	16.0 mm²
Material of terminal box	cast iron	Cable diameter from ... to ...	19.0 mm - 28.0 mm
Type of terminal box	TB1 J01	Cable entry	2xM40x1,5-1xM16x1,5
Contact screw thread	M5	Cable gland	3 plugs

Notes:

I_A/I_N = locked rotor current / current nominal
M_A/M_N = locked rotor torque / torque nominal
M_K/M_N = break down torque / nominal torque

1) L10mh according to DIN ISO 281 10/2010
2) at rated power / at full load

3) Value is valid only for DOL operation with motor design IC411

responsible dep. DI MC LVM	technical reference	created by DT Configurator	approved by		Technical data are subject to change! There may be discrepancies between calculated and rating plate values.			
	document type datasheet			document status released		customer		
	title 1LE1501-1DB29-0AF6-Z			document number				
© Siemens AG 2021	B02+F70+G06+M1F			rev. 01	creation date 2021-04-22 12:13	language en	Page 1/2	

SIMOTICS SD - 160 M - IM B3 - 4p

B02	Acceptance test certificate 3.1 acc. to EN 10204	G06	Mounting a rotary pulse encoder HOG 10 D 1024 I
F70	Mounting of separately driven fan	M1F	460 VD for 60 Hz, 60-Hz power

--

responsible dep. DI MC LVM	technical reference	created by DT Configurator	approved by	Technical data are subject to change! There may be discrepancies between calculated and rating plate values.			
	document type datasheet			document status released		customer	
	title 1LE1501-1DB29-0AF6-Z			document number			
© Siemens AG 2021	B02+F70+G06+M1F			rev. 01	creation date 2021-04-22 12:13	language en	Page 2/2