

SIMOTICS SD - 160 M - IM V1 - 4p

Client order no.	Item-No.	Offer no.
Order no.	Consignment no.	Project

Remarks

Safe Area

U	Δ / Y	f [Hz]	P [kW]	P [hp]	I [A]	n [1/min]	M [Nm]	$\eta^{3)}$			$\cos\varphi^{3)}$			I_A/I_N	M_A/M_N	M_K/M_N	IE-CL
[V]								4/4	3/4	2/4	4/4	3/4	2/4	I_I/I_N	T_I/T_N	T_B/T_N	
DOL duty (S1) - 155(F) to 130(B)																	
380	Δ	50	11.00	-/-	22.00	1480	71.0	93.3	93.4	92.5	0.82	0.76	0.64	8.1	2.9	4.1	IE4
660	Y	50	11.00	-/-	12.60	1480	71.0	93.3	93.4	92.5	0.82	0.76	0.64	8.1	2.9	4.1	IE4
440	Δ	60	12.60	-/-	21.50	1780	68.0	93.6	93.7	92.8	0.83	0.77	0.66	8.1	2.9	3.9	IE4
440	Δ	60	11.00	-/-	19.00	1785	59.0	93.6	93.4	92.2	0.81	0.74	0.62	9.0	3.3	4.5	IE4
IM V1 / IM 3011			FS 160 M			IP55	UKCA	IEC/EN 60034		IEC, DIN, ISO, VDE, EN							
Environmental conditions : -20 °C - +40 °C / 1,000 m									Locked rotor time (hot / cold) : 35.4 s 44.6 s								

Sound level (SPL / SWL) at 50Hz 60Hz	63 / 76 dB(A) ^{2) 3)}	66 / 79 dB(A) ^{2) 3)}	Vibration severity grade	A
Moment of inertia	0.0850 kg m ²		Thermal class	F
Bearing DE NDE	6209 2Z C3	6209 2Z C3	Duty type	S1
bearing lifetime			Direction of rotation	bidirectional
L _{10mh} F _{rad min} for coupling operation 50 60Hz ¹⁾	20000 h	16000 h	Frame material	cast iron
Regreasing device	Without		Net weight of the motor (IM B3)	127 kg
Grease nipple	-/-		Coating (paint finish)	Standard paint finish C2
Type of bearing	Locating bearing NDE		Color, paint shade	RAL7030
Condensate drainage holes	With (standard)		Motor protection	(B) 3 PTC thermistors - for tripping (2 terminals)
External earthing terminal	Without		Method of cooling	IC411 - self ventilated, surface cooled

Terminal box position	top	Max. cross-sectional area	16 mm²
Material of terminal box	cast iron	Cable diameter from ... to ...	19 mm - 28 mm
Type of terminal box	TB1 J01	Cable entry	2xM40x1,5-1xM16x1,5
Contact screw thread	M5	Cable gland	3 plugs

Notes:

I_r/I_n = locked rotor current / current nominal	1) L10mh according to DIN ISO 281 10/2010	3) Value is valid only for DOL operation with motor design IC411
M_r/M_n = locked rotor torque / torque nominal	2) at rated power / at full load	
M_b/M_n = break down torque / nominal torque		

responsible dep. DI MC LVM	technical reference	created by DT Configurator	approved by	Technical data are subject to change! There may be discrepancies between calculated and rating plate values.		Link documents	
SIEMENS	document type datasheet			document status released			
	title 1LE1504-1DB23-3GB4-Z B02+H00			document number			
© Siemens AG 2023				rev. 943	creation date 2023-03-14	language en	Page 1/2

SIMOTICS SD - 160 M - IM V1 - 4p

Special design

B02	Acceptance test certificate 3.1 acc. to EN 10204	H00	Canopy
-----	--	-----	--------

Notes:

responsible dep.	technical reference	created by	approved by	Technical data are subject to change! There may be discrepancies between calculated and rating plate values.		Link documents	
DI MC LVM		DT Configurator					
	document type			document status			
	datasheet			released			
	title			document number			
	1LE1504-1DB23-3GB4-Z						
	B02+H00			rev.	creation date	language	Page
© Siemens AG 2023				943	2023-03-14	en	2/2