

Data sheet for three-phase Squirrel-Cage-Motors SIMOTICS



Motor type : 1CV4184B

SIMOTICS SD - 180 L - IM B3 - 4p

Client order no.	Item-No.	Offer no.
Order no.	Consignment no.	Project

Remarks

Electrical data

Safe Area

U	Δ / Y	f	P	P	I	n	M	η ³⁾			cosφ ³⁾			I _A /I _N	M _A /M _N	M _K /M _N	IE-CL
[V]		[Hz]	[kW]	[hp]	[A]	[1/min]	[Nm]	4/4	3/4	2/4	4/4	3/4	2/4	I _I /I _N	T _I /T _N	T _B /T _N	
460	Δ	60	25.30	-/-	41.00	1775	136.0	94.5	94.8	94.6	0.82	0.77	0.67	7.8	2.8	3.7	IE4
IM B3 / IM 1001			FS 180 L		192 kg		IP55			IEC/EN 60034		IEC, DIN, ISO, VDE, EN					
Environmental conditions : -20 °C - +40 °C / 1,000 m									Locked rotor time (hot / cold) : 34.5 s 47.8 s								

Mechanical data

Sound level (SPL / SWL) at 50Hz 60Hz	75.0 / 79.0 dB(A) ²⁾	75.0 / 79.0 dB(A) ²⁾	External earthing terminal	Yes (standard)
Moment of inertia	0.1800 kg m ²		Vibration severity grade	A
Bearing DE NDE	6210 Z C3	6210 Z C3	Insulation	155(F) to 130(B)
bearing lifetime			Duty type	S1
L _{10mh} F _{Rad min} 50 60Hz ¹⁾ for coupling operation	40000 h	32000 h	Direction of rotation	bidirectional
Lubricants	Unirex N3		Frame material	cast iron
Regreasing device	No		Coating (paint finish)	Standard paint finish C2
Grease nipple	-/-		Color, paint shade	RAL7030
Type of bearing	Locating bearing NDE		Motor protection	(F) 1 temperature sensor KTY84-130 (2 terminals)
Condensate drainage holes	Yes (standard)		Method of cooling	IC416 - separately ventilated, surface cooled

Terminal box

Terminal box position	left	Max. cross-sectional area	16.0 mm ²
Material of terminal box	cast iron	Cable diameter from ... to ...	19.0 mm - 28.0 mm
Type of terminal box	TB1 J01	Cable entry	2xM40x1,5-1xM16x1,5
Contact screw thread	M5	Cable gland	3 plugs

Notes:

I_A/I_N = locked rotor current / current nominal

M_K/M_N = locked rotor torque / torque nominal

M_B/M_N = break down torque / nominal torque

1) L10mh according to DIN ISO 281 10/2010

2) at rated power / at full load

3) Value is valid only for DOL operation with motor design IC411

responsible dep.	technical reference	created by	approved by	Technical data are subject to change! There may be discrepancies between calculated and rating plate values.			
DI MC LVM		DT Configurator					
	document type	datasheet		document status		released	
	title	1LE1504-1EB49-0AF6-Z		document number			
© Siemens AG 2021	B02+F70+G06+M1F+R62		rev.	creation date		language	Page
			01	2021-04-21 20:56		en	1/2

SIMOTICS SD - 180 L - IM B3 - 4p

B02	Acceptance test certificate 3.1 acc. to EN 10204	M1F	460 VD for 60 Hz, 60-Hz power
F70	Mounting of separately driven fan	R62	Cast iron auxiliary terminal box (small)
G06	Mounting a rotary pulse encoder HOG 10 D 1024 I		

Notes:

responsible dep. DI MC LVM	technical reference	created by DT Configurator	approved by	Technical data are subject to change! There may be discrepancies between calculated and rating plate values.			
	document type datasheet			document status released		customer	
	title 1LE1504-1EB49-0AF6-Z			document number			
© Siemens AG 2021	B02+F70+G06+M1F+R62			rev. 01	creation date 2021-04-21 20:56	language en	Page 2/2