

SIMOTICS SD - 250 M - IM V15 - 8p

Client order no.	Item-No.	Offer no.
Order no.	Consignment no.	Project

Remarks

Safe Area

U	Δ / Y	f	P	P	I	n	M	η ³⁾			cosφ ³⁾			I _A /I _N	M _A /M _N	M _K /M _N	IE-CL
[V]		[Hz]	[kW]	[hp]	[A]	[1/min]	[Nm]	4/4	3/4	2/4	4/4	3/4	2/4	I _I /I _N	T _I /T _N	T _B /T _N	
DOL duty (S1) - 155(F) to 130(B)																	
400	Δ	50	30.00	-/-	60.00	735	390.0	91.3	91.8	91.5	0.79	0.73	0.62	6.1	2.6	3.0	IE3
690	Y	50	30.00	-/-	35.00	735	390.0	91.3	91.8	91.5	0.79	0.73	0.62	6.1	2.6	3.0	IE3
IM V15 / IM 2011			FS 250 M				IP55	UKCA		IEC/EN 60034		IEC, DIN, ISO, VDE, EN					

Environmental conditions : -20 °C - +40 °C / 1,000 m

Locked rotor time (hot / cold) : 21.9 s | 34.6 s

Sound level (SPL / SWL) at 50Hz 60Hz	60 / 74 dB(A) ^{2) 3)}	65 / 79 dB(A) ^{2) 3)}	External earthing terminal	With (standard)
Moment of inertia	0.8600 kg m²		Vibration severity grade	A
Bearing DE NDE	6315 C3	6315 C3	Thermal class	F
bearing lifetime			Duty type	S1
L10mh F _{red min} for coupling operation 50 60Hz ¹⁾	20000 h	16000 h	Direction of rotation	bidirectional
Relubrication interval/quantity DE NDE	25 g 25 g 8000 h		Frame material	cast iron
Lubricants	Unirex N3		Net weight of the motor (IM B3)	370 kg
Regreasing device	With (standard)		Coating (paint finish)	Special paint finish C3
Grease nipple	M10x1 DIN 3404 A		Color, paint shade	RAL7030
Type of bearing	Locating bearing NDE		Motor protection	(B) 3 PTC thermistors - for tripping (standard) (2 terminals)
Condensate drainage holes	With (standard)		Method of cooling	IC411 - self ventilated, surface cooled

Terminal box position	top	Max. cross-sectional area	120 mm²
Material of terminal box	cast iron	Cable diameter from ... to ...	34 mm - 42 mm
Type of terminal box	TB1 N01	Cable entry	2xM63x1,5-2xM20x1,5
Contact screw thread	M10	Cable gland	4 plugs

Notes:

I_A/I_N = locked rotor current / current nominal
 M_A/M_N = locked rotor torque / torque nominal
 M_K/M_N = break down torque / nominal torque

1) L10mh according to DIN ISO 281 10/2010
2) at rated power / at full load

3) Value is valid only for DOL operation with motor design IC411

responsible dep. DI MC LVM	technical reference	created by DT Configurator	approved by	Technical data are subject to change! There may be discrepancies between calculated and rating plate values.		Link documents 	
	document type datasheet			document status released			
	title 1LE1603-2CD23-4WB4-Z B02+H00			document number			
© Siemens AG 2023				rev. 943	creation date 2023-05-29	language en	Page 1/2

SIMOTICS SD - 250 M - IM V15 - 8p

Special design

B02	Acceptance test certificate 3.1 acc. to EN 10204	H00	Canopy
-----	--	-----	--------

Notes:

responsible dep.	technical reference	created by	approved by	Technical data are subject to change! There may be discrepancies between calculated and rating plate values.		Link documents	
DI MC LVM		DT Configurator					
	document type			document status			
	datasheet			released			
	title			document number			
	1LE1603-2CD23-4WB4-Z						
	B02+H00			rev.	creation date	language	Page
© Siemens AG 2023				943	2023-05-29	en	2/2