


TRANSCLINIC 16I+ 1K5 H**Weidmüller Interface GmbH & Co. KG**

Klingenbergstraße 26

D-32758 Detmold

Germany

www.weidmueller.com**String monitoring with Transclenic xi+
A system that permanently monitors the
performance of photovoltaic facilities.**

The Transclenic xi+ series continuously monitors the power from single strings or groups of strings as well as the voltage of a Photovoltaic system and thereby permits detailed monitoring of the system. Negative influences, which lead to reduced output, can be detected immediately allowing rapid repairs or adjustments to be made to the system.

General ordering data

Version	Photovoltaics
Order No.	2502520000
Type	TRANSCLINIC 16I+ 1K5 H
GTIN (EAN)	4050118515978
Qty.	1 pc(s).

TRANSCLINIC 16I+ 1K5 H

Weidmüller Interface GmbH & Co. KG

Klingenbergstraße 26

D-32758 Detmold

Germany

www.weidmueller.com

Technical data

Dimensions and weights

Depth	368.9 mm	Depth (inches)	14.524 inch
Height	92.92 mm	Height (inches)	3.658 inch
Net weight	940 g	Width	109.5 mm
Width (inches)	4.311 inch		

Temperatures

Operating temperature	-25 °C...70 °C
-----------------------	----------------

Technical data

Communication	MODBUS RS485 RTU	Height	≤ 2000 m
Maximum current per string	25 A DC (-25...+70 °C)	Maximum number of strings	16
Number of digital inputs	2	Pollution severity	2
Rated voltage (text)		Standards	IEC/ EN61010-1:2010, IEC/ EN61010-2-030:2010, EN61326-1:2013
	1500 V DC	String-voltage measurement error	± 18 V from 150 V DC to 1,500 V
String-current measurement error	± 300 mA from 3 A DC to 15 A DC	Voltage supply	19.2 – 28.8 V DC
Supply current	< 70 mA DC, 200 mA DC max.		
current measuring	Shunt resistance 1 mOhm		

Classifications

ETIM 6.0	EC002928	ETIM 7.0	EC002928
ECLASS 9.0	22-57-92-03	ECLASS 9.1	22-57-04-90
ECLASS 10.0	22-57-04-90	ECLASS 11.0	22-57-02-92

Approvals

Approvals



ROHS

Conform

Downloads

Approval/Certificate/Document of Conformity	TRANSCLINIC 16I+ 1K5 HP
Engineering Data	STEP
User Documentation	Manual Transclinic 16i+ family

TRANSCLINIC 16I+ 1K5 H

Weidmüller Interface GmbH & Co. KG
Klingenbergstraße 26
D-32758 Detmold
Germany

www.weidmueller.com

Drawings

