# **SIEMENS**

Product data sheet 3RB2026-1RD0



OVERLOAD RELAY 0.1...0.4 A FOR MOTOR PROTECTION SZ S0, CLASS 10 F. MOUNTING ONTO CONTACTORS MAIN CIRCUIT: SCREW TERMINAL AUX. CIRCUIT: SPRINGLOADED TERM. MANUAL-AUTOMATIC-RESET

General technical data:		
product brand name		SIRIUS
Product designation		solid-state overload relay
Size of overload relay		S0
Number of poles / for main current circuit		3
Product function / removable terminal for auxiliary and control circuit		Yes
Impulse voltage resistance / rated value	kV	6
Protection class IP		IP20
Protection class IP / on the front		IP20
Protection against electrical shock		finger-safe
Installation altitude / at a height over sea level / maximum	m	2,000
Resistance against shock		15g / 11 ms
Ambient temperature		
during transport	°C	-40 +80
during storage	°C	-40 +80
during operating	°C	-25 +60
Relative humidity / during operating phase / maximum	%	100
Electrostatic discharge / according to IEC 61000-4-2		6 kV contact discharge / 8 kV air discharge
Field-bound parasitic coupling / according to IEC 61000-4-3		10 V/m

Conductor-bound parasitic coupling BURST / according to IEC 61000-4-4		2 kV (power ports), 1 kV (signal ports) corresponds to degree of severity 3
Conductor-bound parasitic coupling conductor-earth SURGE / according to IEC 61000-4-5		2 kV (line to earth) corresponds to degree of severity 3
Conductor-bound parasitic coupling conductor-conductor SURGE / according to IEC 61000-4-5		1 kV (line to line) corresponds to degree of severity 3
Type of protection		PTB 06 ATEX 3001 Ex II (2) GD
Active power loss / total / typical	W	0.05
Size of the contactor / can be combined / company-specific		S0

Main circuit:		
Operating current / of the fuse link / rated value	Α	1
Type of assignement		2

Auxiliary circuit:		
Number of NC contacts / for auxiliary contacts		1
Number of NO contacts / for auxiliary contacts		1
Number of changeover contacts / for auxiliary contacts		0
Design of the fuse link / for short-circuit protection of the auxiliary switch / required		fuse gL/gG: 6 A
Operating current / of the auxiliary contacts		
• at AC-15		
• at 24 V	Α	4
• at 110 V	Α	4
• at 120 V	Α	4
• at 125 V	Α	4
• at 230 V	Α	3
• at DC-13		
• at 24 V	Α	2
• at 60 V	Α	0.55
• at 110 V	Α	0.3
• at 125 V	Α	0.3
• at 220 V	Α	0.11

Protective and monitoring functions:		
Trip class		CLASS 10
Adjustable response current / of the current-dependent overload release	Α	0.1 0.4

Installation/ mounting/ dimensions:		
Mounting type		direct mounting
mounting position		any
Depth	mm	75

Height	mm	73
Width	mm	45

Connections/ terminals:	
Design of the electrical connection	
for main current circuit	screw-type terminals
for auxiliary and control current circuit	spring-loaded terminals
Type of the connectable conductor cross-section	
for main contacts	
• solid	2x (1 2.5 mm²), 2x (2.5 6 mm²)
• finely stranded	
<ul> <li>with conductor end processing</li> </ul>	2x (1 2.5 mm²), 2x (2.5 6 mm²)
• for AWG conductors / for main contacts	2x (14 10)
for auxiliary contacts	
• solid	2x (0.25 1.5 mm²)
• finely stranded	
<ul> <li>with conductor end processing</li> </ul>	2x (0.25 1.5 mm²)
• for AWG conductors / for auxiliary contacts	2x (24 16)

# Certificates/ approvals:

**General Product Approval** 

**EMC** 

For use in hazardous locations













#### **Test Certificates**

Special Test Certificate Type Test
Certificates/Test
Report

## **Shipping Approval**







GL





#### other

Declaration of Conformity

other

Environmental Confirmations

## Further information:

Information- and Downloadcenter (Catalogs, Brochures,...)

http://www.siemens.com/industrial-controls/catalogs

Industry Mall (Online ordering system)

http://www.siemens.com/industrial-controls/mall

#### Cax online generator

http://www.siemens.com/cax

Service&Support (Manuals, Certificates, Characteristics, FAQs,...)

http://support.automation.siemens.com/WW/view/en/3RB2026-1RD0/all

Image database (product images, 2D dimension drawings, 3D models, device circuit diagrams, ...)

http://www.automation.siemens.com/bilddb/cax\_en.aspx?mlfb=3RB2026-1RD0

last change: Jun 16, 2014