SIEMENS

Product data sheet 3RB2046-2EB0



OVERLOAD RELAY 25...100 A FOR MOTOR PROTECTION SIZE S3, CLASS 20 FOR MOUNTING ONTO CONT. MAIN CIRCUIT: SCREW CONNECTION AUX. CIRCUIT: SCREW CONNECTION MANUAL-AUTOMATIC-RESET

General technical data:		
product brand name		SIRIUS
Product designation		solid-state overload relay
Size of overload relay		S3
Number of poles / for main current circuit		3
Product function / removable terminal for auxiliary and control circuit		Yes
Impulse voltage resistance / rated value	kV	8
Protection class IP		IP20
Protection class IP / on the front		IP20
Protection against electrical shock		finger-safe
Installation altitude / at a height over sea level / maximum	m	2,000
Resistance against shock		15g / 11 ms
Ambient temperature		
during transport	°C	-40 +80
during storage	°C	-40 +80
during operating	°C	-25 +60
Relative humidity / during operating phase / maximum	%	100
Electrostatic discharge / according to IEC 61000-4-2		6 kV contact discharge / 8 kV air discharge
Field-bound parasitic coupling / according to IEC 61000-4-3		10 V/m

Conductor-bound parasitic coupling BURST / according to IEC 61000-4-4		2 kV (power ports), 1 kV (signal ports) corresponds to degree of severity 3
Conductor-bound parasitic coupling conductor-earth SURGE / according to IEC 61000-4-5		2 kV (line to earth) corresponds to degree of severity 3
Conductor-bound parasitic coupling conductor-conductor SURGE / according to IEC 61000-4-5		1 kV (line to line) corresponds to degree of severity 3
Type of protection		PTB 06 ATEX 3001 Ex II (2) GD
Active power loss / total / typical	W	0.05
Size of the contactor / can be combined / company-specific		S3

Main circuit:		
Operating current / of the fuse link / rated value	Α	315
Type of assignement		2

Auxiliary circuit:		
Number of NC contacts / for auxiliary contacts		1
Number of NO contacts / for auxiliary contacts		1
Number of changeover contacts / for auxiliary contacts		0
Design of the fuse link / for short-circuit protection of the auxiliary switch / required		fuse gL/gG: 6 A
Operating current / of the auxiliary contacts		
• at AC-15		
• at 24 V	Α	4
• at 110 V	Α	4
• at 120 V	Α	4
• at 125 V	Α	4
• at 230 V	Α	3
• at DC-13		
• at 24 V	Α	2
• at 60 V	Α	0.55
• at 110 V	Α	0.3
• at 125 V	Α	0.3
• at 220 V	Α	0.11

Protective and monitoring functions:		
Trip class		CLASS 20
Adjustable response current / of the current-dependent overload release	А	25 100

Installation/ mounting/ dimensions:		
Mounting type		direct mounting
mounting position		any
Depth	mm	124

Height	mm	106
Width	mm	70

Connections/ terminals:	
Design of the electrical connection	
for main current circuit	screw-type terminals
 for auxiliary and control current circuit 	screw-type terminals
Type of the connectable conductor cross-section	
• for main contacts	
• solid	2x (2.5 16 mm²)
• finely stranded	
 with conductor end processing 	2x (2.5 35 mm²), 2.5 50 mm²
• stranded	2x (10 50 mm²), 10 70 mm²
• for AWG conductors / for main contacts	2x (10 1/0), 1x (10 2/0)
for auxiliary contacts	
• solid	0.5 4 mm², 2x (0.5 2.5 mm²)
• finely stranded	
 with conductor end processing 	0.5 2.5 mm², 2x (0.5 1.5 mm²)
• for AWG conductors / for auxiliary contacts	2x (20 14)

Certificates/ approvals:

General Product Approval

EMC

For use in hazardous locations













Test Certificates

Special Test Certificate Type Test
Certificates/Test
Report

Shipping Approval











other

Declaration of Conformity

other

Environmental Confirmations

Further information:

Information- and Downloadcenter (Catalogs, Brochures,...)

http://www.siemens.com/industrial-controls/catalogs

Industry Mall (Online ordering system)

http://www.siemens.com/industrial-controls/mall

Cax online generator


http://www.siemens.com/cax


Service&Support (Manuals, Certificates, Characteristics, FAQs,...)

http://support.automation.siemens.com/WW/view/en/3RB2046-2EB0/all

Image database (product images, 2D dimension drawings, 3D models, device circuit diagrams, ...)

http://www.automation.siemens.com/bilddb/cax_en.aspx?mlfb=3RB2046-2EB0





last change: Jun 16, 2014