# **SIEMENS**

Product data sheet 3RB2283-4AC1



PROCESSING UNIT FOR FULL MOTOR PROTECTION SIZE S00...S12,

CLASS 5...30 STAND-ALONE INSTALLATION MAIN CIRCUIT: -- AUX. CIRCUIT: SPRINGLOAD. TERM. MANUAL-AUTOMATIC-RESET

General technical data:		
product brand name		SIRIUS
Product designation		solid-state overload relay
Size of overload relay		S00 S12
Number of poles / for main current circuit		3
Product function / removable terminal for auxiliary and control circuit		Yes
Impulse voltage resistance / rated value	kV	4
Protection class IP		IP20
Protection class IP / on the front		IP20
Protection against electrical shock		finger-safe
Installation altitude / at a height over sea level / maximum	m	2,000
Resistance against shock		15g / 11 ms
Ambient temperature		
during transport	°C	-40 +80
during storage	°C	-40 <b>+</b> 80
during operating	°C	-25 +60
Relative humidity / during operating phase / maximum	%	100
Electrostatic discharge / according to IEC 61000-4-2		6 kV contact discharge / 8 kV air discharge
Field-bound parasitic coupling / according to IEC 61000-4-3		10 V/m

Conductor-bound parasitic coupling BURST / according to IEC 61000-4-4		2 kV (power ports), 1 kV (signal ports) corresponds to degree of severity 3
Conductor-bound parasitic coupling conductor-earth SURGE / according to IEC 61000-4-5		2 kV (line to earth) corresponds to degree of severity 3
Conductor-bound parasitic coupling conductor-conductor SURGE / according to IEC 61000-4-5		1 kV (line to line) corresponds to degree of severity 3
Type of protection		PTB 05 ATEX 3022 Ex II (2) GD
Active power loss / total / typical	W	0.5
Size of the contactor / can be combined / company-specific		S00 S12
Main circuit:		
Type of voltage		AC/DC
Control circuit/ Control:		
Control supply voltage		
• for DC / rated value	V	24 240
• at 50 Hz / at AC / rated value	V	24 240
• at 60 Hz / at AC / rated value	V	24 240
Auxiliary circuit:		
Number of NC contacts / for auxiliary contacts		2
Number of NO contacts / for auxiliary contacts		2
Number of changeover contacts / for auxiliary contacts		0
Design of the fuse link / for short-circuit protection of the auxiliary switch / required		fuse gL/gG: 6 A
Operating current / of the auxiliary contacts		
• at AC-15		
• at 24 V	Α	6
• at 110 V	Α	6
• at 120 V	Α	6
• at 125 V	Α	6
• at 230 V	Α	3
• at DC-13		
• at 24 V	Α	2
• at 60 V	Α	0.55
• at 110 V	Α	0.3
• at 125 V	Α	0.3
		0.2

Protective and monitoring functions:			
Trip class		CLASS 5, 10, 20 and 30 adjustable	
Adjustable response current / of the current-dependent overload release	А	0.3 630	

Installation/ mounting/ dimensions:				
Mounting type		stand-alone installation		
mounting position		any		
Depth	mm	95		
Height	mm	111		
Width	mm	45		

Connections/ terminals:			
Design of the electrical connection			
• for auxiliary and control current circuit		spring-loaded terminals	
Type of the connectable conductor cross-section			
for auxiliary contacts			
• solid		2x (0.25 1.5 mm²)	
• finely stranded			
<ul> <li>with conductor end processing</li> </ul>		2x (0.25 1.5 mm²)	
• for AWG conductors / for auxiliary contacts		2x (24 16)	

# Certificates/ approvals:

## **General Product Approval**







**EMC** 



For use in hazardous locations

# **Test Certificates**

Special Test Certificate Type Test
Certificates/Test
Report



**Shipping Approval** 







#### other

Confirmation

Declaration of Conformity

Environmental Confirmations

## **Further information:**

Information- and Downloadcenter (Catalogs, Brochures,...)

http://www.siemens.com/industrial-controls/catalogs

# Industry Mall (Online ordering system)

 $\underline{\text{http://www.siemens.com/industrial-controls/mall}}$ 

## Cax online generator


http://www.siemens.com/cax


### Service&Support (Manuals, Certificates, Characteristics, FAQs,...)

 $\underline{\text{http://support.automation.siemens.com/WW/view/en/3RB2283-4AC1/all}}$ 

 $Image\ database\ (product\ images,\ 2D\ dimension\ drawings,\ 3D\ models,\ device\ circuit\ diagrams,\ ...)$ 

http://www.automation.siemens.com/bilddb/cax\_en.aspx?mlfb=3RB2283-4AC1





last change: Jun 16, 2014