SIEMENS

Product data sheet 3RH1911-2FB22

AUXILIARY SWITCH BLOCK 11, 11U, DIN EN 50005, (1 NO+1 NC AND 1 NO +1NC MAKE- BEFORE-BREAK) CAGE CLAMP CONNECTION, SIZE S00, FOR AUXIL. AND MOTOR CONTACTOR

General technical data:		
product brand name		SIRIUS
Acceptability for application		Contactor relay and power contactor
Protection class IP / on the front		IP20
Ambient temperature		
during storage	°C	-55 +80
during operating	°C	-25 +60
Mechanical operating cycles as operating time		
• typical		10,000,000
Electrical operating cycles as operating time / at AC-15 / at 230 $$ V		
• typical		200,000
Contact reliability		one incorrect switching operation of 100 million switching operations (17 V, 5 mA)
Contact reliability / of the auxiliary contacts		1 faulty switching per 100 million (17 V, 1 mA)
Insulation voltage / with degree of pollution 3		
• rated value	V	690
Impulse voltage resistance		
• rated value	kV	6

Auxiliary circuit:		
Number of NC contacts / for auxiliary contacts		
• instantaneous switching		1
lagging switching		1
Number of NO contacts / for auxiliary contacts		
• instantaneous switching		1
leading switching		1
Operating current / of the auxiliary contacts / at AC-12		
• at 24 V	Α	10
• at 230 V	Α	10
• maximum	Α	10
Operating current		

of the auxiliary contacts		
• at AC-14		
• at 125 V	А	6
• at 250 V	А	6
• at AC-15		
• at 24 V	Α	6
• at 230 V	Α	6
• at 400 V	А	3
• at AC-15 / at 690 V	А	1
Operating current		
• with 2 current paths in series / at DC-12		
• at 24 V / rated value	А	10
• at 60 V / rated value	Α	10
• at 110 V / rated value	А	4
• at 220 V / rated value	А	2
• at 440 V / rated value	Α	1.3
• at 600 V / rated value	Α	0.65
• with 3 current paths in series / at DC-12		
• at 24 V / rated value	Α	10
• at 60 V / rated value	Α	10
• at 110 V / rated value	А	10
• at 220 V / rated value	А	3.6
• at 440 V / rated value	Α	2.5
• at 600 V / rated value	Α	1.8
Operating current		
• of the auxiliary contacts / at DC-13		
• at 24 V	Α	6
• at 60 V	Α	2
• at 110 V	Α	1
• at 220 V	Α	0.3
• with 2 current paths in series / at DC-13		
• at 24 V / rated value	А	10
• at 60 V / rated value	А	3.5
• at 110 V / rated value	Α	1.3
• at 220 V / rated value	Α	0.9
• at 440 V / rated value	Α	0.2
• at 600 V / rated value	Α	0.1
• with 3 current paths in series / at DC-13		
• at 24 V / rated value	А	10
• at 60 V / rated value	Α	4.7

• at 110 V / rated value	Α	3
• at 220 V / rated value	Α	1.2
• at 440 V / rated value	Α	0.5
• at 600 V / rated value	Α	0.26

Installation/ mounting/ dimensions:		
Mounting type		snap-on mounting
Width	mm	36.5
Height	mm	37.5
Depth	mm	46

Connections/ terminals:		
Design of the electrical connection		
for auxiliary and control current circuit	spring-loaded terminals	
Type of the connectable conductor cross-section		
for auxiliary contacts		
finely stranded		
 with conductor end processing 	2x (0.5 1.5 mm²)	
 without conductor final cutting 	2x (0.5 2.5 mm²)	
• for AWG conductors / for auxiliary contacts	2x (20 14)	

Safety:	
Product function / mirror contact to IEC 60947-4-1	Yes
• comment	with 3RT1
Product function / positively driven operation to IEC 60947-5-1	Yes
• comment	with 3RH1

Certificates/ approvals:

General Product Approval

Functional Safety / Safety of Machinery Declaration of Conformity

Type Examination











Test Certificates

Special Test Certificate

Shipping Approval













other

other

Environmental Confirmations

Further information:

Information- and Downloadcenter (Catalogs, Brochures,...)

http://www.siemens.com/industrial-controls/catalogs

Industry Mall (Online ordering system)

http://www.siemens.com/industrial-controls/mall

Cax online generator


http://www.siemens.com/cax


 ${\bf Service \& Support\ (Manuals,\ Certificates,\ Characteristics,\ FAQs,...)}$

 $\underline{\text{http://support.automation.siemens.com/WW/view/en/3RH1911-2FB22/all}}$

 $Image\ database\ (product\ images,\ 2D\ dimension\ drawings,\ 3D\ models,\ device\ circuit\ diagrams,\ ...)$

 $\underline{\text{http://www.automation.siemens.com/bilddb/cax_en.aspx?mlfb=3RH1911-2FB22}}$





last change: Jun 16, 2014