
SIEMENS

Data sheet 3RT2944-5AF01

magnetic coil 110 V AC, 50 Hz, for contactors 3RT2.4.-.A



product brand name	SIRIUS
product designation	Magnet coil
Substance Prohibitance (Date)	10/01/2014
type of voltage of the control supply voltage	AC
control supply voltage 1 at AC	
• at 50 Hz rated value	110 V
control supply voltage frequency	
1 rated value	50 Hz
operating range factor control supply voltage rated value of magnet coil at AC	
● at 50 Hz	0.8 1.1
apparent pick-up power of magnet coil at AC	
● at 50 Hz	296 VA
inductive power factor with closing power of the coil	
● at 50 Hz	0.61
apparent holding power of magnet coil at AC	
● at 50 Hz	19 VA
inductive power factor with the holding power of the coil	
● at 50 Hz	0.38
Approvals Certificates	

General Product Approval EMC Declaration of Conformity Marine / Shipping

Confirmation











Marine / Shipping

other



Confirmation

Siemens has decided to exit the Russian market (see here).

Siemens is working on the renewal of the current EAC certificates.

Please contact your local Siemens office on the status of validity of the EAC certification if you intend to import or offer to supply these products to an EAC relevant market (other than the sanctioned EAEU member states Russia or Belarus).

Information on the packaging

https://support.industry.siemens.com/cs/ww/en/view/109813875

Information- and Downloadcenter (Catalogs, Brochures,...)

https://www.siemens.com/ic10

Industry Mall (Online ordering system)

https://mall.industry.siemens.com/mall/en/en/Catalog/product?mlfb=3RT2944-5AF01

Cax online generator
http://support.automation.siemens.com/WW/CAXorder/default.aspx?lang=en&mlfb=3RT2944-5AF01

Service&Support (Manuals, Certificates, Characteristics, FAQs,...) https://support.industry.siemens.com/cs/ww/en/ps/3RT2944-5AF01

Image database (product images, 2D dimension drawings, 3D models, device circuit diagrams, EPLAN macros, ...) http://www.automation.siemens.com/bilddb/cax_de.aspx?mlfb=3RT2944-5AF01&lang=en

last modified:	1/12/2021 🖸
----------------	-------------