SIEMENS

Product data sheet 3RV1031-4DA10-0BA0

CIRCUIT BREAKER SZ S2,
FOR MOTOR PROTECTION, CLASS 10,
A-REL. 18...25A, N-REL. 325A,
SCREW TERMINAL,
STANDARD BREAKING CAPACITY AMBIENT
TEMPERATURE -50 DEGR. C 500 SWITCHING CYCLES

| General technical data: | | |
|--|----|-----------------|
| product brand name | | SIRIUS |
| product designation | | circuit breaker |
| Size of the circuit-breaker | | S2 |
| Number of poles / for main current circuit | | 3 |
| Product function | | |
| removable terminal for auxiliary and control circuit | | No |
| overload protection | | Yes |
| phase disturbance recognition | | Yes |
| short-circuit to earth recognition | | No |
| Product component | | |
| auxiliary switch | | No |
| undervoltage release mechanism | | No |
| • trip indicator | | No |
| Product extension | | |
| auxiliary switch | | Yes |
| optional / motor drive | _ | Yes |
| Impulse voltage resistance / rated value | V | 6,000 |
| Protection class IP / on the front | | IP20 |
| Protection against electrical shock | | finger-safe |
| Installation altitude / at a height over sea level / maximum | m | 2,000 |
| Resistance against shock | | 25g / 11 ms |
| Ambient temperature | | |
| during transport | °C | -50 + 80 |
| during storage | °C | -50 + 80 |
| during operating | °C | -50 +7 0 |
| Active power loss / total / typical | W | 12 |
| Main circuit: | | |
| Operating voltage / rated value | V | 690 |

| type of voltage | | AC/DC |
|--|-----|-------|
| Service power / at AC-3 / at 400 V / rated value | kW | 11 |
| Operational current / at AC-3 / at 400 V / rated value | А | 25 |
| Mechanical operating cycles as operating time / of the main contacts / typical | | 500 |
| Frequency of operation / at AC-3 / according to IEC 60947-6-2 | 1/h | 15 |

| Auxiliary circuit: | | |
|---|---|--|
| Number of change-over switches / for auxiliary contacts | 0 | |

| Protection function: | | |
|---|----|----------|
| Trip class | | CLASS 10 |
| Adjustable response current / of the current-dependent overload release | А | 18 25 |
| Breaking capacity limit short-circuit current (Icu) | | |
| • at 400 V / rated value | kA | 50 |
| • at 500 V / rated value | kA | 12 |
| • at 690 V / rated value | kA | 5 |

| Installation/mounting/dimensions: | | |
|-----------------------------------|----|--|
| Type of mounting | | screw and snap-on mounting onto 35 mm standard mounting rail according to DIN EN 50022 |
| mounting position | | any |
| Depth | mm | 149 |
| Height | mm | 140 |
| Width | mm | 55 |

| Connections: | |
|---|---|
| Arrangement of electrical connectors / for main current circuit | front side |
| Design of the electrical connection | |
| • for main current circuit | screw-type terminals with box terminals |
| for auxiliary and control current circuit | screw-type terminals |
| Type of the connectable conductor cross-section | |
| • for main contacts | |
| • solid | 2x (0.75 16 mm²) |
| • finely stranded | |
| with conductor end processing | 2x (0.75 16 mm²), 0.75 25 mm² |
| • stranded | 2x (0.75 25 mm²), 0.75 35 mm² |
| • for AWG conductors / for main contacts | 2x (18 2), 1x (18 2) |
| | |

Certificates/approvals:

General Product Approval

For use in hazardous locations

Declaration of Conformity













Test Certificates

Shipping Approval

Special Test Certificate











other

Confirmation

Declaration of Conformity

other

Environmental Confirmations

Further information:

Information- and Downloadcenter (Catalogs, Brochures,...)

http://www.siemens.com/industrial-controls/catalogs

Industry Mall (Online ordering system)

http://www.siemens.com/industrial-controls/mall

Cax online generator:


http://www.siemens.com/cax


Service&Support (Manuals, Certificates, Characteristics, FAQs,...)


http://support.automation.siemens.com/WW/view/en/3RV1031-4DA10-0BA0/all

Image database (product images, 2D dimension drawings, 3D models, device circuit diagrams, ...)

 $\underline{\text{http://www.automation.siemens.com/bilddb/cax_en.aspx?mlfb=3RV1031-4DA10-0BA0}$







last change:

Feb 11, 2013