SIEMENS

Product data sheet 3TK2845-1FB44



SIRIUS SAFETY RELAY WITH REL.- U. EL. RELEASE CIRCUIT (RC),
DC 24V, 45.0MM, SCREW TERMINAL,
RC INSTANT.: 2S, RC DELAYED: 1, MK: 1,
SPRING-LOCKED TUMBLER, BASIC DEVICE,
MAX. ACHIEVABLE PL TO EN13849-1: E,
MAX. ACHIEVABLE SIL TO IEC61508:3,

General technical details:		
product brand name		SIRIUS
product designation		safety relays
Design of the product		spring-locked tumbler
protection class IP / of the housing		IP20
Protection class IP / of the terminal		IP20
Protection against electrical shock		finger-safe
Insulation voltage / rated value	V	300
Ambient temperature		
during storage	°C	-40 +80
during operating	°C	-25 +60
Air pressure		
according to SN 31205	kPa	90 106
Relative humidity		
during operating phase	%	10 95
Installation altitude / at a height over sea level / maximum	m	2,000
Resistance against vibration / according to IEC 60068-2-6		5 500 Hz: 0,075 mm
Resistance against shock		8g / 10 ms and 15g / 5 ms
Impulse voltage resistance / rated value	V	4,000

EMC emitted interference		IEC 60947-5-1, IEC 60000-4-3, IEC 60000-4-5, IEC 60000-4-6
Installation environment relating to EMC		This product is suitable for Class A environments only. It can cause undesired radio-frequency interference in residential environments. If this is the case, the user must take appropriate measures.
Item designation		
 according to DIN 40719 extendable after IEC 204-2 / according to IEC 750 		КТ
according to DIN EN 61346-2		F
Number of sensor inputs		
• 1-channel or 2-channel		2
Design of the cascading		cascading or in-service switching
Type of the safety-related wiring / of the inputs		single-channel and two-channel
Product feature / transverse contact-secure		Yes
Safety Integrity Level (SIL)		
according to IEC 61508		SIL3
• for delayed release circuit / according to IEC 61508		SIL3
SIL claim limit (for a subsystem) / according to EN 62061		3
Performance Level (PL)		
according to ISO 13849-1		е
• for delayed release circuit / according to ISO 13849-1		е
Category / according to EN 954-1		4
Category / according to ISO 13849-1		4
Hardware fault tolerance / according to IEC 61508		1
Safety device type / according to IEC 61508-2		Туре В
Probability of dangerous failure per hour (PFHD) / with high demand rate / according to EN 62061	1/h	0.69E-8
T1 value / for proof test interval or service life / according to IEC 61508	а	20
Number of outputs / as contact-affected switching element		
• as NC contact / for reporting function / instantaneous switching		0
as NO contact / safety-related / instantaneous switching		1
as NO contact / safety-related / delayed switching		1
Number of outputs / as contact-less semiconductor switching element		
safety-related		
delayed switching		1
• non-delayed		1
for reporting function		
delayed switching		0
• non-delayed		1

General technical details:		
Design of the input		
 cascading-input/functional switching 		Yes
• feedback input		Yes
start input		Yes
Design of the electrical connection / jumper socket		Yes
Operating cycles / maximum	1/h	2,000
Switching capacity current		
of semiconductor outputs		
• for signaling function / for DC-13 / at 24 V	Α	0.5
• for enabling circuit / for DC-13 / at 24 V	Α	1
of NO contacts of relay outputs		
• at DC-13		
• at 24 V	Α	1
• at 115 V	Α	0.1
• at 230 V	Α	0.1
• at AC-15		
• at 115 V	Α	3
• at 230 V	Α	3
Mechanical operating cycles as operating time / typical		100,000
Design of the fuse link / for short-circuit protection of the NO contacts of the relay outputs / required		gL/gG: 4 A or fast-acting: 4A
Resistance to direct current / of the cable / maximum	Ω	1,000
Cable length / between sensor and electronic evaluation device / with Cu 1.5 mm² and 150 nF/km / maximum	m	1,000
Make time / with automatic start		
• typical	ms	60
• for DC / maximum	ms	100
Make time / with monitored start		
• maximum	ms	100
• typical	ms	60
Backslide delay time / at mains power cut		
• typical	ms	25
• maximum	ms	30
Adjustable backslide delay time		
after opening of the safety circuits	s	5 300
Recovery time / after opening of the safety circuits / typical	ms	400
Recovery time / after mains power cut / typical	S	8
Pulse duration		

of the sensor input / minimum	ms	45
of the ON pushbutton input / minimum	s	0.2
of the cascading-entrance / minimum	s	0.045

Control circuit:		
Type of voltage / of the controlled supply voltage		DC
Control supply voltage / 1 / for DC / rated value	V	24
operating range factor control supply voltage rated value / of the magnet coil		
• for DC		0.85 1.15

Installation/mounting/dimensions:		
mounting position		any
Type of mounting		screw and snap-on mounting
Width	mm	45
Height	mm	138.5
Depth	mm	88

Connections:	
Design of the electrical connection	screw-type terminals
Type of the connectable conductor cross-section	
• solid	1x (0.5 4 mm²), 2x (0.5 2.5 mm²)
finely stranded	
with wire end processing	1x (0.5 2.5 mm²), 2x (0.5 1.5 mm²)
Type of the connectable conductor cross-section / for AWG conductors	
• solid	2x (20 14)
• stranded	2x (20 14)

Product Function:		
Product function		
light barrier monitoring	No	
standstill monitoring	No	
protective door monitoring	Yes	
automatic start	No	
 magnetic switch monitoring Normally closed contact-Normally open contact 	No	
rotation speed monitoring	No	
laser scanner monitoring	No	
monitored start-up	Yes	
light grid monitoring	No	

 magnetic switch monitoring Normally closed contact-Normally closed contact 	No
emergency stop function	Yes
step mat monitoring	No
Suitability for interaction / pressing control	No
Acceptability for application	
monitoring of floating sensors	Yes
monitoring of non-floating sensors	Yes
safety cut-out switch	Yes
position switch monitoring	Yes
EMERGENCY-OFF circuit monitoring	Yes
valve monitoring	No
tactile sensor monitoring	Yes
 magnetically operated switches monitoring 	Yes
safety-related circuits	Yes

Certificates/approvals:

 Verification of suitability
 UL, CSA, EN 60204-1, EN ISO 12100, EN 954-1, IEC 61508

 • TÜV (German technical inspectorate) certificate
 Yes

 • UL-registration
 Yes

 • BG BIA certificate
 Yes

General Product Approval

EMC

Functional Safety / Safety of Machinery













Declaration of Conformity Test Certificates

other

 ϵ

Special Test Certificate Confirmation

Environmental Confirmations

Further information:

Information- and Downloadcenter (Catalogs, Brochures,...)

http://www.siemens.com/industrial-controls/catalogs

Industry Mall (Online ordering system)

http://www.siemens.com/industrial-controls/mall

Cax online generator:


http://www.siemens.com/cax


Service&Support (Manuals, Certificates, Characteristics, FAQs,...)

http://support.automation.siemens.com/WW/view/en/3TK2845-1FB44/all

Image database (product images, 2D dimension drawings, 3D models, device circuit diagrams, ...)

http://www.automation.siemens.com/bilddb/cax_en.aspx?mlfb=3TK2845-1FB44





last change: Feb 18, 2013