## **SIEMENS**

Product data sheet 3TK2852-2AL20



SIRIUS SAFETY RELAY WITH AUXILIARY CONTACTOR RELEASE CIRCUIT (RC),

AC 230V, 90.0MM,

SPRING-LOADED TERMINAL, RC INSTANT.: 6S, RC DELAYED: 0,

MC: 1NC, AUTOSTART / MONITORED START, BASIC DEVICE, MAX. ACHIEVABLE SIL: 2,

PL: D

General technical details:		
product brand name		SIRIUS
product designation		safety relays
Design of the product		for EMERGENCY-STOP units
protection class IP / of the housing		IP20
Protection class IP / of the terminal		IP20
Protection against electrical shock		finger-safe
Insulation voltage / rated value	V	690
Ambient temperature		
during storage	°C	-40 +80
during operating	°C	-25 +60
Air pressure		
according to SN 31205	kPa	90 106
Relative humidity		
during operating phase	%	10 95
Installation altitude / at a height over sea level / maximum	m	2,000
Resistance against vibration / according to IEC 60068-2-6		5 500 Hz: 0,075 mm
Resistance against shock		5g / 11 ms
Impulse voltage resistance / rated value	V	6,000

EMC emitted interference		IEC 60947-5-1, IEC 60000-4-3, IEC 60000-4-5, IEC 60000-4-6
Installation environment relating to EMC		This product is suitable for Class A environments only. It can cause undesired radio-frequency interference in residential environments. If this is the case, the user must take appropriate measures.
Item designation		
<ul> <li>according to DIN 40719 extendable after IEC 204-2 / according to IEC 750</li> </ul>		КТ
according to DIN EN 61346-2		F
Contact reliability		one incorrect switching operation of 100 million switching operations (17 V, 5 mA)
Number of sensor inputs		
• 1-channel or 2-channel		1
Design of the cascading		none
Type of the safety-related wiring / of the inputs		single-channel and two-channel
Product feature / transverse contact-secure		Yes
Safety Integrity Level (SIL)		
according to IEC 61508		SIL2
SIL claim limit (for a subsystem) / according to EN 62061		2
Performance Level (PL)		
according to ISO 13849-1		d
Category / according to EN 954-1		3
Category / according to ISO 13849-1		3
Hardware fault tolerance / according to IEC 61508		1
Safety device type / according to IEC 61508-2		Type B
Probability of dangerous failure per hour (PFHD) / with high demand rate / according to EN 62061	1/h	0.11E-7
T1 value / for proof test interval or service life / according to IEC 61508	а	20
Number of outputs / as contact-affected switching element		
as NC contact / for reporting function / instantaneous switching		1
as NO contact / safety-related / instantaneous switching		6
as NO contact / safety-related / delayed switching		0
Number of outputs / as contact-less semiconductor switching element		
safety-related		
delayed switching		0
non-delayed		0
for reporting function		
delayed switching		0
• non-delayed		0
Stop category / according to DIN EN 60204-1		0

Design of the Input	General technical details:		
- feedback input	Design of the input		
Pesign of the electrical connection / Jumper socket	cascading-input/functional switching		No
Design of the electrical connection / jumper socket   Yes	• feedback input		Yes
1/h   1,000	• start input		Yes
Switching capacity current              • of NO contacts of relay outputs             • at DC-13             • at 24 V             • at 115 V             • at 230 V             • at 230 V             • at 115 V             • at 230 V             • at 115 V             • at 230 V             • at 230 V             • at 115 V             • at 230 V             • at 230 V             • at 230 V             • at 115 V             • at 230 V             • at 230 V             • A             • A	Design of the electrical connection / jumper socket		Yes
• of NO contacts of relay outputs         • at DC-13           • at 24 V         A         10           • at 115 V         A         1           • at 230 V         A         6           • at 115 V         A         6           • at 230 V         A         6           • of NC contacts of relay outputs         A         6           • at DC-13         A         10           • at 24 V         A         10           • at 115 V         A         1           • at 230 V         A         6           • at AC-15         A         6           • at 115 V         A         6           • at 230 V         A         6           • at AC-15         A         6           • at 3230 V         A         6           Mechanical operating cycles as operating time / typical         30,000,000           Max, permissible voltage for safe isolation / between electronic evaluation device and enabling circuit / according to EN 60947-1         V         400           Design of the fuse link / for short-circuit protection of the NO contacts of the relay outputs / required         T         250           Resistance to direct current / of the cable / maximum         Ω         250 <tr< td=""><td>Operating cycles / maximum</td><td>1/h</td><td>1,000</td></tr<>	Operating cycles / maximum	1/h	1,000
- at DC-13 - at 24 V - at 115 V - at 230 V - at AC-15 - at 116 V - at 230 V - of NC contacts of relay outputs - at 24 V - at 116 V - at 230 V - of NC contacts of relay outputs - at DC-13 - at 24 V - at 116 V - at 230 V - at 115 V - at 230 V - at NC-15 - at 115 V - at 230 V - at AC-15 - at 115 V - at 230 V - at 3000,0000 - at 2000,0000 - at 2000,	Switching capacity current		
• at 24 V         A         10           • at 115 V         A         1           • at 230 V         A         0,3           • at 115 V         A         6           • at 230 V         A         6           • of NC contacts of relay outputs         A         6           • at DC-13         A         10           • at 24 V         A         1           • at 230 V         A         1           • at 230 V         A         0,3           • at AC-15         A         6           • at 115 V         A         6           • at 230 V         A         6           Mace, permissible voltage for safe isolation / between electronic evaluation device and enabling circuit / according to EN 60947-1         V         400           Design of the fuse link / for short-circuit protection of the NO contacts of the relay outputs / required         gL/gG: 10 A         m         2,000           Resistance to direct current / of the cable /	of NO contacts of relay outputs		
• at 115 V         A         1           • at 230 V         A         0.3           • at AC-15         A         6           • at 116 V         A         6           • at 230 V         A         6           • at DC-13         A         10           • at 115 V         A         1           • at 230 V         A         0.3           • at AC-15         A         6           • at 115 V         A         6           • at 230 V         A         6           Mechanical operating cycles as operating time / typical         A         6           Max. permissible voltage for safe isolation / between electronic evaluation device and enabling circuit / according to EN 60947-1         V         400           Design of the fuse link / for short-circuit protection of the NO contacts of the relay outputs / required         V         400           Resistance to direct current / of the cable / maximum         Ω         250           Cable length / between sensor and electronic evaluation device / with curls. Third maximum         ms         2000           Make time / with automatic start         ms         350           maximum         ms         350           maximum         ms         500 <td>• at DC-13</td> <td></td> <td></td>	• at DC-13		
• at 230 V         • at AC-15           • at 115 V         A         6           • at 230 V         A         6           • at 230 V         A         6           • of NC contacts of relay outputs         A         10           • at DC-13         A         10           • at 115 V         A         1           • at 230 V         A         0,3           • at AC-15         A         6           • at 230 V         A         6           Mechanical operating cycles as operating time / typical         A         6           Max. permissible voltage for safe isolation / between electronic evaluation device and enabling circuit / according to EN 80947-1         V         400           Design of the fuse link / for short-circuit protection of the NO contacts of the relay outputs / required         gL/gG: 10 A         gL/gG: 10 A           Resistance to direct current / of the cable / maximum         Ω         250           Cable length / between sensor and electronic evaluation device / with Cu 1.5 mm² and 150 nF/km / maximum         m         2,000           Make time / with automatic start         · typical         ms         100           • for AC / maximum         ms         200           Make time / with automatic start / after mains power cut <td< td=""><td>• at 24 V</td><td>Α</td><td>10</td></td<>	• at 24 V	Α	10
• at AC-15         • at 115 V         A         6           • at 230 V         A         6           • of NC contacts of relay outputs         A         6           • at DC-13         A         10           • at 115 V         A         1           • at 230 V         A         0.3           • at 115 V         A         6           • at 1230 V         A         6           Mechanical operating cycles as operating time / typical         30,000,000           Max. permissible voltage for safe isolation / between electronic evaluation device and enabling circuit / according to EN 60947-1         V         400           Design of the fuse link / for short-circuit protection of the NO contacts of the relay outputs / required         gL/gG: 10 A         gL/gG: 10 A           Resistance to direct current / of the cable / maximum         Ω         250           Cable length / between sensor and electronic evaluation device / with QL 1.5 mm² and 150 nF/km / maximum         m         2,000           Make time / with automatic start         • ypical         ms         100           • for AC / maximum         ms         200           Make time / with automatic start / after mains power cut         • ypical         ms         350           • maximum         ms         500	• at 115 V	Α	1
• at 115 V       • at 230 V         • of NC contacts of relay outputs       6         • at DC-13       10         • at 24 V       A 10         • at 115 V       A 1         • at 230 V       A 0.3         • at AC-15       A 6         • at 230 V       A 6         Mechanical operating cycles as operating time / typical       30,000,000         Max, permissible voltage for safe isolation / between electronic evaluation device and enabling circuit / according to EN 60947-1       V 400         Design of the fuse link / for short-circuit protection of the NO contacts of the relay outputs / required       gL/gG: 10 A         Resistance to direct current / of the cable / maximum       Ω 250         Cable length / between sensor and electronic evaluation device / with Cu 1.5 mm² and 150 nF/km / maximum       m 2,000         Make time / with automatic start       • ms 100         • for AC / maximum       ms 200         Make time / with automatic start / after mains power cut       • ms 350         • maximum       ms 500	• at 230 V	Α	0.3
• at 230 V • of NC contacts of relay outputs • at DC-13 • at 24 V • at 115 V • at 230 V • at AC-15 • at 115 V • at 230 V  Mechanical operating cycles as operating time / typical  Max, permissible voltage for safe isolation / between electronic evaluation device and enabling circuit / according to EN 60947-1  Design of the fuse link / for short-circuit protection of the NO contacts of the relay outputs / required  Resistance to direct current / of the cable / maximum  Cable length / between sensor and electronic evaluation device / with Cu 1.5 mm² and 150 nF/km / maximum  Make time / with automatic start / after mains power cut • typical • maximum  Make time / with monitored start	• at AC-15		
• of NC contacts of relay outputs         at DC-13           • at 24 V         A         10           • at 115 V         A         1           • at 230 V         A         0.3           • at 115 V         A         6           • at 230 V         A         6           Mechanical operating cycles as operating time / typical         30,000,000           Max. permissible voltage for safe isolation / between electronic evaluation device and enabling circuit / according to EN 60947-1         V         400           Design of the fuse link / for short-circuit protection of the NO contacts of the relay outputs / required         gL/gG: 10 A         gL/gG: 10 A           Resistance to direct current / of the cable / maximum         Ω         250           Cable length / between sensor and electronic evaluation device / with C1.5 mm² and 150 nF/km / maximum         ms         2,000           Make time / with automatic start         ms         100           • for AC / maximum         ms         200           Make time / with automatic start / after mains power cut         • typical         ms         350           • maximum         ms         500           Make time / with monitored start         ms         500	• at 115 V	Α	6
• at 2 DC-13       at 24 V       A       10         • at 230 V       A       0.3         • at AC-15       A       6         • at 115 V       A       6         • at 230 V       A       6         Mechanical operating cycles as operating time / typical       30,000,000         Max. permissible voltage for safe isolation / between electronic evaluation device and enabling circuit / according to EN 60947-1       V       400         Design of the fuse link / for short-circuit protection of the NO contacts of the relay outputs / required       gL/gG: 10 A       gL/gG: 10 A         Resistance to direct current / of the cable / maximum       Ω       250         Cable length / between sensor and electronic evaluation device / with Cu 1.5 mm² and 150 nF/km / maximum       m       2,000         Make time / with automatic start       • typical       ms       100         • for AC / maximum       ms       200         Make time / with automatic start / after mains power cut       • typical       ms       350         • maximum       ms       500         Make time / with monitored start       • with monitored start	• at 230 V	Α	6
- at 24 V - at 115 V - at 230 V - at AC-15 - at 115 V - at 230 V - at 230 V - at AC-15 - at 115 V - at 230 V  Mechanical operating cycles as operating time / typical  Max. permissible voltage for safe isolation / between electronic evaluation device and enabling circuit / according to EN 60947-1  Design of the fuse link / for short-circuit protection of the NO contacts of the relay outputs / required  Resistance to direct current / of the cable / maximum  Cable length / between sensor and electronic evaluation device / with Cu 1.5 mm² and 150 nF/km / maximum  Make time / with automatic start  - typical - for AC / maximum  Make time / with automatic start / after mains power cut - typical - maximum  Make time / with monitored start	of NC contacts of relay outputs		
- at 115 V - at 230 V - at AC-15 - at 115 V - at 230 V  Mechanical operating cycles as operating time / typical  Max. permissible voltage for safe isolation / between electronic evaluation device and enabling circuit / according to EN 60947-1  Design of the fuse link / for short-circuit protection of the NO contacts of the relay outputs / required  Resistance to direct current / of the cable / maximum  Cable length / between sensor and electronic evaluation device / with Cu 1.5 mm² and 150 nF/km / maximum  Make time / with automatic start - typical - for AC / maximum  Make time / with automatic start / after mains power cut - typical - maximum  Make time / with monitored start	• at DC-13		
• at 230 V • at AC-15 • at 115 V • at 230 V  Mechanical operating cycles as operating time / typical  Max. permissible voltage for safe isolation / between electronic evaluation device and enabling circuit / according to EN 60947-1  Design of the fuse link / for short-circuit protection of the NO contacts of the relay outputs / required  Resistance to direct current / of the cable / maximum  Cable length / between sensor and electronic evaluation device / with Cu 1.5 mm² and 150 nF/km / maximum  Make time / with automatic start • typical • for AC / maximum  Make time / with automatic start / after mains power cut • typical • maximum  Make time / with monitored start  Make time / with monitored start	• at 24 V	Α	10
• at AC-15 • at 115 V A 6   • at 230 V A 6   Mechanical operating cycles as operating time / typical 30,000,000   Max. permissible voltage for safe isolation / between electronic evaluation device and enabling circuit / according to EN 60947-1 V 400   Design of the fuse link / for short-circuit protection of the NO contacts of the relay outputs / required gL/gG: 10 A   Resistance to direct current / of the cable / maximum Ω 250   Cable length / between sensor and electronic evaluation device / with Cu 1.5 mm² and 150 nF/km / maximum m 2,000   Make time / with automatic start • typical ms 100   • for AC / maximum ms 200   Make time / with automatic start / after mains power cut • typical ms 350   • maximum ms 500    Make time / with monitored start	• at 115 V	Α	1
• at 115 V       • at 230 V       A       6         Mechanical operating cycles as operating time / typical       30,000,000         Max. permissible voltage for safe isolation / between electronic evaluation device and enabling circuit / according to EN 60947-1       V       400         Design of the fuse link / for short-circuit protection of the NO contacts of the relay outputs / required       gL/gG: 10 A         Resistance to direct current / of the cable / maximum       Ω       250         Cable length / between sensor and electronic evaluation device / with Cu 1.5 mm² and 150 nF/km / maximum       m       2,000         Make time / with automatic start         • typical       ms       100         • for AC / maximum       ms       200         Make time / with automatic start / after mains power cut       • typical       ms       350         • maximum       ms       500         Make time / with monitored start       ms       500	• at 230 V	Α	0.3
• at 230 V       A       6         Mechanical operating cycles as operating time / typical       30,000,000         Max. permissible voltage for safe isolation / between electronic evaluation device and enabling circuit / according to EN 60947-1       V       400         Design of the fuse link / for short-circuit protection of the NO contacts of the relay outputs / required       gL/gG: 10 A         Resistance to direct current / of the cable / maximum       Ω       250         Cable length / between sensor and electronic evaluation device / with Cu 1.5 mm² and 150 nF/km / maximum       m       2,000         Make time / with automatic start         • typical             ms       100         • for AC / maximum       ms       200         Make time / with automatic start / after mains power cut         • typical             ms       350         • maximum       ms       500         Make time / with monitored start       ms       500	• at AC-15		
Mechanical operating cycles as operating time / typical       30,000,000         Max. permissible voltage for safe isolation / between electronic evaluation device and enabling circuit / according to EN 60947-1       V       400         Design of the fuse link / for short-circuit protection of the NO contacts of the relay outputs / required       gL/gG: 10 A         Resistance to direct current / of the cable / maximum       Ω       250         Cable length / between sensor and electronic evaluation device / with Cu 1.5 mm² and 150 nF/km / maximum       m       2,000         Make time / with automatic start         • typical         ms       100         • for AC / maximum       ms       200         Make time / with automatic start / after mains power cut       • typical       ms       350         • maximum       ms       500         Make time / with monitored start       ms       500	• at 115 V	Α	6
Max. permissible voltage for safe isolation / between electronic evaluation device and enabling circuit / according to EN 60947-1       V       400         Design of the fuse link / for short-circuit protection of the NO contacts of the relay outputs / required       gL/gG: 10 A         Resistance to direct current / of the cable / maximum       Ω       250         Cable length / between sensor and electronic evaluation device / with Cu 1.5 mm² and 150 nF/km / maximum       m       2,000         Make time / with automatic start         • typical             ms       100         • for AC / maximum       ms       200         Make time / with automatic start / after mains power cut         • typical             ms       350         • maximum       ms       500         Make time / with monitored start       ms       500	• at 230 V	Α	6
evaluation device and enabling circuit / according to EN 60947-1  Design of the fuse link / for short-circuit protection of the NO contacts of the relay outputs / required  Resistance to direct current / of the cable / maximum  Cable length / between sensor and electronic evaluation device / with Cu 1.5 mm² and 150 nF/km / maximum  Make time / with automatic start  - typical - for AC / maximum  Make time / with automatic start / after mains power cut  - typical - ms 350  Make time / with monitored start  Make time / with monitored start	Mechanical operating cycles as operating time / typical		30,000,000
Resistance to direct current / of the cable / maximum       Ω       250         Cable length / between sensor and electronic evaluation device / with Cu 1.5 mm² and 150 nF/km / maximum       m       2,000         Make time / with automatic start <ul> <li>typical</li> <li>for AC / maximum</li> <li>typical</li> <li>typical</li> <li>ms             200               Make time / with automatic start / after mains power cut             ms             350               maximum             ms             500               Make time / with monitored start</li></ul>		V	400
Cable length / between sensor and electronic evaluation device / with Cu 1.5 mm² and 150 nF/km / maximum  Make time / with automatic start  • typical  • for AC / maximum  Make time / with automatic start / after mains power cut  • typical  • typical  • ms 350  • maximum  Make time / with monitored start			gL/gG: 10 A
with Cu 1.5 mm² and 150 nF/km / maximum  Make time / with automatic start  • typical • for AC / maximum  Make time / with automatic start / after mains power cut  • typical • maximum  Make time / with monitored start  Make time / with monitored start	Resistance to direct current / of the cable / maximum	Ω	250
<ul> <li>typical</li> <li>for AC / maximum</li> <li>Make time / with automatic start / after mains power cut</li> <li>typical</li> <li>ms</li> <li>350</li> <li>maximum</li> <li>ms</li> <li>500</li> <li>Make time / with monitored start</li> </ul>		m	2,000
• for AC / maximum ms 200  Make time / with automatic start / after mains power cut • typical • maximum ms 350  Make time / with monitored start  Make time / with monitored start	Make time / with automatic start		
Make time / with automatic start / after mains power cut  • typical  • maximum  ms 350  ms 500  Make time / with monitored start	• typical	ms	100
• typical ms 350 • maximum ms 500  Make time / with monitored start	• for AC / maximum	ms	200
• maximum ms 500  Make time / with monitored start	Make time / with automatic start / after mains power cut		
Make time / with monitored start	• typical	ms	350
	• maximum	ms	500
• maximum ms 100	Make time / with monitored start		
	• maximum	ms	100

• typical	ms	60
Backslide delay time / after opening of the safety circuits / typical	ms	30
Backslide delay time / at mains power cut		
• typical	ms	100
• maximum	ms	120
Recovery time / after opening of the safety circuits / typical	ms	20
Recovery time / after mains power cut / typical	s	0.02
Pulse duration		
of the sensor input / minimum	ms	20
of the ON pushbutton input / minimum	s	0.02
of the cascading-entrance / minimum	s	0.02
Control circuit:		
Type of voltage / of the controlled supply voltage		AC
Control supply voltage frequency	_	
• 1 / rated value	Hz	50
• 2 / rated value	Hz	60
Control supply voltage / 1 / at 50 Hz / for AC / rated value	V	230
Control supply voltage / 1 / at 60 Hz / for AC / rated value	V	230
operating range factor control supply voltage rated value / of the magnet coil		
• at 50 Hz		
• for AC		0.9 1.15
• at 60 Hz		
• for AC		0.9 1.15
Auxiliary circuit:		
Contact reliability / of the auxiliary contacts		< 1 error per 100 million operating cycles
Installation/mounting/dimensions:		
mounting position		any
Type of mounting	_	screw and snap-on mounting
Width	mm	90
Height	mm	132
Depth	mm	149
Connections:		
Design of the electrical connection		spring-loaded terminals
Type of the connectable conductor cross-section		
• solid		1x (0.2 2.5 mm²)
finely stranded		

• without wire end processing

1x (0.25 ... 1.5 mm²)

Type of the connectable conductor cross-section / for AWG conductors	
• solid	1x (24 18)
• stranded	1x (24 18)

Product Function:		
Product function		
light barrier monitoring		No
standstill monitoring		No
protective door monitoring		Yes
automatic start		Yes
<ul> <li>magnetic switch monitoring Normally closed contact-Normally open contact</li> </ul>		No
rotation speed monitoring		No
laser scanner monitoring		No
monitored start-up		Yes
light grid monitoring		No
<ul> <li>magnetic switch monitoring Normally closed contact-Normally closed contact</li> </ul>		Yes
emergency stop function		Yes
step mat monitoring		No
Suitability for interaction / pressing control		No
Acceptability for application		
monitoring of floating sensors		Yes
monitoring of non-floating sensors		No
safety cut-out switch		Yes
position switch monitoring		Yes
EMERGENCY-OFF circuit monitoring		Yes
valve monitoring		No
tactile sensor monitoring		No
magnetically operated switches monitoring		No
safety-related circuits		Yes

Certificates/approvals:	
Verification of suitability	UL, CSA, EN 60204-1, EN ISO 12100, EN 954-1, IEC 61508
• TÜV (German technical inspectorate) certificate	Yes
UL-registration	Yes
BG BIA certificate	Yes

## **General Product Approval**

**EMC** 

Functional Safety / Safety of Machinery













Declaration of Conformity

Test Certificates

other

CE

Special Test Certificate Confirmation

Environmental Confirmations

## Further information:

Information- and Downloadcenter (Catalogs, Brochures,...)

http://www.siemens.com/industrial-controls/catalogs

Industry Mall (Online ordering system)

http://www.siemens.com/industrial-controls/mall

Cax online generator:


http://www.siemens.com/cax


Service&Support (Manuals, Certificates, Characteristics, FAQs,...)

http://support.automation.siemens.com/WW/view/en/3TK2852-2AL20/all

Image database (product images, 2D dimension drawings, 3D models, device circuit diagrams, ...)

 $\underline{\text{http://www.automation.siemens.com/bilddb/cax\_en.aspx?mlfb=3TK2852-2AL20}}$ 





last change:

Feb 18, 2013