SIEMENS

Product data sheet 3TK2857-1BB42

SIRIUS SAFETY RELAY WITH AUXILIARY CONTACTOR RELEASE CIRCUIT (RC),

DC 24V, 90.0MM, SCREW TERMINAL,

RC INSTANT.: 0,

RC DELAYED: 3S 0.5...30S, MK: 0,

EXPANSION UNIT,

MAX. ACHIEVABLE PL: AS GG, MAX. ACHIEVABLE SIL: AS GG,

General technical details:		
product brand name		SIRIUS
product designation		safety relays
Design of the product		extension unit
protection class IP / of the housing		IP20
Protection class IP / of the terminal		IP20
Protection against electrical shock		finger-safe
Insulation voltage / rated value	V	690
Ambient temperature		
during storage	°C	-40 +80
during operating	°C	-25 +60
Air pressure		
according to SN 31205	kPa	90 106
Relative humidity		
during operating phase	%	10 95
Installation altitude / at a height over sea level / maximum	m	2,000
Resistance against vibration / according to IEC 60068-2-6		5 500 Hz: 0,075 mm
Resistance against shock		8g / 10 ms and 15g / 5 ms
Impulse voltage resistance / rated value	V	6,000
EMC emitted interference		IEC 60947-5-1, IEC 60000-4-3, IEC 60000-4-5, IEC 60000-4-6
Installation environment relating to EMC		This product is suitable for Class A environments only. It can cause undesired radio-frequency interference in residential environments. If this is the case, the user must take appropriate measures.
Item designation		
 according to DIN 40719 extendable after IEC 204-2 / according to IEC 750 		КТ
according to DIN EN 61346-2		F

Contact reliability		one incorrect switching operation of 100 million switching operations (17 V, 5 mA)
Design of the cascading		cascading and in-service switching
Product feature / transverse contact-secure		No
Safety Integrity Level (SIL)		
according to IEC 61508		SIL3
• for delayed release circuit / according to IEC 61508		SIL3
SIL claim limit (for a subsystem) / according to EN 62061		3
Performance Level (PL)		
according to ISO 13849-1		е
• for delayed release circuit / according to ISO 13849-1		е
Category / according to EN 954-1		corresponds to basic unit
Category / according to ISO 13849-1		4
Hardware fault tolerance / according to IEC 61508		1
Safety device type / according to IEC 61508-2		Type B
Probability of dangerous failure per hour (PFHD) / with high demand rate / according to EN 62061	1/h	0.11E-7
T1 value / for proof test interval or service life / according to IEC 61508	а	20
Number of outputs / as contact-affected switching element		
• as NC contact / for reporting function / instantaneous switching		0
as NO contact / safety-related / instantaneous switching		0
as NO contact / safety-related / delayed switching		3
Number of outputs / as contact-less semiconductor switching element		
safety-related		
delayed switching		0
non-delayed		1
for reporting function		
delayed switching		0
non-delayed		0
Stop category / according to DIN EN 60204-1		1
General technical details:		
Design of the input		
cascading-input/functional switching		Yes
feedback input		Yes
start input		Yes
Design of the electrical connection / jumper socket		Yes
Operating cycles / maximum	1/h	1,000
Switching capacity current		

of NO contacts of relay outputs		
• at DC-13		
• at 24 V	Α	10
• at 115 V	Α	1
• at 230 V	Α	0.3
• at AC-15		
• at 115 V	Α	6
• at 230 V	Α	6
of NC contacts of relay outputs		
• at DC-13		
• at 24 V	Α	10
• at 115 V	Α	1
• at 230 V	Α	0.3
• at AC-15		
• at 115 V	Α	6
• at 230 V	Α	6
Mechanical operating cycles as operating time / typical		30,000,000
Max. permissible voltage for safe isolation / between electronic evaluation device and enabling circuit / according to EN 60947-1	V	400
Design of the fuse link / for short-circuit protection of the NO contacts of the relay outputs / required		gL/gG: 10 A
Resistance to direct current / of the cable / maximum	Ω	500
Cable length / between sensor and electronic evaluation device / with Cu 1.5 mm² and 150 nF/km / maximum	m	2,000
Make time / with automatic start / after mains power cut		
• typical	ms	6,000
• maximum	ms	7,000
Backslide delay time / at mains power cut		
• typical	ms	120
• maximum	ms	120
Adjustable backslide delay time		
after opening of the safety circuits	s	0.5 30
Recovery time / after opening of the safety circuits / typical	ms	500
Recovery time / after mains power cut / typical	s	7
Pulse duration		
of the cascading-entrance / minimum	S	0.045
Control circuit:		
Type of voltage / of the controlled supply voltage		DC
Control supply voltage / 1 / for DC / rated value	V	24

operating range factor control supply voltage rated value / of the magnet coil • for DC 0.85 ... 1.1

Auxiliary circuit:		
	< 1 error per 100 million operating cycles	
	any	
	screw and snap-on mounting	

mounting position		any
Type of mounting		screw and snap-on mounting
Width	mm	90
Height	mm	132
Depth	mm	146

Connections:	
Design of the electrical connection	screw-type terminals
Type of the connectable conductor cross-section	
• solid	1x (0.2 2.5 mm²), 2x (0.2 1.0 mm²)
finely stranded	
with wire end processing	1x (0.25 2.5 mm²), 2x (0.25 1.0 mm²)
Type of the connectable conductor cross-section / for AWG conductors	
• solid	2x (24 18)
• stranded	2x (24 18)

Product Function:	
Product function	
light barrier monitoring	No
standstill monitoring	No
protective door monitoring	No
automatic start	No
 magnetic switch monitoring Normally closed contact-Normally open contact 	No
rotation speed monitoring	No
laser scanner monitoring	No
monitored start-up	No
light grid monitoring	No
 magnetic switch monitoring Normally closed contact-Normally closed contact 	Yes
emergency stop function	Yes
step mat monitoring	No
Suitability for interaction / pressing control	No
Acceptability for application	

safety cut-out switch	Yes
position switch monitoring	Yes
EMERGENCY-OFF circuit monitoring	Yes
valve monitoring	No
tactile sensor monitoring	No
magnetically operated switches monitoring	No
safety-related circuits	Yes

Certificates/approvals:	
Verification of suitability	UL, CSA, EN 60204-1, EN ISO 12100, EN 954-1, IEC 61508
TÜV (German technical inspectorate) certificate	Yes
UL-registration	Yes
BG BIA certificate	Yes

General Product Approval









Environmental

Confirmations



EMC



Functional Safety / Safety of Machinery

Declaration of Conformity Test Certificates

other

Special Test Co

Confirmation

CE

Further information:

Information- and Downloadcenter (Catalogs, Brochures,...)

Certificate

http://www.siemens.com/industrial-controls/catalogs

Industry Mall (Online ordering system)

http://www.siemens.com/industrial-controls/mall

Cax online generator:


http://www.siemens.com/cax


Service&Support (Manuals, Certificates, Characteristics, FAQs,...)

http://support.automation.siemens.com/WW/view/en/3TK2857-1BB42/all

Image database (product images, 2D dimension drawings, 3D models, device circuit diagrams, ...)

http://www.automation.siemens.com/bilddb/cax_en.aspx?mlfb=3TK2857-1BB42





last change: Feb 18, 2013