

WITHDRAWABLE CIRCUIT BREAKER WITHOUT
GUIDE FRAME 4-POLE, SIZE I, IEC IN=630A TO
690V, AC50/60HZ ICU=66KA AT 500V REAR
CONNECTION HORIZONTAL

Model		
product brandname		SENTRON
Product designation		ACB
Design of the operating mechanism		Pushbutton
Type of the driving mechanism		Manual operating mechanism with mechanical closing
Type of the driving mechanism / motor drive		No
Design of the overcurrent release		ETU25B
General technical data		
Number of poles		4
Size of the circuit-breaker		1
Electrical endurance (switching cycles) / typical		20 000
Usage category		B
circuit-breaker / Design		3WL1106
Mechanical service life (switching cycles) / typical		20 000
Voltage		
Rated insulation voltage Ui	V	1 000
Insulation voltage / rated value	V	1 000
Protection class		
Protection class IP		IP20
Protective function of the overcurrent release		LSI
Dissipation		
Power loss [W]		
• for rated value of the current / at AC / in hot operating state / per pole	W	65
• maximum	W	195
Electricity		
Continuous current / rated value	A	630
Adjustable pick-up value current		
• of instantaneous short-circuit trip unit / initial value	A	12 600
• of instantaneous short-circuit trip unit / Full-scale value	A	12 600

Short-time current resistance (I_{cw})		
• limited to 0.5 s / rated value	kA	66
• limited to 1 s / rated value	kA	50
• limited to 2 s / rated value	kA	35
• limited to 3 s / rated value	kA	29
Main circuit		
Operating frequency		
• 1 / rated value	Hz	50
• 2 / rated value	Hz	60
Operating voltage		
• at AC / at 50/60 Hz / rated value	V	690
Operating current		
• at 40 °C / rated value	A	630
• at 50 °C / rated value	A	630
• at 55 °C / rated value	A	630
• at 60 °C / rated value	A	630
• at 65 °C / rated value	A	630
• at 70 °C / rated value	A	630
Auxiliary circuit		
Number of NC contacts / for auxiliary contacts		4
Number of NO contacts / for auxiliary contacts		4
Suitability		
Suitability for use		Plant / motor protection
Product details		
Product component		
• Trip indicator		Yes
• Voltage trigger		No
• undervoltage release		No
Product extension / optional / motor drive		Yes
Product function		
Product function		
• Ground fault protection		No
Display and operation		
Display version		without display
Short circuit		
Operational short-circuit current breaking capacity (I_{cs})		
• at 415 V / rated value	kA	66
• at 500 V / rated value	kA	66

• at 690 V / rated value	kA	50
Maximum short-circuit current breaking capacity (Icu)		
• at 415 V / rated value	kA	66
• at 500 V / rated value	kA	66
• at 690 V / rated value	kA	50
Short-circuit current making capacity (Icm)		
• at 415 V / rated value	kA	145
• at 500 V / rated value	kA	145
• at 690 V / rated value	kA	105

Connections

Arrangement of electrical connectors / for main current circuit		without guide frame
Type of electrical connection / for main current circuit		Blade contacts

Mechanical Design

Height	mm	411.5
Width	mm	401
Depth	mm	337
Mounting type		drawer unit

Environmental conditions

Ambient temperature		
• during operation / minimum	°C	-20
• during operation / maximum	°C	70
• during storage / minimum	°C	-40
• during storage / maximum	°C	70

Certificates

Equipment marking		
• acc. to DIN EN 61346-2		Q
• acc. to DIN EN 81346-2		Q

General Product Approval				Declaration of Conformity	Test Certificates
					sonstig
CB	CCC	VDE		EG-Konf.	

Test Certificates	Shipping Approval				
spezielle Prüfbescheinigung n					
	ABS		DNV	GL	LRS

Shipping Approval	other	
		Umweltbestätigung sonstig
PRS	RMRS	

Further information

Industry Mall (Online ordering system)

<https://eb.automation.siemens.com/mall/en/WW/Catalog/Product/3WL1106-3CB45-1AA4-Z B06+K07>

Service&Support (Manuals, Certificates, Characteristics, FAQs,...)

<http://support.automation.siemens.com/WW/view/en/3WL1106-3CB45-1AA4-Z B06+K07/all>

Image database (product images, 2D dimension drawings, 3D models, device circuit diagrams, ...)

http://www.automation.siemens.com/bilddb/cax_en.aspx?mlfb=3WL1106-3CB45-1AA4-Z B06+K07

CAX-Online-Generator

<http://www.siemens.com/cax>

Tender specifications

<http://ausschreibungstexte.siemens.com/tiplv>

last modified:

09/22/2016