

WITHDRAWABLE CIRCUIT BREAKER WITHOUT
GUIDE FRAME 4-POLE, SIZE I, IEC IN=1000A TO
690V, AC50/60HZ ICU=66KA AT 500V REAR
CONNECTION HORIZONTAL

Model		
product brandname		SENTRON
Product designation		ACB
Design of the operating mechanism		Pushbutton
Type of the driving mechanism		Manual/motorized operating mechanism with mechanical and electrical closing
Type of the driving mechanism / motor drive		Yes
Design of the overcurrent release		ETU25B
General technical data		
Number of poles		4
Size of the circuit-breaker		1
Electrical endurance (switching cycles) / typical		20 000
Usage category		B
circuit-breaker / Design		3WL1110
Mechanical service life (switching cycles) / typical		20 000
Voltage		
Rated insulation voltage Ui	V	1 000
Insulation voltage / rated value	V	1 000
Protection class		
Protection class IP		IP20
Protective function of the overcurrent release		LSI
Dissipation		
Power loss [W]		
• for rated value of the current / at AC / in hot operating state / per pole	W	65
• maximum	W	195
Electricity		
Continuous current / rated value	A	1 000
Adjustable pick-up value current		
• of instantaneous short-circuit trip unit / initial value	A	20 000
• of instantaneous short-circuit trip unit / Full-scale value	A	20 000

Short-time current resistance (I_{cw})		
• limited to 0.5 s / rated value	kA	66
• limited to 1 s / rated value	kA	50
• limited to 2 s / rated value	kA	35
• limited to 3 s / rated value	kA	29
Main circuit		
Operating frequency		
• 1 / rated value	Hz	50
• 2 / rated value	Hz	60
Operating voltage		
• at AC / at 50/60 Hz / rated value	V	690
Operating current		
• at 40 °C / rated value	A	1 000
• at 50 °C / rated value	A	1 000
• at 55 °C / rated value	A	1 000
• at 60 °C / rated value	A	1 000
• at 65 °C / rated value	A	1 000
• at 70 °C / rated value	A	1 000
Suitability		
Suitability for use		Plant / motor protection
Product details		
Product component		
• Trip indicator		Yes
• Voltage trigger		No
• undervoltage release		Yes
Product extension / optional / motor drive		No
Product function		
Product function		
• Ground fault protection		No
Display and operation		
Display version		without display
Short circuit		
Operational short-circuit current breaking capacity (I_{cs})		
• at 415 V / rated value	kA	66
• at 500 V / rated value	kA	66
• at 690 V / rated value	kA	50
Maximum short-circuit current breaking capacity (I_{cu})		
• at 415 V / rated value	kA	66
• at 500 V / rated value	kA	66

- at 690 V / rated value

kA	50
----	----

Connections

Arrangement of electrical connectors / for main current circuit		without guide frame
Type of electrical connection / for main current circuit		Blade contacts

Mechanical Design

Height	mm	411.5
Width	mm	401
Depth	mm	337
Mounting type		drawer unit

Environmental conditions

Ambient temperature		
• during operation / minimum	°C	-20
• during operation / maximum	°C	70
• during storage / minimum	°C	-40
• during storage / maximum	°C	70

Certificates

Equipment marking		
• acc. to DIN EN 61346-2		Q
• acc. to DIN EN 81346-2		Q

General Product Approval	Declaration of Conformity	Test Certificates
--------------------------	---------------------------	-------------------

CB

CB



CCC



VDE

EAC



EG-Konf.

[sonstig](#)

Test Certificates	Shipping Approval
-------------------	-------------------

[spezielle
Prüfbescheinigung
n](#)



ABS



BUREAU
VERITAS



DNV



GL



LRS

Shipping Approval	other
-------------------	-------



PRS



RMRS

[Umweltbestätigung](#)

[sonstig](#)

Further information

Industry Mall (Online ordering system)

<https://eb.automation.siemens.com/mall/en/WW/Catalog/Product/3WL1110-3CB45-4AN2-Z C22+K07>

Service&Support (Manuals, Certificates, Characteristics, FAQs,...)

<http://support.automation.siemens.com/WW/view/en/3WL1110-3CB45-4AN2-Z C22+K07/all>

Image database (product images, 2D dimension drawings, 3D models, device circuit diagrams, ...)

http://www.automation.siemens.com/bilddb/cax_en.aspx?mlfb=3WL1110-3CB45-4AN2-Z C22+K07

CAX-Online-Generator

<http://www.siemens.com/cax>

Tender specifications

<http://www.siemens.com/specifications>

last modified:

10/20/2016