

WITHDRAW. NON-AUT. CIRCUIT-B. WITH GUIDE FRAME
 4-POLE,
 SIZE III, IEC IN=4000A TO 690V,
 AC50/60HZ ICU=100KA AT 500V W. CONNECTION
 FLANGE

General technical data:

Number of poles	4
------------------------	---

Connections:

Arrangement of electrical connectors	with guide frame, connecting flange
<ul style="list-style-type: none"> for main current circuit 	

Certificates/approvals:

General Product Approval	EMC	Declaration of Conformity
 CB	 CCC	 GOST
	 C-TICK	 EG-Konf.

Shipping Approval

 ABS	 BUREAU VERITAS	 DNV	 GL	 LRS
--	--	--	---	--

other

other	Environmental Confirmations
-----------------------	---

Further information:

- Information- and Downloadcenter (Catalogs, Brochures,...)**
<http://www.siemens.com/lowvoltage/catalogs>

- Industry Mall (Online ordering system)**
<http://www.siemens.com/lowvoltage/mall>

- Service&Support (Manuals, Certificates, Characteristics, FAQs,...)**
<http://support.automation.siemens.com/WWW/view/en/3WL1340-4A.48-..../all>

- Image database (product images, 2D dimension drawings, 3D models, device circuit diagrams, ...)**
http://www.automation.siemens.com/bilddb/cax_en.aspx?mlfb=3WL1340-4A.48-....

- CAX-Online-Generator**
<http://www.siemens.com/cax>

last change:

Feb 9, 2013