

product type designation



SIPLUS S7-1200 CP 1243-1

SIPLUS S7-1200 CP 1243-1 based on 6GK7243-1BX30-0XE0 with conformal coating, -40...+70 °C, communications processor CP 1243-1 for connection of SIMATIC S7-1200 as additional Ethernet interface and for connection to control centers via telecontrol protocols (DNP3, IEC 60870, TeleControl Basic), security (firewall, VPN)

transfer rate	
transfer rate	
• at the 1st interface	10 ... 100 Mbit/s
interfaces	
number of interfaces / according to Industrial Ethernet	1
number of electrical connections	
• at the 1st interface / according to Industrial Ethernet	1
• for power supply	0
type of electrical connection	
• at the 1st interface / according to Industrial Ethernet	RJ45 port
supply voltage, current consumption, power loss	
type of voltage / of the supply voltage	DC
supply voltage / 1 / from backplane bus	5 V
consumed current	
• from backplane bus / at DC / at 5 V / typical	0.25 A
power loss [W]	1.25 W
ambient conditions	
ambient temperature	
• for vertical installation / during operation	-40 ... +60 °C
• for horizontally arranged busbars / during operation	-40 ... +70 °C
• during storage	-40 ... +70 °C
• during transport	-40 ... +70 °C
installation altitude / at height above sea level / maximum	5000 m
ambient condition / relating to ambient temperature - air pressure - installation altitude	Tmin ... Tmax at 1 140 hPa ... 795 hPa (-1 000 m ... +2 000 m) // Tmin ... (Tmax - 10 K) at 795 hPa ... 658 hPa (+2 000 m ... +3 500 m) // Tmin ... (Tmax - 20 K) at 658 hPa ... 540 hPa (+3 500 m ... +5 000 m)
relative humidity	
• with condensation / according to IEC 60068-2-38 / maximum	100 %; RH including condensation/frost (no commissioning when condensation is present), horizontal installation
chemical resistance / to commercially available cooling lubricants	Yes; incl. airborne diesel and oil droplets
resistance to biologically active substances	
• conformity according to EN 60721-3-3	Yes; Class 3B2 mold and fungal spores (excluding fauna), Class 3B3 on request
• conformity according to EN 60721-3-6	Yes; Class 6B2 mold, fungal and dry rot spores (excluding fauna)
resistance to chemically active substances	
• conformity according to EN 60721-3-3	Yes; Class 3C4 (RH < 75 %) incl. salt spray in accordance with EN 60068-2-52 (Severity 3). The supplied plug covers must remain in place on the unused interfaces during operation.
• conformity according to EN 60721-3-6	Yes
resistance to mechanically active substances	

conformity according to EN 60721-3-3	Yes; Class 3S4 incl. sand, dust. The supplied plug covers must remain in place over the unused interfaces during operation.
conformity according to EN 60721-3-6	Yes; Class 6S3 incl. sand, dust. The supplied plug covers must remain in place over the unused interfaces during operation.
coating / for equipped printed circuit board / according to EN 61086	Yes; Class 2 for high availability
type of coating / protection against pollution according to EN 60664-3	Yes; Protection of the type 1
type of test / of the coating / according to MIL-I-46058C	Yes; Coating discoloration during service life possible
product conformity / of the coating / Qualification and Performance of Electrical Insulating Compound for Printed Board Assemblies according to IPC-CC-830A	Yes; Conformal coating, class A
protection class IP	IP20
design, dimensions and weights	
module format	Compact module S7-1200 single width
width	30 mm
height	110 mm
depth	75 mm
net weight	0.122 kg
fastening method 35 mm top hat DIN rail mounting - wall mounting	Yes Yes
product features, product functions, product components / general	
number of units per CPU / maximum	3
performance data / open communication	
number of possible connections / for open communication by means of T blocks / maximum	like CPU
performance data / S7 communication	
number of possible connections / for S7 communication maximum	like CPU
performance data / IT functions	
number of possible connections as email client / maximum	1
performance data / telecontrol	
suitability for use - node station - substation - TIM control center	No Yes No
control center connection - by means of a permanent connection - note	For use with TeleControl Server Basic, WinCC and PCS7 supported Connection to SCADA system via Telecontrol Server Basic and Standard Telecontrol protocols
protocol / is supported - DNP3 - IEC 60870-5	Yes Yes
product function / data buffering if connection is aborted	Yes; 64,000 events
number of data points per station / maximum	200
number of stations / for direct communication / with Telecontrol Server Basic - in send direction / maximum - in receive direction / maximum	3 15
performance data / teleservice	
diagnostics function / online diagnostics with SIMATIC STEP 7	Yes
product function - program download with SIMATIC STEP 7 - remote firmware update	Yes Yes
product functions / management, configuration, engineering	
configuration software required	STEP 7 Basic/Professional
product functions / diagnostics	
product function / web-based diagnostics	Yes

product functions / security	
firewall version	stateful inspection
product function / with VPN connection	IPsec, SINEMA RC
type of encryption algorithms / with VPN connection	AES-256, AES-192, AES-128, 3DES-168
type of authentication procedure / with VPN connection	Preshared key (PSK), X.509v3 certificates
type of hashing algorithms / with VPN connection	MD5, SHA-1, SHA-2
number of possible connections / with VPN connection	8
product function	
• password protection for Web applications	No
• password protection for teleservice access	No
• encrypted data transmission	Yes
• ACL - IP-based	No
• ACL - IP-based for PLC/routing	No
• switch-off of non-required services	Yes
• blocking of communication via physical ports	No
• log file for unauthorized access	No

product functions / time	
protocol / is supported	
• NTP	Yes
• NTP (secure)	Yes
time synchronization	
• from NTP-server	Yes
• from control center	Yes

standards, specifications, approvals	
reference code	
• according to IEC 81346-2:2019	KEC

further information / internet links	
internet link	
• to web page: selection aid TIA Selection Tool	https://www.siemens.com/tstcloud
• to website: Industrial communication	https://www.siemens.com/simatic-net
• to web page: SiePortal	https://sieportal.siemens.com/
• to website: Image database	https://www.automation.siemens.com/bilddb
• to website: CAX-Download-Manager	https://www.siemens.com/cax
• to website: Industry Online Support	https://support.industry.siemens.com

security information	
security information	Siemens provides products and solutions with industrial cybersecurity functions that support the secure operation of plants, systems, machines and networks. In order to protect plants, systems, machines and networks against cyber threats, it is necessary to implement – and continuously maintain – a holistic, state-of-the-art industrial cybersecurity concept. Siemens' products and solutions constitute one element of such a concept. Customers are responsible for preventing unauthorized access to their plants, systems, machines and networks. Such systems, machines and components should only be connected to an enterprise network or the internet if and to the extent such a connection is necessary and only when appropriate security measures (e.g. firewalls and/or network segmentation) are in place. For additional information on industrial cybersecurity measures that may be implemented, please visit www.siemens.com/cybersecurity-industry. Siemens' products and solutions undergo continuous development to make them more secure. Siemens strongly recommends that product updates are applied as soon as they are available and that the latest product versions are used. Use of product versions that are no longer supported, and failure to apply the latest updates may increase customer's exposure to cyber threats. To stay informed about product updates, subscribe to the Siemens Industrial Cybersecurity RSS Feed under https://www.siemens.com/cert. (V4.7)

Approvals / Certificates	
General Product Approval	EMV

[Miscellaneous](#)



[Manufacturer Declaration](#)



For use in hazardous locations

[CCC-Ex](#)



last modified:

8/22/2024 