SIEMENS

Data sheet

6AG1510-1SK03-2AB0

SIPLUS ET 200SP CPU 1510SP F-1 PN based on 6ES7510-1SK03-0AB0 with conformal coating -40...+60 $^{\circ}$ C . central processing unit with work memory 300 KB for program and 1 MB for data, 1st interface: PROFINET IRT with 3-port switch, 25 ns bit performance, SIMATIC Memory Card required, BusAdapter required for port 1 and 2

Firmware version FW update possible Product function I&M data Module swapping during operation (hot swapping) Isochronous mode Engineering with STEP 7 TIA Portal configurable/integrated from version Configuration control	Yes Yes; I&M0 to I&M3 Yes; Multi-hot swapping Yes; only with PROFINET; with minimum OB 6x cycle of 500 µs see entry ID: 109746275
Firmware version FW update possible Product function I&M data Module swapping during operation (hot swapping) Isochronous mode Engineering with STEP 7 TIA Portal configurable/integrated from version Configuration control via dataset	Yes; I&M0 to I&M3 Yes; Multi-hot swapping Yes; only with PROFINET; with minimum OB 6x cycle of 500 μs
FW update possible Product function I&M data Module swapping during operation (hot swapping) Isochronous mode Engineering with STEP 7 TIA Portal configurable/integrated from version Configuration control via dataset	Yes; I&M0 to I&M3 Yes; Multi-hot swapping Yes; only with PROFINET; with minimum OB 6x cycle of 500 µs
Product function I&M data Module swapping during operation (hot swapping) Isochronous mode Engineering with STEP 7 TIA Portal configurable/integrated from version Configuration control via dataset	Yes; I&M0 to I&M3 Yes; Multi-hot swapping Yes; only with PROFINET; with minimum OB 6x cycle of 500 µs
I&M data Module swapping during operation (hot swapping) Isochronous mode Ingineering with STEP 7 TIA Portal configurable/integrated from version Configuration control via dataset	Yes; Multi-hot swapping Yes; only with PROFINET; with minimum OB 6x cycle of 500 µs
Module swapping during operation (hot swapping) Isochronous mode Engineering with STEP 7 TIA Portal configurable/integrated from version Configuration control via dataset	Yes; Multi-hot swapping Yes; only with PROFINET; with minimum OB 6x cycle of 500 µs
Isochronous mode Engineering with STEP 7 TIA Portal configurable/integrated from version Configuration control via dataset Y	Yes; only with PROFINET; with minimum OB 6x cycle of 500 μs
Engineering with • STEP 7 TIA Portal configurable/integrated from version Configuration control via dataset	
STEP 7 TIA Portal configurable/integrated from version Configuration control via dataset Y	see entry ID: 109746275
Configuration control via dataset	
via dataset Y	•
	Yes
Mode selector switch 1	1
Supply voltage	
	24 V
	19.2 V
	28.8 V
	Yes
Mains buffering	
	10 ms
Input current	
	0.51 A
	0.7 A
·	1.34 A; Rated value
	0.3 A ² ·s
Power	
	8.05 W
Power loss	
	6.5 W
Memory	
Number of slots for SIMATIC memory card 1	1
	Yes
Work memory	
	300 kbyte
	1 Mbyte
Load memory	
	32 Gbyte
Backup	
	Yes
CPU processing times	
	25 ns
·	32 ns
	42 ns
	170 ns
CPU-blocks	
	4 000; Blocks (OB, FB, FC, DB) and UDTs
DB	, , , , , , , , , , , , , , , , , , , ,

Number range	1 60 999; subdivided into: number range that can be used by the user: 1 59 999, and number range of DBs created via SFC 86: 60 000 60 999
• Size, max.	1 Mbyte; For DBs with absolute addressing, the max. size is 64 KB
FB	
Number range	0 65 535
Size, max.	300 kbyte
FC	
Number range	0 65 535
• Size, max.	300 kbyte
OB	
• Size, max.	300 kbyte
Number of free cycle OBs	100
Number of time alarm OBs	20
Number of delay alarm OBs	20
Number of cyclic interrupt OBs	20; With minimum OB 3x cycle of 250 μs
Number of process alarm OBs	50
Number of DPV1 alarm OBs	3
Number of isochronous mode OBs	1
Number of technology synchronous alarm OBs	2
Number of startup OBs	100
Number of asynchronous error OBs	4
Number of synchronous error OBs	2
Number of diagnostic alarm OBs	1
Nesting depth	
per priority class	24; Up to 8 possible for F-blocks
Counters, timers and their retentivity	
S7 counter	
Number	2 048
Retentivity	
— adjustable	Yes
IEC counter	
• Number	Any (only limited by the main memory)
Retentivity	
— adjustable	Yes
S7 times	0.010
• Number	2 048
Retentivity	· ·
— adjustable	Yes
IEC timer	
Number	Any (only limited by the main memory)
Retentivity	V
— adjustable	Yes
Data areas and their retentivity	
Retentive data area (incl. timers, counters, flags), max.	256 kbyte; in total; available retentive memory for bit memories, timers, counters, DBs, and technology data (axes): 216 KB
Flag	253.11010, 250, and commoney data (and). 210 ND
• Size, max.	16 kbyte
Number of clock memories	8; 8 clock memory bit, grouped into one clock memory byte
Data blocks	t, 2 dodsd., s., g. saped into one dods memory byte
Retentivity adjustable	Yes
Retentivity preset	No
Local data	
per priority class, max.	64 kbyte; max. 16 KB per block
Address area	5
Number of IO modules	2 048; max. number of modules / submodules
Hamber of to modules	
	2 0 10, max. nambor of modulos / odsmodulos
I/O address area	
I/O address area • Inputs	32 kbyte; All inputs are in the process image
I/O address area • Inputs • Outputs	
I/O address area • Inputs • Outputs per integrated IO subsystem	32 kbyte; All inputs are in the process image 32 kbyte; All outputs are in the process image
I/O address area • Inputs • Outputs	32 kbyte; All inputs are in the process image

per CM/CP	
— Inputs (volume)	8 kbyte
— Outputs (volume)	8 kbyte
Subprocess images	
Number of subprocess images, max.	32
Address space per module	
Address space per module, max.	288 byte; For input and output data respectively
Address space per station	
Address space per station, max.	2 560 byte; for central inputs and outputs; depending on configuration; 2 048 bytes for ET 200SP modules + 512 bytes for ET 200AL modules
Hardware configuration	
Number of distributed IO systems	32; A distributed I/O system is characterized not only by the integration of distributed I/O via PROFINET or PROFIBUS communication modules, but also by the connection of I/O via AS-i master modules or links (e.g. IE/PB-Link)
Number of DP masters	
Via CM	1
Number of IO Controllers	
integrated	1
• Via CM	0
Rack	
Modules per rack, max.	82; CPU + 64 modules + server module (mounting width max. 1 m) + 16 ET 200AL modules
 Quantity of operable ET 200SP modules, max. 	64
 Quantity of operable ET 200AL modules, max. 	16
Number of lines, max.	1
PtP CM	
Number of PtP CMs	the number of connectable PtP CMs is only limited by the number of available slots
Time of day	
Clock	
• Type	Hardware clock
Backup time	6 wk; At 40 °C ambient temperature, typically
Deviation per day, max.	10 s; Typ.: 2 s
Operating hours counter	
Number	16
Clock synchronization	
supported	Yes
• to DP, master	Yes; Via CM DP module
◆ to DP, slave	Yes; Via CM DP module
• in AS, master	Yes
• in AS, slave	Yes
 on Ethernet via NTP 	Yes
Interfaces	
Number of PROFINET interfaces	1
Number of PROFIBUS interfaces	1; Via CM DP module
Optical interface	No
1. Interface	
Interface types	
RJ 45 (Ethernet)	Yes; X1 P3; opt. X1 P1 and X1 P2 via BusAdapter BA 2x RJ45
Number of ports	3; 1. integr. + 2. via BusAdapter
integrated switch	Yes
BusAdapter (PROFINET)	Yes; compatible BusAdapters: BA 2x RJ45, BA 2x FC, BA 2x M12
Protocols	
• IP protocol	Yes; IPv4
PROFINET IO Controller	Yes
PROFINET IO Device	Yes
SIMATIC communication	Yes
Open IE communication	Yes; Optionally also encrypted
Web server	Yes
Media redundancy	Yes
PROFINET IO Controller	
Services	
OCI 41000	

DC/OD communication	Voc
— PG/OP communication	Yes
— Isochronous mode	Yes
— Direct data exchange	Yes; Requirement: IRT and isochronous mode (MRPD optional)
— IRT	Yes
— PROFlenergy	Yes; per user program
— Prioritized startup	Yes; Max. 32 PROFINET devices
 Number of connectable IO Devices, max. 	128; In total, up to 512 distributed I/O devices can be connected via AS-i, PROFIBUS or PROFINET
 Of which IO devices with IRT, max. 	64
 Number of connectable IO Devices for RT, max. 	128
— of which in line, max.	128
 Number of IO Devices that can be simultaneously activated/deactivated, max. 	8; in total across all interfaces
 Number of IO Devices per tool, max. 	8
— Updating times	The minimum value of the update time also depends on communication share set for PROFINET IO, on the number of IO devices, and on the quantity of configured user data
Update time for IRT	
— for send cycle of 250 μs	250 μs to 4 ms; Note: In the case of IRT with isochronous mode, the minimum
— for send cycle of 500 μs	update time of 500 µs of the isochronous OB is decisive 500 µs to 8 ms; Note: In the case of IRT with isochronous mode, the minimum
•	update time of 625 µs of the isochronous OB is decisive
— for send cycle of 1 ms	1 ms to 16 ms
— for send cycle of 2 ms	2 ms to 32 ms
— for send cycle of 4 ms	4 ms to 64 ms
 With IRT and parameterization of "odd" send cycles 	Update time = set "odd" send clock (any multiple of 125 μ s: 375 μ s, 625 μ s 3 875 μ s)
Update time for RT	
— for send cycle of 250 μs	250 µs to 128 ms
— for send cycle of 500 μs	500 μs to 256 ms
— for send cycle of 1 ms	1 ms to 512 ms
— for send cycle of 2 ms	2 ms to 512 ms
•	4 ms to 512 ms
— for send cycle of 4 ms	4 1115 10 312 1115
— for send cycle of 4 ms PROFINET IO Device	4 1115 to 512 1115
— for send cycle of 4 ms PROFINET IO Device Services	4 1115 10 512 1115
PROFINET IO Device	Yes
PROFINET IO Device Services	
PROFINET IO Device Services — PG/OP communication	Yes
PROFINET IO Device Services — PG/OP communication — Isochronous mode — IRT	Yes No Yes
PROFINET IO Device Services — PG/OP communication — Isochronous mode	Yes No
PROFINET IO Device Services — PG/OP communication — Isochronous mode — IRT — PROFlenergy	Yes No Yes Yes; per user program
PROFINET IO Device Services — PG/OP communication — Isochronous mode — IRT — PROFlenergy — Shared device	Yes No Yes Yes; per user program Yes 4
PROFINET IO Device Services — PG/OP communication — Isochronous mode — IRT — PROFIenergy — Shared device — Number of IO Controllers with shared device, max.	Yes No Yes Yes; per user program Yes 4 Yes; per user program
PROFINET IO Device Services — PG/OP communication — Isochronous mode — IRT — PROFIenergy — Shared device — Number of IO Controllers with shared device, max. — activation/deactivation of I-devices	Yes No Yes Yes; per user program Yes 4
PROFINET IO Device Services — PG/OP communication — Isochronous mode — IRT — PROFlenergy — Shared device — Number of IO Controllers with shared device, max. — activation/deactivation of I-devices — Asset management record	Yes No Yes Yes; per user program Yes 4 Yes; per user program
PROFINET IO Device Services — PG/OP communication — Isochronous mode — IRT — PROFlenergy — Shared device — Number of IO Controllers with shared device, max. — activation/deactivation of I-devices — Asset management record 2. Interface	Yes No Yes Yes; per user program Yes 4 Yes; per user program
PROFINET IO Device Services — PG/OP communication — Isochronous mode — IRT — PROFlenergy — Shared device — Number of IO Controllers with shared device, max. — activation/deactivation of I-devices — Asset management record 2. Interface Interface types	Yes No Yes Yes; per user program Yes 4 Yes; per user program Yes; per user program Yes; per user program
PROFINET IO Device Services — PG/OP communication — Isochronous mode — IRT — PROFIenergy — Shared device — Number of IO Controllers with shared device, max. — activation/deactivation of I-devices — Asset management record 2. Interface Interface types • RS 485	Yes No Yes Yes; per user program Yes 4 Yes; per user program Yes; per user program Yes; per user program
PROFINET IO Device Services — PG/OP communication — Isochronous mode — IRT — PROFlenergy — Shared device — Number of IO Controllers with shared device, max. — activation/deactivation of I-devices — Asset management record 2. Interface Interface types • RS 485 • Number of ports	Yes No Yes Yes; per user program Yes 4 Yes; per user program Yes; per user program Yes; per user program
PROFINET IO Device Services — PG/OP communication — Isochronous mode — IRT — PROFlenergy — Shared device — Number of IO Controllers with shared device, max. — activation/deactivation of I-devices — Asset management record 2. Interface Interface types • RS 485 • Number of ports Protocols	Yes No Yes Yes; per user program Yes 4 Yes; per user program Yes; per user program Yes; per user program Yes; Via CM DP module 1
PROFIBUS DP master Services — PG/OP communication — Isochronous mode — IRT — PROFlenergy — Shared device — Number of IO Controllers with shared device, max. — activation/deactivation of I-devices — Asset management record 2. Interface Interface types • RS 485 • Number of ports Protocols • PROFIBUS DP master	Yes No Yes Yes; per user program Yes 4 Yes; per user program Yes; per user program Yes; per user program Yes; Via CM DP module 1 Yes
PROFIBUS DP slave Services — PG/OP communication — Isochronous mode — IRT — PROFlenergy — Shared device — Number of IO Controllers with shared device, max. — activation/deactivation of I-devices — Asset management record 2. Interface Interface types • RS 485 • Number of ports Protocols • PROFIBUS DP master • PROFIBUS DP slave	Yes No Yes Yes; per user program Yes 4 Yes; per user program Yes; per user program Yes; per user program Yes; Via CM DP module 1 Yes Yes
PROFINET IO Device Services — PG/OP communication — Isochronous mode — IRT — PROFlenergy — Shared device — Number of IO Controllers with shared device, max. — activation/deactivation of I-devices — Asset management record 2. Interface Interface types • RS 485 • Number of ports Protocols • PROFIBUS DP master • PROFIBUS DP slave • SIMATIC communication	Yes No Yes Yes; per user program Yes 4 Yes; per user program Yes; per user program Yes; per user program Yes; Via CM DP module 1 Yes Yes
PROFIBUS DP master Services — PG/OP communication — Isochronous mode — IRT — PROFlenergy — Shared device — Number of IO Controllers with shared device, max. — activation/deactivation of I-devices — Asset management record 2. Interface Interface types • RS 485 • Number of ports Protocols • PROFIBUS DP master • PROFIBUS DP slave • SIMATIC communication PROFIBUS DP master	Yes No Yes Yes; per user program Yes 4 Yes; per user program Yes; per user program Yes; per user program Yes; Via CM DP module 1 Yes Yes Yes
PROFINET IO Device Services — PG/OP communication — Isochronous mode — IRT — PROFlenergy — Shared device — Number of IO Controllers with shared device, max. — activation/deactivation of I-devices — Asset management record 2. Interface Interface types • RS 485 • Number of ports Protocols • PROFIBUS DP master • PROFIBUS DP slave • SIMATIC communication PROFIBUS DP master • Number of connections, max.	Yes No Yes Yes; per user program Yes 4 Yes; per user program Yes; per user program Yes; per user program Yes; Via CM DP module 1 Yes Yes Yes Yes In total, up to 512 distributed I/O devices can be connected via AS-i,
PROFINET IO Device Services — PG/OP communication — Isochronous mode — IRT — PROFlenergy — Shared device — Number of IO Controllers with shared device, max. — activation/deactivation of I-devices — Asset management record 2. Interface Interface types • RS 485 • Number of ports Protocols • PROFIBUS DP master • PROFIBUS DP slave • SIMATIC communication PROFIBUS DP master • Number of connections, max. • Number of DP slaves, max.	Yes No Yes Yes; per user program Yes 4 Yes; per user program Yes; per user program Yes; per user program Yes; Via CM DP module 1 Yes Yes Yes Yes In total, up to 512 distributed I/O devices can be connected via AS-i,
PROFINET IO Device Services — PG/OP communication — Isochronous mode — IRT — PROFlenergy — Shared device — Number of IO Controllers with shared device, max. — activation/deactivation of I-devices — Asset management record 2. Interface Interface types • RS 485 • Number of ports Protocols • PROFIBUS DP master • PROFIBUS DP slave • SIMATIC communication PROFIBUS DP master • Number of connections, max. • Number of DP slaves, max. Services — PG/OP communication	Yes No Yes Yes; per user program Yes 4 Yes; per user program Yes; per user program Yes; per user program Yes; Via CM DP module 1 Yes Yes Yes Yes Yes Yes Yes The connected via AS-i, PROFIBUS or PROFINET
PROFINET IO Device Services — PG/OP communication — Isochronous mode — IRT — PROFlenergy — Shared device — Number of IO Controllers with shared device, max. — activation/deactivation of I-devices — Asset management record 2. Interface Interface types • RS 485 • Number of ports Protocols • PROFIBUS DP master • PROFIBUS DP slave • SIMATIC communication PROFIBUS DP master • Number of connections, max. • Number of DP slaves, max. Services	Yes No Yes Yes; per user program Yes 4 Yes; per user program Yes; per user program Yes; per user program Yes; Via CM DP module 1 Yes Yes Yes Yes Yes Yes Yes Yes Yes Ye
PROFINET IO Device Services — PG/OP communication — Isochronous mode — IRT — PROFlenergy — Shared device — Number of IO Controllers with shared device, max. — activation/deactivation of I-devices — Asset management record 2. Interface Interface types • RS 485 • Number of ports Protocols • PROFIBUS DP master • PROFIBUS DP slave • SIMATIC communication PROFIBUS DP master • Number of connections, max. • Number of DP slaves, max. Services — PG/OP communication — Equidistance	Yes No Yes Yes; per user program Yes 4 Yes; per user program Yes; per user program Yes; per user program Yes; Via CM DP module 1 Yes Yes Yes Yes Yes Yes Yes Yes Yes Ye
PROFINET IO Device Services — PG/OP communication — Isochronous mode — IRT — PROFlenergy — Shared device — Number of IO Controllers with shared device, max. — activation/deactivation of I-devices — Asset management record 2. Interface Interface types • RS 485 • Number of ports Protocols • PROFIBUS DP master • PROFIBUS DP slave • SIMATIC communication PROFIBUS DP master • Number of connections, max. • Number of DP slaves, max. Services — PG/OP communication — Equidistance — Isochronous mode — Activation/deactivation of DP slaves	Yes No Yes Yes; per user program Yes 4 Yes; per user program Yes; per user program Yes; per user program Yes; Via CM DP module 1 Yes Yes Yes Yes Yes Yes Yes 48; Of which 4 each reserved for ES and HMI 125; In total, up to 512 distributed I/O devices can be connected via AS-i, PROFIBUS or PROFINET Yes No No
PROFINET IO Device Services — PG/OP communication — Isochronous mode — IRT — PROFIenergy — Shared device — Number of IO Controllers with shared device, max. — activation/deactivation of I-devices — Asset management record 2. Interface Interface types • RS 485 • Number of ports Protocols • PROFIBUS DP master • PROFIBUS DP slave • SIMATIC communication PROFIBUS DP master • Number of connections, max. • Number of DP slaves, max. Services — PG/OP communication — Equidistance — Isochronous mode — Activation/deactivation of DP slaves Interface types	Yes No Yes Yes; per user program Yes 4 Yes; per user program Yes; per user program Yes; per user program Yes; Via CM DP module 1 Yes Yes Yes Yes Yes Yes Yes 48; Of which 4 each reserved for ES and HMI 125; In total, up to 512 distributed I/O devices can be connected via AS-i, PROFIBUS or PROFINET Yes No No
PROFINET IO Device Services — PG/OP communication — Isochronous mode — IRT — PROFlenergy — Shared device — Number of IO Controllers with shared device, max. — activation/deactivation of I-devices — Asset management record 2. Interface Interface types • RS 485 • Number of ports Protocols • PROFIBUS DP master • PROFIBUS DP slave • SIMATIC communication PROFIBUS DP master • Number of connections, max. • Number of DP slaves, max. Services — PG/OP communication — Equidistance — Isochronous mode — Activation/deactivation of DP slaves	Yes No Yes Yes; per user program Yes 4 Yes; per user program Yes; per user program Yes; per user program Yes; Via CM DP module 1 Yes Yes Yes Yes Yes Yes Yes 48; Of which 4 each reserved for ES and HMI 125; In total, up to 512 distributed I/O devices can be connected via AS-i, PROFIBUS or PROFINET Yes No No

A	V
Autonegotiation	Yes
Autocrossing	Yes
Industrial Ethernet status LED	Yes
RS 485	
Transmission rate, max.	12 Mbit/s
Protocols	
PROFIsafe	Yes; V2.4 / V2.6
Number of connections	
 Number of connections, max. 	128; via integrated interfaces of the CPU and connected CPs / CMs
 Number of connections reserved for ES/HMI/web 	10
 Number of connections via integrated interfaces 	88
 Number of connections per CP/CM 	32
Number of S7 routing paths	16
Redundancy mode	
H-Sync forwarding	Yes
Media redundancy	
— Media redundancy	Yes; only via BusAdapter
— MRP	Yes; MRP Automanager according to IEC 62439-2 Edition 2.0, MRP Manager; MRP Client
- MRP interconnection, supported	Yes; as MRP ring node according to IEC 62439-2 Edition 3.0
— MRPD	Yes; Requirement: IRT
 Switchover time on line break, typ. 	200 ms; For MRP, bumpless for MRPD
— Number of stations in the ring, max.	50
SIMATIC communication	
PG/OP communication	Yes; encryption with TLS V1.3 pre-selected
S7 routing	Yes
Data record routing	Yes
S7 communication, as server	Yes
S7 communication, as client	Yes
User data per job, max.	See online help (S7 communication, user data size)
Open IE communication	
• TCP/IP	Yes
— Data length, max.	64 kbyte
several passive connections per port, supported	Yes
• ISO-on-TCP (RFC1006)	Yes
— Data length, max.	64 kbyte
• UDP	Yes
— Data length, max.	2 kbyte; 1 472 bytes for UDP broadcast
— UDP multicast	Yes; max. 78 multicast circuits
DHCP	Yes
• DNS	Yes
• SNMP	Yes
• DCP	Yes
• LLDP	Yes
• Encryption	Yes; Optional
Web server	V Other dead and use a series
• HTTP	Yes; Standard and user pages
• HTTPS	Yes; Standard and user pages
OPC UA	V
Runtime license required	Yes; "Small" license required
OPC UA Client	Yes; Data Access (registered Read/Write), Method Call
Application authentication	Yes
— Security policies	Available security policies: None, Basic128Rsa15, Basic256Rsa15, Basic256Sha256
User authentication	"anonymous" or by user name & password
 Number of connections, max. 	4
 Number of nodes of the client interfaces, recommended max. 	1 000
 Number of elements for one call of OPC_UA_NodeGetHandleList/OPC_UA_ReadList/OPC_I max. 	300
Number of elements for one call of	20

OPC_UA_NameSpaceGetIndexList, max.	400
 Number of elements for one call of OPC_UA_MethodGetHandleList, max. 	100
 Number of simultaneous calls of the client instructions for session management, per connection, max. 	1
 Number of simultaneous calls of the client instructions for data access, per connection, max. 	5
 Number of registerable nodes, max. 	5 000
 Number of registerable method calls of OPC_UA_MethodCall, max. 	100
 Number of inputs/outputs when calling OPC_UA_MethodCall, max. 	20
OPC UA Server	Yes; Data Access (Read, Write, Subscribe), Method Call, Alarms & Condition (A&C), Custom Address Space
 Application authentication 	Yes
— Security policies	available security policies: None, Basic128Rsa15, Basic256Rsa15, Basic256Sha256, Aes128Sha256RsaOaep, Aes256Sha256RsaPss
User authentication	"anonymous" or by user name & password
 — GDS support (certificate management) 	Yes
— Number of sessions, max.	32
 Number of accessible variables, max. 	50 000
 Number of registerable nodes, max. 	10 000
 Number of subscriptions per session, max. 	50
 — Sampling interval, min. 	100 ms
— Publishing interval, min.	200 ms
 Number of server methods, max. 	20
 Number of inputs/outputs per server method, max. 	20
 Number of monitored items, recommended max. 	4 000; for 1 s sampling interval and 1 s send interval
 Number of server interfaces, max. 	10 of each "Server interfaces" / "Companion specification" type and 20 of the
Number of nodes for user-defined server interfaces, max.	type "Reference namespace" 15 000
Alarms and Conditions	Yes
 Number of program alarms 	100
Number of program alarms Number of alarms for system diagnostics	
Number of program alarms Number of alarms for system diagnostics Further protocols	100 50
 Number of program alarms Number of alarms for system diagnostics Further protocols MODBUS 	100
 Number of program alarms Number of alarms for system diagnostics Further protocols MODBUS S7 message functions 	100 50 Yes; MODBUS TCP
— Number of program alarms — Number of alarms for system diagnostics Further protocols • MODBUS S7 message functions Number of login stations for message functions, max.	100 50 Yes; MODBUS TCP
 Number of program alarms Number of alarms for system diagnostics Further protocols MODBUS S7 message functions 	100 50 Yes; MODBUS TCP
— Number of program alarms — Number of alarms for system diagnostics Further protocols • MODBUS S7 message functions Number of login stations for message functions, max. Program alarms	100 50 Yes; MODBUS TCP 32 Yes 5 000; Program messages are generated by the "Program_Alarm" block,
— Number of program alarms — Number of alarms for system diagnostics Further protocols • MODBUS S7 message functions Number of login stations for message functions, max. Program alarms Number of configurable program messages, max.	100 50 Yes; MODBUS TCP 32 Yes 5 000; Program messages are generated by the "Program_Alarm" block, ProDiag or GRAPH
- Number of program alarms - Number of alarms for system diagnostics Further protocols • MODBUS S7 message functions Number of login stations for message functions, max. Program alarms Number of configurable program messages, max. Number of loadable program messages in RUN, max.	100 50 Yes; MODBUS TCP 32 Yes 5 000; Program messages are generated by the "Program_Alarm" block, ProDiag or GRAPH
- Number of program alarms - Number of alarms for system diagnostics Further protocols • MODBUS S7 message functions Number of login stations for message functions, max. Program alarms Number of configurable program messages, max. Number of loadable program messages in RUN, max. Number of simultaneously active program alarms • Number of program alarms	Yes; MODBUS TCP 32 Yes 5 000; Program messages are generated by the "Program_Alarm" block, ProDiag or GRAPH 2 500
- Number of program alarms - Number of alarms for system diagnostics Further protocols • MODBUS S7 message functions Number of login stations for message functions, max. Program alarms Number of configurable program messages, max. Number of loadable program messages in RUN, max. Number of simultaneously active program alarms • Number of program alarms • Number of alarms for system diagnostics	Yes; MODBUS TCP 32 Yes 5 000; Program messages are generated by the "Program_Alarm" block, ProDiag or GRAPH 2 500 600
- Number of program alarms - Number of alarms for system diagnostics Further protocols • MODBUS S7 message functions Number of login stations for message functions, max. Program alarms Number of configurable program messages, max. Number of loadable program messages in RUN, max. Number of simultaneously active program alarms • Number of program alarms • Number of alarms for system diagnostics • Number of alarms for motion technology objects	100 50 Yes; MODBUS TCP 32 Yes 5 000; Program messages are generated by the "Program_Alarm" block, ProDiag or GRAPH 2 500 600 100
- Number of program alarms - Number of alarms for system diagnostics Further protocols • MODBUS S7 message functions Number of login stations for message functions, max. Program alarms Number of configurable program messages, max. Number of loadable program messages in RUN, max. Number of simultaneously active program alarms • Number of program alarms • Number of alarms for system diagnostics • Number of alarms for motion technology objects Test commissioning functions	Yes; MODBUS TCP 32 Yes 5 000; Program messages are generated by the "Program_Alarm" block, ProDiag or GRAPH 2 500 600 100 160
- Number of program alarms - Number of alarms for system diagnostics Further protocols • MODBUS S7 message functions Number of login stations for message functions, max. Program alarms Number of configurable program messages, max. Number of loadable program messages in RUN, max. Number of simultaneously active program alarms • Number of program alarms • Number of alarms for system diagnostics • Number of alarms for motion technology objects Test commissioning functions Joint commission (Team Engineering)	Yes; MODBUS TCP 32 Yes 5 000; Program messages are generated by the "Program_Alarm" block, ProDiag or GRAPH 2 500 600 100 100 160 Yes; Parallel online access possible for up to 5 engineering systems
- Number of program alarms - Number of alarms for system diagnostics Further protocols • MODBUS S7 message functions Number of login stations for message functions, max. Program alarms Number of configurable program messages, max. Number of loadable program messages in RUN, max. Number of simultaneously active program alarms • Number of program alarms • Number of alarms for system diagnostics • Number of alarms for motion technology objects Test commissioning functions Joint commission (Team Engineering) Status block	Yes; MODBUS TCP 32 Yes 5 000; Program messages are generated by the "Program_Alarm" block, ProDiag or GRAPH 2 500 600 100 160 Yes; Parallel online access possible for up to 5 engineering systems Yes; Up to 8 simultaneously (in total across all ES clients)
- Number of program alarms - Number of alarms for system diagnostics Further protocols • MODBUS S7 message functions Number of login stations for message functions, max. Program alarms Number of configurable program messages, max. Number of loadable program messages in RUN, max. Number of simultaneously active program alarms • Number of program alarms • Number of alarms for system diagnostics • Number of alarms for motion technology objects Test commissioning functions Joint commission (Team Engineering) Status block Single step	Yes; MODBUS TCP 32 Yes 5 000; Program messages are generated by the "Program_Alarm" block, ProDiag or GRAPH 2 500 600 100 160 Yes; Parallel online access possible for up to 5 engineering systems Yes; Up to 8 simultaneously (in total across all ES clients) No
Number of program alarms Number of alarms for system diagnostics Further protocols • MODBUS S7 message functions Number of login stations for message functions, max. Program alarms Number of configurable program messages, max. Number of loadable program messages in RUN, max. Number of simultaneously active program alarms • Number of program alarms • Number of alarms for system diagnostics • Number of alarms for motion technology objects Test commissioning functions Joint commission (Team Engineering) Status block Single step Number of breakpoints	Yes; MODBUS TCP 32 Yes 5 000; Program messages are generated by the "Program_Alarm" block, ProDiag or GRAPH 2 500 600 100 160 Yes; Parallel online access possible for up to 5 engineering systems Yes; Up to 8 simultaneously (in total across all ES clients)
Number of program alarms Number of alarms for system diagnostics Further protocols • MODBUS S7 message functions Number of login stations for message functions, max. Program alarms Number of configurable program messages, max. Number of loadable program messages in RUN, max. Number of simultaneously active program alarms • Number of program alarms • Number of alarms for system diagnostics • Number of alarms for motion technology objects Test commissioning functions Joint commission (Team Engineering) Status block Single step Number of breakpoints Status/control	Yes; MODBUS TCP 32 Yes 5 000; Program messages are generated by the "Program_Alarm" block, ProDiag or GRAPH 2 500 600 100 100 160 Yes; Parallel online access possible for up to 5 engineering systems Yes; Up to 8 simultaneously (in total across all ES clients) No 8
Number of program alarms Number of alarms for system diagnostics Further protocols • MODBUS S7 message functions Number of login stations for message functions, max. Program alarms Number of configurable program messages, max. Number of loadable program messages in RUN, max. Number of simultaneously active program alarms • Number of program alarms • Number of alarms for system diagnostics • Number of alarms for motion technology objects Test commissioning functions Joint commission (Team Engineering) Status block Single step Number of breakpoints	Yes; MODBUS TCP 32 Yes 5 000; Program messages are generated by the "Program_Alarm" block, ProDiag or GRAPH 2 500 600 100 160 Yes; Parallel online access possible for up to 5 engineering systems Yes; Up to 8 simultaneously (in total across all ES clients) No
Number of program alarms Number of alarms for system diagnostics Further protocols • MODBUS S7 message functions Number of login stations for message functions, max. Program alarms Number of configurable program messages, max. Number of loadable program messages in RUN, max. Number of simultaneously active program alarms • Number of program alarms • Number of alarms for system diagnostics • Number of alarms for motion technology objects Test commissioning functions Joint commission (Team Engineering) Status block Single step Number of breakpoints Status/control • Status/control variable • Variables	Yes; MODBUS TCP 32 Yes 5 000; Program messages are generated by the "Program_Alarm" block, ProDiag or GRAPH 2 500 600 100 160 Yes; Parallel online access possible for up to 5 engineering systems Yes; Up to 8 simultaneously (in total across all ES clients) No 8 Yes; without fail-safe inputs/outputs, bit memories, DBs, peripheral I/Os (without fail-safe), times,
Number of program alarms Number of alarms for system diagnostics Further protocols • MODBUS S7 message functions Number of login stations for message functions, max. Program alarms Number of configurable program messages, max. Number of loadable program messages in RUN, max. Number of simultaneously active program alarms • Number of program alarms • Number of alarms for system diagnostics • Number of alarms for motion technology objects Test commissioning functions Joint commission (Team Engineering) Status block Single step Number of breakpoints Status/control • Status/control variable • Variables • Number of variables, max.	Yes; MODBUS TCP 32 Yes 5 000; Program messages are generated by the "Program_Alarm" block, ProDiag or GRAPH 2 500 600 100 160 Yes; Parallel online access possible for up to 5 engineering systems Yes; Up to 8 simultaneously (in total across all ES clients) No 8 Yes; without fail-safe inputs/outputs, bit memories, DBs, peripheral I/Os (without fail-safe), times, counters
 Number of program alarms Number of alarms for system diagnostics Further protocols MODBUS S7 message functions Number of login stations for message functions, max. Program alarms Number of configurable program messages, max. Number of loadable program messages in RUN, max. Number of simultaneously active program alarms Number of program alarms Number of alarms for system diagnostics Number of alarms for motion technology objects Test commissioning functions Joint commission (Team Engineering) Status block Single step Number of breakpoints Status/control Status/control variable Variables Number of variables, max. of which status variables, max. 	Yes; MODBUS TCP 32 Yes 5 000; Program messages are generated by the "Program_Alarm" block, ProDiag or GRAPH 2 500 600 100 100 160 Yes; Parallel online access possible for up to 5 engineering systems Yes; Up to 8 simultaneously (in total across all ES clients) No 8 Yes; without fail-safe inputs/outputs, bit memories, DBs, peripheral I/Os (without fail-safe), times, counters 200; per job
 Number of program alarms Number of alarms for system diagnostics Further protocols MODBUS 87 message functions Number of login stations for message functions, max. Program alarms Number of configurable program messages, max. Number of loadable program messages in RUN, max. Number of simultaneously active program alarms Number of program alarms Number of alarms for system diagnostics Number of alarms for motion technology objects Test commissioning functions Joint commission (Team Engineering) Status block Single step Number of breakpoints Status/control Status/control variable Variables Number of variables, max. of which status variables, max. of which control variables, max. 	Yes; MODBUS TCP 32 Yes 5 000; Program messages are generated by the "Program_Alarm" block, ProDiag or GRAPH 2 500 600 100 160 Yes; Parallel online access possible for up to 5 engineering systems Yes; Up to 8 simultaneously (in total across all ES clients) No 8 Yes; without fail-safe inputs/outputs, bit memories, DBs, peripheral I/Os (without fail-safe), times, counters
 Number of program alarms Number of alarms for system diagnostics Further protocols MODBUS S7 message functions Number of login stations for message functions, max. Program alarms Number of configurable program messages, max. Number of loadable program messages in RUN, max. Number of simultaneously active program alarms Number of program alarms Number of alarms for system diagnostics Number of alarms for motion technology objects Test commissioning functions Joint commission (Team Engineering) Status block Single step Number of breakpoints Status/control Status/control variable Variables Number of variables, max. of which status variables, max. of which control variables, max. Forcing	Yes; MODBUS TCP 32 Yes 5 000; Program messages are generated by the "Program_Alarm" block, ProDiag or GRAPH 2 500 600 100 160 Yes; Parallel online access possible for up to 5 engineering systems Yes; Up to 8 simultaneously (in total across all ES clients) No 8 Yes; without fail-safe inputs/outputs, bit memories, DBs, peripheral I/Os (without fail-safe), times, counters 200; per job 200; per job
 Number of program alarms Number of alarms for system diagnostics Further protocols MODBUS S7 message functions Number of login stations for message functions, max. Program alarms Number of configurable program messages, max. Number of loadable program messages in RUN, max. Number of simultaneously active program alarms Number of program alarms Number of alarms for system diagnostics Number of alarms for motion technology objects Test commissioning functions Joint commission (Team Engineering) Status block Single step Number of breakpoints Status/control Status/control variable Variables Number of variables, max. of which status variables, max. of which control variables, max. Forcing Forcing 	Yes; MODBUS TCP 32 Yes 5 000; Program messages are generated by the "Program_Alarm" block, ProDiag or GRAPH 2 500 600 100 160 Yes; Parallel online access possible for up to 5 engineering systems Yes; Up to 8 simultaneously (in total across all ES clients) No 8 Yes; without fail-safe inputs/outputs, bit memories, DBs, peripheral I/Os (without fail-safe), times, counters 200; per job 200; per job
 Number of program alarms Number of alarms for system diagnostics Further protocols MODBUS S7 message functions Number of login stations for message functions, max. Program alarms Number of configurable program messages, max. Number of loadable program messages in RUN, max. Number of simultaneously active program alarms Number of program alarms Number of alarms for system diagnostics Number of alarms for motion technology objects Test commissioning functions Joint commission (Team Engineering) Status block Single step Number of breakpoints Status/control Status/control variable Variables Number of variables, max. of which status variables, max. of which control variables, max. Forcing	Yes; MODBUS TCP 32 Yes 5 000; Program messages are generated by the "Program_Alarm" block, ProDiag or GRAPH 2 500 600 100 160 Yes; Parallel online access possible for up to 5 engineering systems Yes; Up to 8 simultaneously (in total across all ES clients) No 8 Yes; without fail-safe inputs/outputs, bit memories, DBs, peripheral I/Os (without fail-safe), times, counters 200; per job 200; per job

Diagnostic buffer	
present	Yes
Number of entries, max.	1 000
— of which powerfail-proof	500
Traces	300
Number of configurable Traces	4; Up to 512 KB of data per trace are possible
Interrupts/diagnostics/status information	4, Op to 312 NB of data per trace are possible
Diagnostics indication LED RUN/STOP LED	Yes
• ERROR LED	Yes
MAINT LED	Yes
	Yes
Monitoring of the supply voltage (PWR-LED)Connection display LINK TX/RX	Yes
Supported technology objects	T CS
Motion Control	Voc. Note: The number of technology chicate affects the guals time of the DLC
	Yes; Note: The number of technology objects affects the cycle time of the PLC program; selection guide via the TIA Selection Tool
 Number of available Motion Control resources for technology objects 	1 120
 Required Motion Control resources 	
— per speed-controlled axis	40
— per positioning axis	80
— per synchronous axis	160
— per external encoder	80
— per output cam	20
— per cam track	160
— per probe	40
 Positioning axis 	
 Number of positioning axes at motion control cycle of 4 ms (typical value) 	11
 Number of positioning axes at motion control cycle of 8 ms (typical value) 	14
Controller	
PID_Compact	Yes; Universal PID controller with integrated optimization
PID_3Step	Yes; PID controller with integrated optimization for valves
PID-Temp	Yes; PID controller with integrated optimization for temperature
Counting and measuring	
High-speed counter	Yes
Standards, approvals, certificates	
Highest safety class achievable in safety mode	
 Performance level according to ISO 13849-1 	PLe
SIL acc. to IEC 61508	SIL 3
Probability of failure (for service life of 20 years and repair time	e of 100 hours)
 Low demand mode: PFDavg in accordance with SIL3 	< 2.00E-05
High demand/continuous mode: PFH in accordance with SIL3	< 1.00E-09
Ambient conditions	
Ambient temperature during operation	
 horizontal installation, min. 	-40 °C; = Tmin (incl. condensation/frost)
 horizontal installation, max. 	60 °C; = Tmax
 vertical installation, min. 	-40 °C; = Tmin
vertical installation, max.	50 °C; = Tmax
Altitude during operation relating to sea level	
 Installation altitude above sea level, max. 	5 000 m; Restrictions for installation altitudes > 2 000 m, see manual
Relative humidity	
 With condensation, tested in accordance with IEC 60068- 2-38, max. 	100 %; RH incl. condensation / frost (no commissioning in bedewed state), horizontal installation
Resistance	
Coolants and lubricants	
 Resistant to commercially available coolants and lubricants 	Yes; Incl. diesel and oil droplets in the air
Use in stationary industrial systems	
— to biologically active substances according to EN	Yes; Class 3B2 mold, fungus and dry rot spores (with the exception of fauna);

60721-3-3	Class 3B3 on request
 to chemically active substances according to EN 60721-3-3 	Yes; Class 3C4 (RH < 75 %) incl. salt spray acc. to EN 60068-2-52 (severity degree 3); *
 to mechanically active substances according to EN 60721-3-3 	Yes; Class 3S4 incl. sand, dust, *
Use on ships/at sea	
 to biologically active substances according to EN 60721-3-6 	Yes; Class 6B2 mold, fungal and dry rot spores (excluding fauna)
 to chemically active substances according to EN 60721-3-6 	Yes; Class 6C3 (RH < 75 %) incl. salt spray acc. to EN 60068-2-52 (severity degree 3); *
 to mechanically active substances according to EN 60721-3-6 	Yes; Class 6S3 incl. sand, dust; *
Usage in industrial process technology	
 Against chemically active substances acc. to EN 60654-4 	Yes; Class 3 (excluding trichlorethylene)
 Environmental conditions for process, measuring and control systems acc. to ANSI/ISA-71.04 	Yes; Level GX group A/B (excluding trichlorethylene; harmful gas concentrations up to the limits of EN 60721-3-3 class 3C4 permissible); level LC3 (salt spray) and level LB3 (oil)
Remark	
 Note regarding classification of environmental conditions acc. to EN 60721, EN 60654-4 and ANSI/ISA-71.04 	* The supplied plug covers must remain in place over the unused interfaces during operation!
Conformal coating	
Coatings for printed circuit board assemblies acc. to EN 61086	Yes; Class 2 for high reliability
 Protection against fouling acc. to EN 60664-3 	Yes; Type 1 protection
 Military testing according to MIL-I-46058C, Amendment 7 	Yes; Discoloration of coating possible during service life
 Qualification and Performance of Electrical Insulating Compound for Printed Board Assemblies according to IPC- CC-830A 	Yes; Conformal coating, Class A
configuration / header	
configuration / programming / header	
configuration / programming / header Programming language	
	Yes; incl. failsafe
Programming language	Yes; incl. failsafe Yes; incl. failsafe
Programming language — LAD	
Programming language — LAD — FBD	Yes; incl. failsafe
Programming language — LAD — FBD — STL	Yes; incl. failsafe Yes
Programming language — LAD — FBD — STL — SCL	Yes; incl. failsafe Yes Yes
Programming language — LAD — FBD — STL — SCL — GRAPH	Yes; incl. failsafe Yes Yes
Programming language — LAD — FBD — STL — SCL — GRAPH Know-how protection	Yes; incl. failsafe Yes Yes Yes
Programming language — LAD — FBD — STL — SCL — GRAPH Know-how protection • User program protection/password protection	Yes; incl. failsafe Yes Yes Yes Yes
Programming language — LAD — FBD — STL — SCL — GRAPH Know-how protection • User program protection/password protection • Copy protection	Yes; incl. failsafe Yes Yes Yes Yes Yes
Programming language — LAD — FBD — STL — SCL — GRAPH Know-how protection • User program protection/password protection • Copy protection • Block protection	Yes; incl. failsafe Yes Yes Yes Yes Yes
Programming language — LAD — FBD — STL — SCL — GRAPH Know-how protection • User program protection/password protection • Copy protection • Block protection Access protection	Yes; incl. failsafe Yes Yes Yes Yes Yes Yes Yes
Programming language — LAD — FBD — STL — SCL — GRAPH Know-how protection • User program protection/password protection • Copy protection • Block protection Access protection • protection of confidential configuration data	Yes; incl. failsafe Yes Yes Yes Yes Yes Yes Yes
Programming language — LAD — FBD — STL — SCL — GRAPH Know-how protection • User program protection/password protection • Copy protection • Block protection Access protection • protection of confidential configuration data • Protection level: Write protection	Yes; incl. failsafe Yes Yes Yes Yes Yes Yes Yes Yes Yes
Programming language — LAD — FBD — STL — SCL — GRAPH Know-how protection • User program protection/password protection • Copy protection • Block protection Access protection • protection of confidential configuration data • Protection level: Write protection • Protection level: Read/write protection	Yes; incl. failsafe Yes Yes Yes Yes Yes Yes Yes Yes Yes Ye
Programming language — LAD — FBD — STL — SCL — GRAPH Know-how protection • User program protection/password protection • Copy protection • Block protection Access protection • protection of confidential configuration data • Protection level: Write protection • Protection level: Read/write protection • Protection level: Write protection • Protection level: Write protection	Yes; incl. failsafe Yes Yes Yes Yes Yes Yes Yes Yes Yes Ye
Programming language — LAD — FBD — STL — SCL — GRAPH Know-how protection • User program protection/password protection • Copy protection • Block protection Access protection • protection of confidential configuration data • Protection level: Write protection • Protection level: Read/write protection • Protection level: Write protection for Failsafe • Protection level: Complete protection	Yes; incl. failsafe Yes Yes Yes Yes Yes Yes Yes Yes Yes Ye
Programming language — LAD — FBD — STL — SCL — GRAPH Know-how protection • User program protection/password protection • Copy protection • Block protection Access protection • protection of confidential configuration data • Protection level: Write protection • Protection level: Read/write protection • Protection level: Write protection • Protection level: Complete protection programming / cycle time monitoring / header	Yes; incl. failsafe Yes Yes Yes Yes Yes Yes Yes Yes Yes Ye
Programming language — LAD — FBD — STL — SCL — GRAPH Know-how protection • User program protection/password protection • Copy protection • Block protection Access protection • protection of confidential configuration data • Protection level: Write protection • Protection level: Read/write protection • Protection level: Write protection • Protection level: Complete protection programming / cycle time monitoring / header • lower limit	Yes; incl. failsafe Yes Yes Yes Yes Yes Yes Yes Yes Yes Ye
Programming language — LAD — FBD — STL — SCL — GRAPH Know-how protection • User program protection/password protection • Copy protection • Block protection Access protection • protection of confidential configuration data • Protection level: Write protection • Protection level: Read/write protection • Protection level: Write protection • Protection level: Write protection for Failsafe • Protection level: Complete protection programming / cycle time monitoring / header • lower limit • upper limit	Yes; incl. failsafe Yes Yes Yes Yes Yes Yes Yes Yes Yes Ye
Programming language — LAD — FBD — STL — SCL — GRAPH Know-how protection • User program protection/password protection • Copy protection • Block protection Access protection • protection of confidential configuration data • Protection level: Write protection • Protection level: Read/write protection • Protection level: Write protection • Protection level: Complete protection programming / cycle time monitoring / header • lower limit • upper limit Dimensions	Yes; incl. failsafe Yes Yes Yes Yes Yes Yes Yes Yes Yes Ye
Programming language — LAD — FBD — STL — SCL — GRAPH Know-how protection • User program protection/password protection • Copy protection • Block protection Access protection • protection of confidential configuration data • Protection level: Write protection • Protection level: Read/write protection • Protection level: Write protection for Failsafe • Protection level: Complete protection programming / cycle time monitoring / header • lower limit • upper limit Dimensions Width	Yes; incl. failsafe Yes Yes Yes Yes Yes Yes Yes Yes Yes Ye
Programming language — LAD — FBD — STL — SCL — GRAPH Know-how protection • User program protection/password protection • Copy protection • Block protection Access protection • protection of confidential configuration data • Protection level: Write protection • Protection level: Read/write protection • Protection level: Write protection for Failsafe • Protection level: Complete protection programming / cycle time monitoring / header • lower limit • upper limit Dimensions Width Height	Yes; incl. failsafe Yes Yes Yes Yes Yes Yes Yes Yes Yes Ye
Programming language — LAD — FBD — STL — SCL — GRAPH Know-how protection • User program protection/password protection • Copy protection • Block protection Access protection • protection of confidential configuration data • Protection level: Write protection • Protection level: Read/write protection • Protection level: Write protection for Failsafe • Protection level: Complete protection programming / cycle time monitoring / header • lower limit • upper limit Dimensions Width Height Depth	Yes; incl. failsafe Yes Yes Yes Yes Yes Yes Yes Yes Yes Ye

last modified:

10/21/2023