## 6AG2511-1AK02-4AB0

**Data sheet** 



SIPLUS S7-1500 CPU 1511-1 PN TX rail based on 6ES7511-1AK02-0AB0 with conformal coating, -40...+70 °C, OT4 with ST1/2 (+85 °C for 10 minutes), heat sink, no PS usable, central processing unit without display with work memory 150 KB for program and 1 MB for data, 1st interface: PROFINET IRT with 2-port switch, 60 ns bit performance, SIMATIC Memory Card required

Figure similar

A 11 6 4	
General information	
Product type designation	CPU 1511-1 PN
Product function	
I&M data	Yes; I&M0 to I&M3
Isochronous mode	Yes; Distributed and central; with minimum OB $6x$ cycle of $625~\mu s$ (distributed) and 1 ms (central)
Engineering with	
STEP 7 TIA Portal configurable/integrated from version	see entry ID: 109746275
Configuration control	
via dataset	Yes
Display	
Screen diagonal [cm]	3.45 cm
Control elements	
Number of keys	8
Mode buttons	2
Supply voltage	
Rated value (DC)	24 V
permissible range, lower limit (DC)	19.2 V
permissible range, upper limit (DC)	28.8 V
Reverse polarity protection	Yes
Mains buffering	
<ul> <li>Mains/voltage failure stored energy time</li> </ul>	5 ms
Input current	
Current consumption (rated value)	0.7 A
Current consumption, max.	0.95 A
Inrush current, max.	1.9 A; Rated value
l²t	0.02 A²·s
Power	
Infeed power to the backplane bus	10 W
Power consumption from the backplane bus (balanced)	5.5 W
Power loss	
Power loss, typ.	5.7 W
Memory	
Number of slots for SIMATIC memory card	1
SIMATIC memory card required	Yes
Work memory	
• integrated (for program)	150 kbyte
• integrated (for data)	1 Mbyte
Load memory	

<ul> <li>Plug-in (SIMATIC Memory Card), max.</li> </ul>	32 Gbyte
Backup	,
maintenance-free	Yes
CPU processing times	
for bit operations, typ.	60 ns
for word operations, typ.	72 ns
for fixed point arithmetic, typ.	96 ns
for floating point arithmetic, typ.	384 ns
CPU-blocks	
Number of elements (total)	2 000; Blocks (OB, FB, FC, DB) and UDTs
DB	
Number range	1 60 999; subdivided into: number range that can be used by the user: 1 59 999, and number range of DBs created via SFC 86: 60 000 60 999
• Size, max.	1 Mbyte; For DBs with absolute addressing, the max. size is 64 KB
FB	
Number range	0 65 535
• Size, max.	150 kbyte
FC	
Number range	0 65 535
• Size, max.	150 kbyte
OB	
• Size, max.	150 kbyte
<ul> <li>Number of free cycle OBs</li> </ul>	100
<ul> <li>Number of time alarm OBs</li> </ul>	20
<ul> <li>Number of delay alarm OBs</li> </ul>	20
<ul> <li>Number of cyclic interrupt OBs</li> </ul>	20; With minimum OB 3x cycle of 500 μs
<ul> <li>Number of process alarm OBs</li> </ul>	50
<ul> <li>Number of DPV1 alarm OBs</li> </ul>	3
<ul> <li>Number of isochronous mode OBs</li> </ul>	2
<ul> <li>Number of technology synchronous alarm OBs</li> </ul>	2
Number of startup OBs	100
Number of asynchronous error OBs	4
Number of synchronous error OBs	2
Number of diagnostic alarm OBs	1
Nesting depth	
per priority class	24
Counters, timers and their retentivity	
S7 counter	
Number	2 048
Retentivity	
— adjustable	Yes
IEC counter	
Number	Any (only limited by the main memory)
Retentivity	
— adjustable	Yes
S7 times	
Number	2 048
Retentivity	
— adjustable	Yes
IEC timer	
Number	Any (only limited by the main memory)
Retentivity	
— adjustable	Yes
Data areas and their retentivity	
Retentive data area (incl. timers, counters, flags), max.	128 kbyte; In total; available retentive memory for bit memories, timers, counters, DBs, and technology data (axes): 88 KB
Flag	
• Size, max.	16 kbyte
Number of clock memories	8; 8 clock memory bit, grouped into one clock memory byte
Data blocks	-, I down memory and grouped into one clock memory byte
Retentivity adjustable	Yes
- Notomirity adjustable	

Retentivity preset	No
Local data	110
per priority class, max.	64 kbyte; max. 16 KB per block
Address area	
Number of IO modules	1 024; max. number of modules / submodules
I/O address area	
• Inputs	32 kbyte; All inputs are in the process image
Outputs	32 kbyte; All outputs are in the process image
per integrated IO subsystem	
— Inputs (volume)	8 kbyte
— Outputs (volume)	8 kbyte
per CM/CP	
— Inputs (volume)	8 kbyte
— Outputs (volume)	8 kbyte
Subprocess images	
<ul> <li>Number of subprocess images, max.</li> </ul>	32
Hardware configuration	
Number of distributed IO systems	32; A distributed I/O system is characterized not only by the integration of distributed I/O via PROFINET or PROFIBUS communication modules, but also by the connection of I/O via AS-i master modules or links (e.g. IE/PB-Link)
Number of DP masters	
• Via CM	4; A maximum of 4 CMs/CPs (PROFIBUS, PROFINET, Ethernet) can be inserted in total
Number of IO Controllers	
• integrated	1
• Via CM	4; A maximum of 4 CMs/CPs (PROFIBUS, PROFINET, Ethernet) can be inserted in total
Rack  Modulos por rack may	22: CPLL+ 24 modulos: no system negro symply (PC) and he wood
Modules per rack, max.  PtP CM	32; CPU + 31 modules; no system power supply (PS) can be used
Number of PtP CMs	the number of connectable PtP CMs is only limited by the number of available
• Number of tit Owis	slots
Time of day	
Clock	
• Type	Hardware clock
Backup time	6 wk; At 40 °C ambient temperature, typically
Deviation per day, max.	10 s; Typ.: 2 s
Operating hours counter	
Number	16
Clock synchronization	
• supported	Yes
<ul><li>supported</li><li>in AS, master</li></ul>	Yes
<ul><li>supported</li><li>in AS, master</li><li>in AS, slave</li></ul>	Yes Yes
<ul><li>supported</li><li>in AS, master</li><li>in AS, slave</li><li>on Ethernet via NTP</li></ul>	Yes
<ul> <li>supported</li> <li>in AS, master</li> <li>in AS, slave</li> <li>on Ethernet via NTP</li> </ul> Interfaces	Yes Yes Yes
<ul> <li>supported</li> <li>in AS, master</li> <li>in AS, slave</li> <li>on Ethernet via NTP</li> </ul> Interfaces Number of PROFINET interfaces	Yes Yes
supported     in AS, master     in AS, slave     on Ethernet via NTP  Interfaces  Number of PROFINET interfaces  1. Interface	Yes Yes Yes
supported     in AS, master     in AS, slave     on Ethernet via NTP  Interfaces  Number of PROFINET interfaces  1. Interface types	Yes Yes Yes 1
supported     in AS, master     in AS, slave     on Ethernet via NTP  Interfaces  Number of PROFINET interfaces  1. Interface types     RJ 45 (Ethernet)	Yes Yes Yes Yes  1  Yes; X1
<ul> <li>supported</li> <li>in AS, master</li> <li>in AS, slave</li> <li>on Ethernet via NTP</li> </ul> Interfaces Number of PROFINET interfaces 1. Interface Interface types <ul> <li>RJ 45 (Ethernet)</li> <li>Number of ports</li> </ul>	Yes Yes Yes Yes Yes X
supported     in AS, master     in AS, slave     on Ethernet via NTP  Interfaces  Number of PROFINET interfaces  1. Interface  Interface types     RJ 45 (Ethernet)     Number of ports     integrated switch	Yes Yes Yes Yes  1  Yes; X1
supported     in AS, master     in AS, slave     on Ethernet via NTP  Interfaces  Number of PROFINET interfaces  1. Interface Interface types     RJ 45 (Ethernet)     Number of ports     integrated switch  Protocols	Yes Yes Yes Yes  1  Yes; X1 2 Yes
supported     in AS, master     in AS, slave     on Ethernet via NTP  Interfaces  Number of PROFINET interfaces  1. Interface Interface types     RJ 45 (Ethernet)     Number of ports     integrated switch  Protocols     IP protocol	Yes Yes Yes  1  Yes; X1 2 Yes Yes
supported     in AS, master     in AS, slave     on Ethernet via NTP  Interfaces  Number of PROFINET interfaces  1. Interface  Interface types     RJ 45 (Ethernet)     Number of ports     integrated switch  Protocols     IP protocol     PROFINET IO Controller	Yes Yes Yes  1  Yes; X1 2 Yes Yes  Yes; IPv4 Yes
supported     in AS, master     in AS, slave     on Ethernet via NTP  Interfaces  Number of PROFINET interfaces  1. Interface  Interface types     RJ 45 (Ethernet)     Number of ports     integrated switch  Protocols     IP protocol     PROFINET IO Controller     PROFINET IO Device	Yes Yes Yes  1  Yes; X1 2 Yes Yes  Yes  Yes  Yes  Yes
supported     in AS, master     in AS, slave     on Ethernet via NTP  Interfaces  Number of PROFINET interfaces  1. Interface  Interface types     RJ 45 (Ethernet)     Number of ports     integrated switch  Protocols      IP protocol     PROFINET IO Controller     PROFINET IO Device     SIMATIC communication	Yes Yes Yes  1  Yes; X1 2 Yes  Yes  Yes  Yes  Yes  Yes  Yes  Ye
supported     in AS, master     in AS, slave     on Ethernet via NTP  Interfaces  Number of PROFINET interfaces  1. Interface  Interface types     RJ 45 (Ethernet)     Number of ports     integrated switch  Protocols      IP protocol     PROFINET IO Controller     PROFINET IO Device     SIMATIC communication     Open IE communication	Yes Yes Yes  1  Yes; X1 2 Yes  Yes  Yes  Yes  Yes  Yes  Yes  Ye
supported     in AS, master     in AS, slave     on Ethernet via NTP  Interfaces  Number of PROFINET interfaces  1. Interface Interface types     RJ 45 (Ethernet)     Number of ports     integrated switch  Protocols     IP protocol     PROFINET IO Controller     PROFINET IO Device     SIMATIC communication     Open IE communication     Web server	Yes Yes Yes  1  Yes; X1 2 Yes Yes  Yes Yes  Yes Yes Yes Yes Yes Y
supported     in AS, master     in AS, slave     on Ethernet via NTP  Interfaces  Number of PROFINET interfaces  1. Interface Interface types     RJ 45 (Ethernet)     Number of ports     integrated switch  Protocols     IP protocol     PROFINET IO Controller     PROFINET IO Device     SIMATIC communication     Open IE communication     Web server     Media redundancy	Yes Yes Yes  1  Yes; X1 2 Yes  Yes  Yes  Yes  Yes  Yes  Yes  Ye
supported     in AS, master     in AS, slave     on Ethernet via NTP  Interfaces  Number of PROFINET interfaces  1. Interface Interface types     RJ 45 (Ethernet)     Number of ports     integrated switch  Protocols     IP protocol     PROFINET IO Controller     PROFINET IO Device     SIMATIC communication     Open IE communication     Web server	Yes Yes Yes  1  Yes; X1 2 Yes Yes  Yes Yes  Yes Yes Yes Yes Yes Y
supported     in AS, master     in AS, slave     on Ethernet via NTP  Interfaces  Number of PROFINET interfaces  1. Interface  Interface types     RJ 45 (Ethernet)     Number of ports     integrated switch  Protocols      IP protocol     PROFINET IO Controller     PROFINET IO Device     SIMATIC communication     Open IE communication     Web server     Media redundancy  PROFINET IO Controller	Yes Yes Yes  1  Yes; X1 2 Yes Yes  Yes Yes  Yes Yes Yes Yes Yes Y

lanahanna	Voc
— Isochronous mode	Yes
Direct data exchange	Yes; Requirement: IRT and isochronous mode (MRPD optional)
— IRT	Yes
— PROFlenergy	Yes; per user program
<ul><li>— Prioritized startup</li></ul>	Yes; Max. 32 PROFINET devices
<ul> <li>Number of connectable IO Devices, max.</li> </ul>	128; In total, up to 256 distributed I/O devices can be connected via AS-i, PROFIBUS or PROFINET
<ul> <li>Of which IO devices with IRT, max.</li> </ul>	64
<ul> <li>Number of connectable IO Devices for RT, max.</li> </ul>	128
— of which in line, max.	128
<ul> <li>Number of IO Devices that can be simultaneously activated/deactivated, max.</li> </ul>	8; in total across all interfaces
<ul> <li>Number of IO Devices per tool, max.</li> </ul>	8
— Updating times	The minimum value of the update time also depends on communication share set for PROFINET IO, on the number of IO devices, and on the quantity of configured user data
Update time for IRT	
— for send cycle of 250 μs	250 $\mu s$ to 4 ms; Note: In the case of IRT with isochronous mode, the minimum update time of 625 $\mu s$ of the isochronous OB is decisive
— for send cycle of 500 μs	500 $\mu s$ to 8 ms; Note: In the case of IRT with isochronous mode, the minimum update time of 625 $\mu s$ of the isochronous OB is decisive
— for send cycle of 1 ms	1 ms to 16 ms
— for send cycle of 2 ms	2 ms to 32 ms
— for send cycle of 4 ms	4 ms to 64 ms
With IRT and parameterization of "odd" send cycles	Update time = set "odd" send clock (any multiple of 125 $\mu$ s: 375 $\mu$ s, 625 $\mu$ s 3 875 $\mu$ s)
Update time for RT	
— for send cycle of 250 μs	250 μs to 128 ms
— for send cycle of 500 μs	500 μs to 256 ms
— for send cycle of 1 ms	1 ms to 512 ms
— for send cycle of 2 ms	2 ms to 512 ms
— for send cycle of 4 ms	4 ms to 512 ms
PROFINET IO Device	
Services	
— PG/OP communication	Yes
— Isochronous mode	No
— IRT	Yes
— PROFleneray	Yes; per user program
— Shared device	Yes
Number of IO Controllers with shared device, max.	4
Asset management record	Yes; per user program
Interface types	roo, por acor program
RJ 45 (Ethernet)	
	Von
• 100 Mbps	Yes
Autoregotiation     Autorogoing	Yes
Autocrossing     Industrial Ethornot status LED	Yes
Industrial Ethernet status LED	Yes
Protocols	
PROFIsafe	No
Number of connections	
Number of connections, max.	96; via integrated interfaces of the CPU and connected CPs / CMs
Number of connections reserved for ES/HMI/web	10
Number of connections via integrated interfaces	64
Number of S7 routing paths	16
Redundancy mode	
H-Sync forwarding	Yes
Media redundancy	
— MRP	Yes; as MRP redundancy manager and/or MRP client; max. number of devices in the ring: 50
— MRPD	Yes; Requirement: IRT
<ul> <li>Switchover time on line break, typ.</li> </ul>	200 ms; For MRP, bumpless for MRPD
— Number of stations in the ring, max.	50
SIMATIC communication	

07	V
• S7 routing	Yes
S7 communication, as server     S7 communication, as client	Yes Yes
S7 communication, as client      User data per job, may	
User data per job, max.  Open IE communication	See online help (S7 communication, user data size)
• TCP/IP	Yes
— Data length, max.	64 kbyte
several passive connections per port, supported	Yes
• ISO-on-TCP (RFC1006)	Yes
— Data length, max.	64 kbyte
• UDP	Yes
— Data length, max.	2 kbyte; 1 472 bytes for UDP broadcast
— UDP multicast	Yes; Max. 5 multicast circuits
• DHCP	No
• SNMP	Yes
• DCP	Yes
• LLDP	Yes
Web server	
• HTTP	Yes; Standard and user pages
• HTTPS	Yes; Standard and user pages
OPC UA	
Runtime license required	Yes
OPC UA Client	Yes
<ul> <li>Application authentication</li> </ul>	Yes
— Security policies	Available security policies: None, Basic128Rsa15, Basic256Rsa15, Basic256Sha256
<ul> <li>User authentication</li> </ul>	"anonymous" or by user name & password
<ul><li>Number of connections, max.</li></ul>	4
<ul> <li>Number of nodes of the client interfaces, recommended max.</li> </ul>	1 000
<ul> <li>Number of elements for one call of OPC_UA_NodeGetHandleList/OPC_UA_ReadList/OPC_I max.</li> </ul>	300
<ul> <li>Number of elements for one call of OPC_UA_NameSpaceGetIndexList, max.</li> </ul>	20
<ul> <li>Number of elements for one call of OPC_UA_MethodGetHandleList, max.</li> </ul>	100
<ul> <li>Number of simultaneous calls of the client instructions for session management, per connection, max.</li> </ul>	1
<ul> <li>Number of simultaneous calls of the client instructions for data access, per connection, max.</li> </ul>	5
<ul> <li>Number of registerable nodes, max.</li> </ul>	5 000
<ul> <li>Number of registerable method calls of OPC_UA_MethodCall, max.</li> </ul>	100
<ul> <li>Number of inputs/outputs when calling OPC_UA_MethodCall, max.</li> </ul>	20
OPC UA Server	Yes; Data access (read, write, subscribe), method call, custom address space
<ul> <li>Application authentication</li> </ul>	Yes
— Security policies	Available security policies: None, Basic128Rsa15, Basic256Rsa15, Basic256Sha256
<ul> <li>User authentication</li> </ul>	"anonymous" or by user name & password
<ul><li>— Number of sessions, max.</li></ul>	32
<ul> <li>Number of accessible variables, max.</li> </ul>	50 000
Number of registerable nodes, max.	10 000
Number of subscriptions per session, max.	20
— Sampling interval, min.	100 ms
— Publishing interval, min.	500 ms
Number of server methods, max.	20
Number of inputs/outputs per server method, max.	
Number of monitored items, recommended max.	1 000; for 1 s sampling interval and 1 s send interval
Number of server interfaces, max.	10
<ul> <li>Number of nodes for user-defined server interfaces, max.</li> </ul>	1 000
Further protocols	

• MODBUS	Yes; MODBUS TCP
S7 message functions	
Number of login stations for message functions, max.	32
Program alarms	Yes
Number of configurable program messages, max.	5 000; Program messages are generated by the "Program_Alarm" block, ProDiag or GRAPH
Number of loadable program messages in RUN, max.	2 500
Number of simultaneously active program alarms	
Number of program alarms	300
<ul> <li>Number of alarms for system diagnostics</li> </ul>	100
<ul> <li>Number of alarms for motion technology objects</li> </ul>	80
Test commissioning functions	
Joint commission (Team Engineering)	Yes; Parallel online access possible for up to 5 engineering systems
Status block	Yes; Up to 8 simultaneously (in total across all ES clients)
Single step	No
Number of breakpoints	8
Status/control	
Status/control variable	Yes
Variables	Inputs/outputs, memory bits, DBs, distributed I/Os, timers, counters
<ul> <li>Number of variables, max.</li> </ul>	
— of which status variables, max.	200; per job
— of which control variables, max.	200; per job
Forcing	
• Forcing, variables	Peripheral inputs/outputs
Number of variables, max.	200
Diagnostic buffer	V
• present	Yes
Number of entries, max.	1 000
— of which powerfail-proof	500
Traces	4: Up to 512 KB of data per trace are possible
Number of configurable Traces  Interrupts/diagnostics/status information	4; Up to 512 KB of data per trace are possible
Diagnostics indication LED	
RUN/STOP LED	Yes
• ERROR LED	Yes
• MAINT LED	Yes
STOP ACTIVE LED	Yes
Connection display LINK TX/RX	Yes
Supported technology objects	
Motion Control	Yes; Note: The number of axes affects the cycle time of the PLC program;
	selection guide via the TIA Selection Tool or SIZER
<ul> <li>Number of available Motion Control resources for technology objects</li> </ul>	800
<ul> <li>Required Motion Control resources</li> </ul>	
— per speed-controlled axis	40
— per positioning axis	80
— per synchronous axis	160
— per external encoder	80
— per output cam	20
— per cam track	160
— per probe	40
Positioning axis	
Number of positioning axes at motion control cycle of 4 ms (typical value)  Number of positioning axes at motion control cycle.	5
	5 10
of 4 ms (typical value)  — Number of positioning axes at motion control cycle	10
of 4 ms (typical value)  — Number of positioning axes at motion control cycle of 8 ms (typical value)  Controller  • PID_Compact	Yes; Universal PID controller with integrated optimization
of 4 ms (typical value)  — Number of positioning axes at motion control cycle of 8 ms (typical value)  Controller  • PID_Compact • PID_3Step	Yes; Universal PID controller with integrated optimization Yes; PID controller with integrated optimization for valves
of 4 ms (typical value)  — Number of positioning axes at motion control cycle of 8 ms (typical value)  Controller  • PID_Compact  • PID_3Step  • PID-Temp	10 Yes; Universal PID controller with integrated optimization
of 4 ms (typical value)  — Number of positioning axes at motion control cycle of 8 ms (typical value)  Controller  • PID_Compact • PID_3Step	Yes; Universal PID controller with integrated optimization Yes; PID controller with integrated optimization for valves

solation	
Isolation tested with	750 V DC (type test) and according to EN 50155 (routine test)
Standards, approvals, certificates	
Railway application	
• EN 50121-3-2	Yes; EMC for rail vehicles
● EN 50121-4	Yes; EMC for signal and telecommunications systems
● EN 50124-1	Yes; Railway applications - overvoltage category OV2; pollution degree PD2; rated surge voltage UNi = 0.5 kV; UNm = 24 V DC
• EN 50125-1	Yes; Rail vehicles - see ambient conditions
• EN 50125-2	Yes; Stationary electrical equipment - see ambient conditions
• EN 50125-3	Yes; Signal and telecommunications systems - see ambient conditions; vibrations and shocks: Application point outside of tracks (1 m to 3 m away from track)
• EN 50155	Yes; Rail vehicles - temperature class OT4, ST1/ST2, horizontal mounting position
• EN 61373	Yes; Rail vehicles - vibrations and shocks: Category 1 Class A/B
• Fire protection acc. to EN 45545-2	Yes; For proof of conformity, see Service & Support
Imbient conditions	
Ambient temperature during operation	
horizontal installation, min.	-40 °C; = Tmin (incl. condensation/frost)
horizontal installation, max.	70 °C; = Tmax; +85 °C for 10 min (OT4, ST1/ST2 acc. to EN 50155); display: 50 °C, the display is switched off at an operating temperature of typically 50 °C
vertical installation, min.	-40 °C; = Tmin  40 °C; = Tmov, display: 40 °C, et an apparating temporature of twicelly 40 °C.
vertical installation, max.	40 °C; = Tmax; display: 40 °C, at an operating temperature of typically 40 °C, the display is switched off
Ambient temperature during storage/transportation	
• min.	-40 °C
• max.	70 °C
Altitude during operation relating to sea level	
<ul> <li>Installation altitude above sea level, max.</li> </ul>	2 000 m
Ambient air temperature-barometric pressure-altitude	Tmin Tmax at 1 140 hPa 795 hPa (-1 000 m +2 000 m)
Relative humidity	
With condensation, tested in accordance with IEC 60068- 2-38, max.	100 %; RH incl. condensation / frost (no commissioning in bedewed state), horizontal installation
Resistance	
Coolants and lubricants	
<ul> <li>Resistant to commercially available coolants and lubricants</li> </ul>	Yes; Incl. diesel and oil droplets in the air
Use in stationary industrial systems	
<ul> <li>— to biologically active substances according to EN 60721-3-3</li> </ul>	Yes; Class 3B2 mold, fungus and dry rot spores (with the exception of fauna); Class 3B3 on request
<ul> <li>to chemically active substances according to EN 60721-3-3</li> </ul>	Yes; Class 3C4 (RH < 75 %) incl. salt spray acc. to EN 60068-2-52 (severity degree 3); $^{\star}$
<ul> <li>to mechanically active substances according to EN 60721-3-3</li> </ul>	Yes; Class 3S4 incl. sand, dust, *
Use on land craft, rail vehicles and special-purpose vehicles	
— to biologically active substances according to EN 60721-3-5	Yes; Class 5B2 mold, fungus and dry rot spores (with the exception of fauna); Class 5B3 on request
— to chemically active substances according to EN 60721-3-5	Yes; Class 5C3 (RH < 75 %) incl. salt spray acc. to EN 60068-2-52 (severity degree 3); *
— to mechanically active substances according to EN 60721-3-5	Yes; Class 5S3 incl. sand, dust; *
Usage in industrial process technology	Vary Olara O (avaluation trial to 1)
— Against chemically active substances acc. to EN 60654-4  Environmental conditions for present measuring.	Yes; Class 3 (excluding trichlorethylene)
<ul> <li>Environmental conditions for process, measuring and control systems acc. to ANSI/ISA-71.04</li> </ul>	Yes; Level GX group A/B (excluding trichlorethylene; harmful gas concentrations up to the limits of EN 60721-3-3 class 3C4 permissible); level LC3 (salt spray) and level LB3 (oil)
Remark	
<ul> <li>Note regarding classification of environmental conditions acc. to EN 60721, EN 60654-4 and ANSI/ISA-71.04</li> </ul>	* The supplied plug covers must remain in place over the unused interfaces during operation!
Conformal coating	
<ul> <li>Coatings for printed circuit board assemblies acc. to EN 61086</li> </ul>	Yes; Class 2 for high reliability
<ul> <li>Protection against fouling acc. to EN 60664-3</li> </ul>	Yes; Type 1 protection
<ul> <li>Electronic equipment on rolling stock acc. to EN 50155</li> </ul>	Yes: Class PC2 protective coating acc. to EN 50155:2017

• Military testing according to MIL-I-46058C, Amendment 7

 Qualification and Performance of Electrical Insulating Compound for Printed Board Assemblies according to IPC-CC-830A Yes; Discoloration of coating possible during service life

Yes; Conformal coating, Class A

configuration / header	
configuration / programming / header	
Programming language	
— LAD	Yes
— FBD	Yes
— STL	Yes
— SCL	Yes
— GRAPH	Yes
Know-how protection	
<ul> <li>User program protection/password protection</li> </ul>	Yes
<ul> <li>Copy protection</li> </ul>	Yes
Block protection	Yes
Access protection	
<ul> <li>Password for display</li> </ul>	Yes
<ul> <li>Protection level: Write protection</li> </ul>	Yes
<ul> <li>Protection level: Read/write protection</li> </ul>	Yes
Protection level: Complete protection	Yes
programming / cycle time monitoring / header	
<ul> <li>lower limit</li> </ul>	adjustable minimum cycle time
• upper limit	adjustable maximum cycle time
Dimensions	
Width	70 mm
Height	147 mm
Depth	129 mm
Weights	
Weight, approx.	590 g
Other	
Note:	for use in railway applications, also observe the product information "SIPLUS extreme RAIL" A5E37661960A, Online Support article 109736776

last modified:

4/25/2024