## **SIEMENS**

## **Data sheet**



SIPLUS ET 200SP CPU 1512SP-1 PN rail based on 6ES7512-1DK01-0AB0 with conformal coating, -40...+60 °C, OT2 with ST1/2 (+70 °C für 10 minutes), central processing unit with work memory 200 KB for program and 1 MB for data, 1st interface, PROFINET IRT with 3-port switch, 48 ns bit performance, SIMATIC Memory Card required, BusAdapter required for port 1 and 2

Figure similar

General information	
Product type designation	CPU 1512SP-1 PN
Product function	
<ul><li>I&amp;M data</li></ul>	Yes; I&M0 to I&M3
<ul> <li>Module swapping during operation (hot swapping)</li> </ul>	Yes; Multi-hot swapping
Isochronous mode	Yes; Only with PROFINET; with minimum OB 6x cycle of 625 µs
Engineering with	
<ul> <li>STEP 7 TIA Portal configurable/integrated from version</li> </ul>	see entry ID: 109746275
Configuration control	
via dataset	Yes
Control elements	
Mode selector switch	1
Supply voltage	
Rated value (DC)	24 V
permissible range, lower limit (DC)	19.2 V
permissible range, upper limit (DC)	28.8 V
Reverse polarity protection	Yes
Mains buffering	
<ul> <li>Mains/voltage failure stored energy time</li> </ul>	5 ms
Input current	
Current consumption (rated value)	0.6 A
Current consumption, max.	0.9 A
Inrush current, max.	4.7 A; Rated value
l²t	0.14 A <sup>2</sup> ·s
Power	
Infeed power to the backplane bus	8.75 W
Power loss	
Power loss, typ.	5.6 W
Memory	
Number of slots for SIMATIC memory card	1
SIMATIC memory card required	Yes
Work memory	
<ul><li>integrated (for program)</li></ul>	200 kbyte
integrated (for data)	1 Mbyte
Load memory	
<ul> <li>Plug-in (SIMATIC Memory Card), max.</li> </ul>	32 Gbyte
Backup	
<ul> <li>maintenance-free</li> </ul>	Yes

CPU processing times	
for bit operations, typ.	48 ns
for word operations, typ.	58 ns
for fixed point arithmetic, typ.	77 ns
for floating point arithmetic, typ.	307 ns
CPU-blocks	001 113
Number of elements (total)	4 000; Blocks (OB, FB, FC, DB) and UDTs
DB	4 000, Blocks (OB, 1 B, 1 O, BB) and OB 13
Number range	1 60 999; subdivided into: number range that can be used by the user: 1 59 999, and number range of DBs created via SFC 86: 60 000 60 999
• Size, max.	1 Mbyte; For DBs with absolute addressing, the max. size is 64 KB
Number range	0 65 535
• Size, max.	200 kbyte
FC	200 10310
Number range	0 65 535
• Size, max.	200 kbyte
OB	
• Size, max.	200 kbyte
<ul> <li>Number of free cycle OBs</li> </ul>	100
<ul> <li>Number of time alarm OBs</li> </ul>	20
<ul> <li>Number of delay alarm OBs</li> </ul>	20
<ul> <li>Number of cyclic interrupt OBs</li> </ul>	20; With minimum OB 3x cycle of 500 μs
<ul> <li>Number of process alarm OBs</li> </ul>	50
<ul> <li>Number of DPV1 alarm OBs</li> </ul>	3
<ul> <li>Number of isochronous mode OBs</li> </ul>	1
<ul> <li>Number of technology synchronous alarm OBs</li> </ul>	2
<ul> <li>Number of startup OBs</li> </ul>	100
<ul> <li>Number of asynchronous error OBs</li> </ul>	4
<ul> <li>Number of synchronous error OBs</li> </ul>	2
Number of diagnostic alarm OBs	1
Nesting depth	
per priority class	24
Counters, timers and their retentivity	
S7 counter	
Number	2 048
Retentivity	
— adjustable	Yes
IEC counter	
Number	Any (only limited by the main memory)
Retentivity	
— adjustable	Yes
S7 times	0.010
• Number	2 048
Retentivity	V
— adjustable	Yes
IEC timer	
• Number	Any (only limited by the main memory)
Retentivity	V
— adjustable	Yes
Data areas and their retentivity	
Retentive data area (incl. timers, counters, flags), max.	128 kbyte; Available retentive memory for bit memories, timers, counters, DBs, and technology data (axes): 88 KB
Flag	
• Size, max.	16 kbyte
<u> </u>	16 kbyte 8; 8 clock memory bit, grouped into one clock memory byte
• Size, max.	
<ul><li>Size, max.</li><li>Number of clock memories</li></ul>	
<ul><li>Size, max.</li><li>Number of clock memories</li><li>Data blocks</li></ul>	8; 8 clock memory bit, grouped into one clock memory byte
<ul> <li>Size, max.</li> <li>Number of clock memories</li> <li>Data blocks</li> <li>Retentivity adjustable</li> </ul>	8; 8 clock memory bit, grouped into one clock memory byte  Yes
<ul> <li>Size, max.</li> <li>Number of clock memories</li> <li>Data blocks</li> <li>Retentivity adjustable</li> <li>Retentivity preset</li> </ul>	8; 8 clock memory bit, grouped into one clock memory byte  Yes
<ul> <li>Size, max.</li> <li>Number of clock memories</li> <li>Data blocks</li> <li>Retentivity adjustable</li> <li>Retentivity preset</li> <li>Local data</li> </ul>	8; 8 clock memory bit, grouped into one clock memory byte  Yes No

Number of IO modules	2 048; max. number of modules / submodules
I/O address area	
• Inputs	32 kbyte; All inputs are in the process image
Outputs	32 kbyte; All imputs are in the process image
per integrated IO subsystem	22 Jto, 7 iii odipato di o iii tilo proceso iiilago
— Inputs (volume)	8 kbyte
— Inputs (volume)  — Outputs (volume)	8 kbyte
per CM/CP	O KDYIC
·	9 khuto
— Inputs (volume)	8 kbyte
— Outputs (volume)	8 kbyte
Subprocess images	00
Number of subprocess images, max.	32
Address space per module	
Address space per module, max.	288 byte; For input and output data respectively
Address space per station	
Address space per station, max.	2 560 byte; for central inputs and outputs; depending on configuration; 2 048 bytes for ET 200SP modules + 512 bytes for ET 200AL modules
Hardware configuration	
Number of distributed IO systems	32; A distributed I/O system is characterized not only by the integration of distributed I/O via PROFINET or PROFIBUS communication modules, but also by the connection of I/O via AS-i master modules or links (e.g. IE/PB-Link)
Number of DP masters	
• Via CM	1
Number of IO Controllers	
integrated	1
• Via CM	0
Rack	
Modules per rack, max.	80; CPU + 64 modules + server module (mounting width max. 1 m) + 16 ET 200AL modules
<ul> <li>Quantity of operable ET 200SP modules, max.</li> </ul>	64
Quantity of operable ET 200AL modules, max.	16
Number of lines, max.	1
PtP CM	
Number of PtP CMs	the number of connectable PtP CMs is only limited by the number of
	available slots
Time of day	
Clock	
• Type	Hardware clock
Backup time	6 wk; At 40 °C ambient temperature, typically
Deviation per day, max.	10 s; Typ.: 2 s
Operating hours counter	10 0, 1 μμ 2 σ
Number	16
	16
Clock synchronization	
- accompanie d	Voc
• supported	Yes
• to DP, master	Yes; Via CM DP module
<ul><li>to DP, master</li><li>to DP, slave</li></ul>	Yes; Via CM DP module Yes; Via CM DP module
<ul><li>to DP, master</li><li>to DP, slave</li><li>in AS, master</li></ul>	Yes; Via CM DP module Yes; Via CM DP module Yes
<ul> <li>to DP, master</li> <li>to DP, slave</li> <li>in AS, master</li> <li>in AS, slave</li> </ul>	Yes; Via CM DP module Yes; Via CM DP module Yes Yes
<ul><li>to DP, master</li><li>to DP, slave</li><li>in AS, master</li></ul>	Yes; Via CM DP module Yes; Via CM DP module Yes
<ul> <li>to DP, master</li> <li>to DP, slave</li> <li>in AS, master</li> <li>in AS, slave</li> </ul>	Yes; Via CM DP module Yes; Via CM DP module Yes Yes
<ul> <li>to DP, master</li> <li>to DP, slave</li> <li>in AS, master</li> <li>in AS, slave</li> <li>on Ethernet via NTP</li> </ul>	Yes; Via CM DP module Yes; Via CM DP module Yes Yes
<ul> <li>to DP, master</li> <li>to DP, slave</li> <li>in AS, master</li> <li>in AS, slave</li> <li>on Ethernet via NTP</li> </ul> Interfaces Number of PROFINET interfaces	Yes; Via CM DP module Yes; Via CM DP module Yes Yes Yes Yes
to DP, master     to DP, slave     in AS, master     in AS, slave     on Ethernet via NTP  Interfaces  Number of PROFINET interfaces  Number of PROFIBUS interfaces	Yes; Via CM DP module Yes; Via CM DP module Yes Yes Yes Yes 1 1; Via CM DP module
to DP, master     to DP, slave     in AS, master     in AS, slave     on Ethernet via NTP  Interfaces  Number of PROFIBUT interfaces  Number of PROFIBUS interfaces  Optical interface	Yes; Via CM DP module Yes; Via CM DP module Yes Yes Yes Yes
to DP, master     to DP, slave     in AS, master     in AS, slave     on Ethernet via NTP  Interfaces  Number of PROFINET interfaces Number of PROFIBUS interfaces Optical interface  1. Interface	Yes; Via CM DP module Yes; Via CM DP module Yes Yes Yes Yes 1 1; Via CM DP module
to DP, master     to DP, slave     in AS, master     in AS, slave     on Ethernet via NTP  Interfaces  Number of PROFINET interfaces Number of PROFIBUS interfaces Optical interface  Interface types	Yes; Via CM DP module Yes; Via CM DP module Yes Yes Yes Yes Yes  1 1; Via CM DP module Yes; via BusAdapter
to DP, master     to DP, slave     in AS, master     in AS, slave     on Ethernet via NTP  Interfaces  Number of PROFINET interfaces Number of PROFIBUS interfaces Optical interface  1. Interface Interface types     RJ 45 (Ethernet)	Yes; Via CM DP module Yes; Via CM DP module Yes Yes Yes Yes  1 1; Via CM DP module Yes; via BusAdapter  Yes; X1 P3; opt. X1 P1 and X1 P2 via BusAdapter BA 2x RJ45
to DP, master     to DP, slave     in AS, master     in AS, slave     on Ethernet via NTP  Interfaces  Number of PROFINET interfaces Number of PROFIBUS interfaces Optical interface  Interface types	Yes; Via CM DP module Yes; Via CM DP module Yes Yes Yes Yes Yes  1 1; Via CM DP module Yes; via BusAdapter
to DP, master     to DP, slave     in AS, master     in AS, slave     on Ethernet via NTP  Interfaces  Number of PROFINET interfaces Number of PROFIBUS interfaces Optical interface  1. Interface Interface types     RJ 45 (Ethernet)	Yes; Via CM DP module Yes; Via CM DP module Yes Yes Yes Yes  1 1; Via CM DP module Yes; via BusAdapter  Yes; X1 P3; opt. X1 P1 and X1 P2 via BusAdapter BA 2x RJ45
to DP, master     to DP, slave     in AS, master     in AS, slave     on Ethernet via NTP  Interfaces  Number of PROFINET interfaces Number of PROFIBUS interfaces Optical interface  1. Interface Interface types     RJ 45 (Ethernet)     Number of ports	Yes; Via CM DP module Yes; Via CM DP module Yes Yes Yes Yes  1 1; Via CM DP module Yes; via BusAdapter  Yes; Via BusAdapter  Yes; X1 P3; opt. X1 P1 and X1 P2 via BusAdapter BA 2x RJ45 3; 1. integr. + 2. via BusAdapter
<ul> <li>to DP, master</li> <li>to DP, slave</li> <li>in AS, master</li> <li>in AS, slave</li> <li>on Ethernet via NTP</li> </ul> Interfaces Number of PROFINET interfaces Number of PROFIBUS interfaces Optical interface 1. Interface Interface types <ul> <li>RJ 45 (Ethernet)</li> <li>Number of ports</li> <li>integrated switch</li> </ul>	Yes; Via CM DP module Yes Yes Yes Yes Yes Yes  1 1; Via CM DP module Yes; via BusAdapter  Yes; via BusAdapter  Yes; X1 P3; opt. X1 P1 and X1 P2 via BusAdapter BA 2x RJ45 3; 1. integr. + 2. via BusAdapter Yes Yes; compatible BusAdapters: BA 2x RJ45, BA 2x M12, BA 2x FC, BA 2x LC, BA LC/RJ45, BA LC/FC, BA 2x SCRJ, BA SCRJ/RJ45, BA

<ul> <li>PROFINET IO Controller</li> </ul>	Yes
<ul> <li>PROFINET IO Device</li> </ul>	Yes
<ul> <li>SIMATIC communication</li> </ul>	Yes
<ul> <li>Open IE communication</li> </ul>	Yes; Optionally also encrypted
<ul> <li>Web server</li> </ul>	Yes
Media redundancy	Yes; MRP Automanager according to IEC 62439-2 Edition 2.0
PROFINET IO Controller	
Services	
— PG/OP communication	Yes
— Isochronous mode	Yes
<ul> <li>Direct data exchange</li> </ul>	Yes; Requirement: IRT and isochronous mode (MRPD optional)
— IRT	Yes
— PROFlenergy	Yes; per user program
Prioritized startup	Yes; Max. 32 PROFINET devices
·	
Number of connectable IO Devices, max.	128; In total, up to 512 distributed I/O devices can be connected via AS-i, PROFIBUS or PROFINET
— Of which IO devices with IRT, max.	64
<ul> <li>Number of connectable IO Devices for RT,</li> </ul>	128
max.	
— of which in line, max.	128
Number of IO Devices that can be	8; in total across all interfaces
simultaneously activated/deactivated, max.	
Number of IO Devices per tool, max.	8
— Updating times	The minimum value of the update time also depends on communication share set for PROFINET IO, on the number of IO devices, and on the quantity of configured user data
Update time for IRT	
— for send cycle of 250 μs	250 μs to 4 ms; Note: In the case of IRT with isochronous mode, the minimum update time of 500 μs of the isochronous OB is decisive
— for send cycle of 500 μs	500 μs to 8 ms
— for send cycle of 1 ms	1 ms to 16 ms
— for send cycle of 1 ms — for send cycle of 2 ms	2 ms to 32 ms
— for send cycle of 4 ms	4 ms to 64 ms
<ul> <li>With IRT and parameterization of "odd" send cycles</li> </ul>	Update time = set "odd" send clock (any multiple of 125 μs: 375 μs, 625 μs 3 875 μs)
Update time for RT	μο ο οτο μο)
— for send cycle of 250 μs	250 μs to 128 ms
— for send cycle of 200 µs  — for send cycle of 500 µs	500 µs to 256 ms
•	·
— for send cycle of 1 ms	1 ms to 512 ms
— for send cycle of 2 ms	2 ms to 512 ms
— for send cycle of 4 ms	4 ms to 512 ms
PROFINET IO Device	
Services	
— PG/OP communication	Yes
— Isochronous mode	No
— IRT	Yes
— PROFlenergy	Yes; per user program
<ul> <li>Shared device</li> </ul>	Yes
<ul> <li>Number of IO Controllers with shared device,</li> </ul>	4
max.	
<ul> <li>activation/deactivation of I-devices</li> </ul>	Yes; per user program
Asset management record	Yes; per user program
2. Interface	
Interface types	
• RS 485	Yes; Via CM DP module
<ul> <li>Number of ports</li> </ul>	1
Protocols	
PROFIBUS DP master	Yes
PROFIBUS DP slave	Yes
SIMATIC communication	Yes
PROFIBUS DP master	
Number of connections, max.	48; Of which 4 each reserved for ES and HMI
Number of DP slaves, max.	125; In total, up to 512 distributed I/O devices can be connected via AS-
Framosi of Dr. Slavos, max.	i, PROFIBUS or PROFINET
Services	

B0/0B	v.
— PG/OP communication	Yes
— Equidistance	No
— Isochronous mode	No
Activation/deactivation of DP slaves	Yes
Interface types	
RJ 45 (Ethernet)	
• 100 Mbps	Yes
Autonegotiation	Yes
Autocrossing     Autocrossing	Yes
Industrial Ethernet status LED  RS 485	Yes
Transmission rate, max.	12 Mbit/s
Protocols	12 IVIDIUS
	Na
PROFIsafe  Number of connections	No
Number of connections, max.	128; via integrated interfaces of the CPU and connected CPs / CMs
Number of connections, max.     Number of connections reserved for ES/HMI/web	10
Number of connections via integrated interfaces	88
Number of connections via integrated interfaces     Number of connections per CP/CM	32
Number of S7 routing paths	16
Redundancy mode	
H-Sync forwarding	Yes
Media redundancy	
— Media redundancy	Yes; only via BusAdapter
— MRP	Yes; MRP Automanager according to IEC 62439-2 Edition 2.0, MRP
	Manager; MRP Client
MRP interconnection, supported	Yes; as MRP ring node according to IEC 62439-2 Edition 3.0
— MRPD	Yes; Requirement: IRT
— Switchover time on line break, typ.	200 ms; For MRP, bumpless for MRPD
— Number of stations in the ring, max.	50
SIMATIC communication  • PG/OP communication	Vacuation with TLC V/1.2 pro-palested
• S7 routing	Yes; encryption with TLS V1.3 pre-selected Yes
Data record routing	Yes
S7 communication, as server	Yes
S7 communication, as client	Yes
User data per job, max.	See online help (S7 communication, user data size)
Open IE communication	
• TCP/IP	Yes
— Data length, max.	64 kbyte
<ul> <li>several passive connections per port,</li> </ul>	Yes
supported	
• ISO-on-TCP (RFC1006)	Yes
— Data length, max.	64 kbyte
• UDP	Yes
— Data length, max.	2 kbyte; 1 472 bytes for UDP broadcast
<ul><li>— UDP multicast</li><li>◆ DHCP</li></ul>	Yes; Max. 5 multicast circuits Yes
• DNS	Yes
• SNMP	Yes
• DCP	Yes
• LLDP	Yes
• Encryption	Yes; Optional
Web server	
• HTTP	Yes; Standard and user pages
• HTTPS	Yes; Standard and user pages
OPC UA	
Runtime license required	Yes; "Small" license required
OPC UA Client	Yes
<ul> <li>Application authentication</li> </ul>	Yes
<ul><li>— Security policies</li></ul>	Available security policies: None, Basic128Rsa15, Basic256Rsa15,
	Basic256Sha256
— User authentication	"anonymous" or by user name & password
<ul><li>Number of connections, max.</li></ul>	4

<ul> <li>number of nodes of the client interfaces, recommended max.</li> </ul>	1 000
<ul> <li>Number of elements for one call of OPC_UA_NodeGetHandleList/OPC_UA_ReadList/C max.</li> </ul>	300
Number of elements for one call of OPC_UA_NameSpaceGetIndexList, max.	20
<ul> <li>Number of elements for one call of</li> </ul>	100
OPC_UA_MethodGetHandleList, max.  — number of simultaneous calls of the client instructions for session management, per	1
connection, max.  — number of simultaneous calls of the client instructions for data access, per connection, max.	5
	5 000
Number of registerable nodes, max.      Number of registerable method calls of	100
OPC_UA_MethodCall, max.  — Number of inputs/outputs when calling	20
OPC_UA_MethodCall, max.	
OPC UA Server	Yes; Data access (read, write, subscribe), method call, custom address space
<ul> <li>Application authentication</li> </ul>	Yes
— Security policies	Available security policies: None, Basic128Rsa15, Basic256Rsa15, Basic256Sha256
<ul><li>User authentication</li></ul>	"anonymous" or by user name & password
<ul> <li>— GDS support (certificate management)</li> </ul>	Yes
— Number of sessions, max.	32
<ul> <li>Number of accessible variables, max.</li> </ul>	50 000
<ul> <li>Number of registerable nodes, max.</li> </ul>	10 000
<ul> <li>Number of subscriptions per session, max.</li> </ul>	20
— Sampling interval, min.	100 ms
— Publishing interval, min.	500 ms
Number of server methods, max.	20
Number of inputs/outputs per server method,	20
max.	
<ul> <li>number of monitored items, recommended max.</li> </ul>	1 000; for 1 s sampling interval and 1 s send interval
<ul> <li>Number of server interfaces, max.</li> </ul>	10 of each "Server interfaces" / "Companion specification" type and 20 of the type "Reference namespace"
<ul> <li>Number of nodes for user-defined server interfaces, max.</li> </ul>	1 000
Alarms and Conditions	Yes
Number of program alarms	100
Number of alarms for system diagnostics	50
Further protocols	
MODBUS	Yes; MODBUS TCP
S7 message functions	133, 11102233 13.
	22
Number of login stations for message functions, max.	32 Von
Program alarms	Yes 5 000: Program messages are generated by the "Program Alarm"
Number of configurable program messages, max.	5 000; Program messages are generated by the "Program_Alarm" block, ProDiag or GRAPH
Number of loadable program messages in RUN, max.	2 500
Test commissioning functions	
Joint commission (Team Engineering)	Yes; Parallel online access possible for up to 5 engineering systems
Status block	Yes; Up to 8 simultaneously (in total across all ES clients)
Single step	No
Number of breakpoints	8
Status/control	
<ul> <li>Status/control variable</li> </ul>	Yes
<ul><li>Variables</li></ul>	Inputs/outputs, memory bits, DBs, distributed I/Os, timers, counters
<ul> <li>Number of variables, max.</li> </ul>	
<ul><li>of which status variables, max.</li></ul>	200; per job
<ul><li>of which control variables, max.</li></ul>	200; per job
Forcing	
• Forcing	Yes
<ul> <li>Forcing, variables</li> </ul>	Peripheral inputs/outputs
<ul> <li>Number of variables, max.</li> </ul>	200

Diagnostic buffer	
present	Yes
Number of entries, max.	1 000
— of which powerfail-proof	500
Traces	
Number of configurable Traces	4; Up to 512 KB of data per trace are possible
Interrupts/diagnostics/status information	
Diagnostics indication LED	
RUN/STOP LED	Yes
• ERROR LED	Yes
MAINT LED	Yes
<ul> <li>Monitoring of the supply voltage (PWR-LED)</li> </ul>	Yes
Connection display LINK TX/RX	Yes
Supported technology objects	
Motion Control	Yes; Note: The number of technology objects affects the cycle time of
Number of sucilable Maties Control account for	the PLC program; selection guide via the TIA Selection Tool
<ul> <li>Number of available Motion Control resources for technology objects</li> </ul>	800
Required Motion Control resources	
— per speed-controlled axis	40
— per positioning axis	80
— per synchronous axis	160
— per external encoder	80
— per output cam	20
— per cam track	160
— per probe	40
Positioning axis	
Number of positioning axes at motion control  aveloa of 4 ms (typical value)	5
cycle of 4 ms (typical value)  — Number of positioning axes at motion control	10
cycle of 8 ms (typical value)	10
Controller	
<ul><li>PID_Compact</li></ul>	Yes; Universal PID controller with integrated optimization
<ul><li>PID_3Step</li></ul>	Yes; PID controller with integrated optimization for valves
PID-Temp	Yes; PID controller with integrated optimization for temperature
Counting and measuring	
High-speed counter	Yes
Isolation	
Isolation tested with	750 V DC (type test) and according to EN 50155 (routine test)
Standards, approvals, certificates	
Railway application	V 540 ( 1 1 1 1
• EN 50121-3-2	Yes; EMC for right and telecommunications systems
<ul><li>EN 50121-4</li><li>EN 50124-1</li></ul>	Yes; EMC for signal and telecommunications systems Yes; Railway applications - overvoltage category OV2; pollution degree
♥ LIN JU IZ+-I	PD2; rated surge voltage UNi = 0.5 kV; UNm = 24 V DC
• EN 50125-1	Yes; Rail vehicles - see ambient conditions
• EN 50125-2	Yes; Stationary electrical equipment - see ambient conditions
• EN 50125-3	Yes; Signal and telecommunications systems - see ambient conditions;
	vibrations and shocks: Application point outside of tracks (1 m to 3 m
• EN 50155	away from track)
● EN 50155	Yes; Rail vehicles - temperature class OT1, ST1/ST2, horizontal mounting position
• EN 61373	Yes; Rail vehicles - vibrations and shocks: Category 1 Class A/B
• Fire protection acc. to EN 45545-2	Yes; For proof of conformity, see Service & Support
Ambient conditions	
Ambient temperature during operation	
horizontal installation, min.	-40 °C; = Tmin (incl. condensation/frost)
<ul> <li>horizontal installation, max.</li> </ul>	60 °C; = Tmax; +70 °C for 10 min (OT1, ST1/ST2 acc. to EN 50155)
<ul> <li>vertical installation, min.</li> </ul>	-40 °C; = Tmin
<ul> <li>vertical installation, max.</li> </ul>	50 °C; = Tmax
Altitude during operation relating to sea level	
<ul> <li>Installation altitude above sea level, max.</li> </ul>	2 000 m
Ambient air temperature-barometric pressure-	Tmin Tmax at 1 140 hPa 795 hPa (-1 000 m +2 000 m)
altitude	

Relative humidity	
With condensation, tested in accordance with IEC	100 %; RH incl. condensation / frost (no commissioning in bedewed
60068-2-38, max.	state), horizontal installation
Resistance	
Coolants and lubricants	
<ul> <li>Resistant to commercially available coolants and lubricants</li> </ul>	Yes; Incl. diesel and oil droplets in the air
Use in stationary industrial systems	
<ul> <li>to biologically active substances according to EN 60721-3-3</li> </ul>	Yes; Class 3B2 mold, fungus and dry rot spores (with the exception of fauna); Class 3B3 on request
<ul> <li>to chemically active substances according to EN 60721-3-3</li> </ul>	Yes; Class 3C4 (RH < 75 %) incl. salt spray acc. to EN 60068-2-52 (severity degree 3); *
<ul> <li>to mechanically active substances according to EN 60721-3-3</li> </ul>	Yes; Class 3S4 incl. sand, dust, *
<ul> <li>Against mechanical environmental conditions acc. to EN 60721-3-3</li> </ul>	Yes; Class 3M8 using the SIPLUS Mounting Kit ET 200SP (6AG1193-6AA00-0AA0)
Use on land craft, rail vehicles and special-purpose vehic	cles
<ul> <li>to biologically active substances according to EN 60721-3-5</li> </ul>	Yes; Class 5B2 mold, fungus and dry rot spores (with the exception of fauna); Class 5B3 on request
<ul> <li>to chemically active substances according to EN 60721-3-5</li> </ul>	Yes; Class 5C3 (RH < 75 %) incl. salt spray acc. to EN 60068-2-52 (severity degree 3); *
<ul> <li>to mechanically active substances according to EN 60721-3-5</li> </ul>	Yes; Class 5S3 incl. sand, dust; *
<ul> <li>Against mechanical environmental conditions acc. to EN 60721-3-5</li> </ul>	Yes; Class 5M2 using the SIPLUS Mounting Kit ET 200SP (6AG1193-6AA00-0AA0)
<ul> <li>against mechanical environmental conditions in agriculture acc. to ISO 15003</li> </ul>	Yes; level 1 (Location LE) using the SIPLUS Mounting Kit ET 200SP (6AG1193-6AA00-0AA0)
Usage in industrial process technology	
<ul> <li>Against chemically active substances acc. to EN 60654-4</li> </ul>	Yes; Class 3 (excluding trichlorethylene)
<ul> <li>Environmental conditions for process, measuring and control systems acc. to ANSI/ISA- 71.04</li> </ul>	Yes; Level GX group A/B (excluding trichlorethylene; harmful gas concentrations up to the limits of EN 60721-3-3 class 3C4 permissible); level LC3 (salt spray) and level LB3 (oil)
Remark	
<ul> <li>Note regarding classification of environmental conditions acc. to EN 60721, EN 60654-4 and ANSI/ISA-71.04</li> </ul>	* The supplied plug covers must remain in place over the unused interfaces during operation!
Conformal coating	
<ul> <li>Coatings for printed circuit board assemblies acc. to EN 61086</li> </ul>	Yes; Class 2 for high reliability
<ul> <li>Protection against fouling acc. to EN 60664-3</li> </ul>	Yes; Type 1 protection
Electronic equipment on rolling stock acc. to EN 50155	Yes; Class PC2 protective coating acc. to EN 50155:2017
<ul> <li>Military testing according to MIL-I-46058C, Amendment 7</li> </ul>	Yes; Discoloration of coating possible during service life
Qualification and Performance of Electrical Insulating Compound for Printed Board Assemblies	Yes; Conformal coating, Class A
according to IPC-CC-830A onfiguration / header	
configuration / programming / header	
Programming language  — LAD	Yes
— FBD	Yes
— STL	Yes
— SCL	Yes
— GRAPH	Yes
Know-how protection	
User program protection/password protection	Yes
Copy protection	Yes
Block protection	Yes
Access protection	
protection of confidential configuration data	Yes
Protection level: Write protection	Yes
<ul> <li>Protection level: Read/write protection</li> </ul>	Yes
Protection level: Complete protection	Yes
programming / cycle time monitoring / header	
lower limit	adjustable minimum cycle time
upper limit	adjustable maximum cycle time

Dimensions	
Width	100 mm
Height	117 mm
Depth	75 mm
Weights	
Weight, approx.	310 g
Other	
Note:	for use in railway applications, also observe the product information "SIPLUS extreme RAIL" A5E37661960A, Online Support article 109736776
last modified:	4/1/2022 🗗