Data sheet



SIPLUS S7-1500 CPU 1515F-2 PN rail based on 6ES7515-2FM02-0AB0 with conformal coating, -40...+70 °C, OT4 with ST1/2 (+85 °C for 10 minutes), heat sink, no PS usable, central processing unit with work memory 750 KB for program and 3 MB for data, 1st interface: PROFINET IRT with 2-port switch, 2nd interface: PROFINET RT, 30 ns bit performance, SIMATIC Memory Card required

Figure similar

| Figure similar | |
|--|--|
| General information | |
| Product type designation | CPU 1515F-2 PN |
| Product function | |
| ● I&M data | Yes; I&M0 to I&M3 |
| • Isochronous mode | Yes; Distributed and central; with minimum OB $6x$ cycle of $500~\mu s$ (distributed) and $1~ms$ (central) |
| Engineering with | |
| STEP 7 TIA Portal configurable/integrated from version | see entry ID: 109746275 |
| Configuration control | |
| via dataset | Yes |
| Display | |
| Screen diagonal [cm] | 6.1 cm |
| Control elements | |
| Number of keys | 8 |
| Mode buttons | 2 |
| Supply voltage | |
| Rated value (DC) | 24 V |
| permissible range, lower limit (DC) | 19.2 V |
| permissible range, upper limit (DC) | 28.8 V |
| Reverse polarity protection | Yes |
| Mains buffering | |
| Mains/voltage failure stored energy time | 5 ms |
| Repeat rate, min. | 1/s |
| Input current | |
| Current consumption (rated value) | 0.8 A |
| Current consumption, max. | 1.1 A |
| Inrush current, max. | 2.4 A; Rated value |
| l²t | 0.02 A ² ·s |
| Power | |
| Infeed power to the backplane bus | 12 W |
| Power consumption from the backplane bus (balanced) | 6.2 W |
| Power loss | |
| Power loss, typ. | 6.3 W |
| Memory | |
| Number of slots for SIMATIC memory card | 1 |
| SIMATIC memory card required | Yes |
| Work memory | |
| integrated (for program) | 750 kbyte |
| integrated (for data) | 3 Mbyte |

| Load memory | |
|---|---|
| Plug-in (SIMATIC Memory Card), max. | 32 Gbyte |
| Backup | |
| maintenance-free | Yes |
| CPU processing times | |
| for bit operations, typ. | 30 ns |
| for word operations, typ. | 36 ns |
| for fixed point arithmetic, typ. | 48 ns |
| for floating point arithmetic, typ. | 192 ns |
| CPU-blocks | 102 110 |
| Number of elements (total) | 6 000; Blocks (OB, FB, FC, DB) and UDTs |
| DB | 0 000, Blocks (OB, 1 B, 1 O, BB) and OB 15 |
| Number range | 1 60 999; subdivided into: number range that can be used by the user: 1 59 999, and number range of DBs created via SFC 86: 60 000 60 999 |
| • Size, max. | 3 Mbyte; For DBs with absolute addressing, the max. size is 64 KB |
| FB | |
| Number range | 0 65 535 |
| • Size, max. | 500 kbyte |
| FC | |
| Number range | 0 65 535 |
| • Size, max. | 500 kbyte |
| OB | |
| • Size, max. | 500 kbyte |
| Number of free cycle OBs | 100 |
| Number of time alarm OBs | 20 |
| Number of delay alarm OBs | 20 |
| Number of cyclic interrupt OBs | 20; With minimum OB 3x cycle of 500 μs |
| Number of process alarm OBs | 50 |
| Number of DPV1 alarm OBs | 3 |
| Number of isochronous mode OBs | 2 |
| Number of technology synchronous alarm OBs | 2 |
| Number of startup OBs | 100 |
| Number of asynchronous error OBs | 4 |
| Number of synchronous error OBs | 2 |
| Number of diagnostic alarm OBs | 1 |
| Nesting depth | |
| per priority class | 24; Up to 8 possible for F-blocks |
| Counters, timers and their retentivity | |
| S7 counter | |
| • Number | 2 048 |
| Retentivity | |
| — adjustable | Yes |
| IEC counter | |
| Number | Any (only limited by the main memory) |
| Retentivity | · · |
| — adjustable | Yes |
| S7 times | 0.040 |
| Number Patenticity | 2 048 |
| Retentivity | Ver |
| — adjustable | Yes |
| IEC timer | And the limited by the |
| Number Patenticity | Any (only limited by the main memory) |
| | |
| Retentivity | Voo |
| — adjustable | Yes |
| — adjustable Data areas and their retentivity | |
| — adjustable | 512 kbyte; In total; available retentive memory for bit memories, timers, |
| — adjustable Data areas and their retentivity Retentive data area (incl. timers, counters, flags), max. | |
| — adjustable Data areas and their retentivity | 512 kbyte; In total; available retentive memory for bit memories, timers, |
| — adjustable Data areas and their retentivity Retentive data area (incl. timers, counters, flags), max. Flag | 512 kbyte; In total; available retentive memory for bit memories, timers, counters, DBs, and technology data (axes): 472 KB |

| Retentivity adjustable | Yes |
|--|---|
| Retentivity adjustable Retentivity preset | No |
| Local data | NO |
| per priority class, max. | 64 kbyte; max. 16 KB per block |
| Address area | 04 kbyte, max. To kb per block |
| Number of IO modules | 8 192; max. number of modules / submodules |
| I/O address area | o 192, max. number of modules / submodules |
| • Inputs | 32 kbyte; All inputs are in the process image |
| • | 32 kbyte; All imputs are in the process image |
| Outputs Par integrated IO subsystem | 32 kbyte, All outputs are in the process image |
| per integrated IO subsystem — Inputs (volume) | 8 kbyte |
| | |
| — Outputs (volume) | 8 kbyte |
| per CM/CP | 0 khuta |
| — Inputs (volume) | 8 kbyte |
| — Outputs (volume) | 8 kbyte |
| Subprocess images | 22 |
| Number of subprocess images, max. | 32 |
| Hardware configuration | |
| Number of distributed IO systems | 64; A distributed I/O system is characterized not only by the integration of distributed I/O via PROFINET or PROFIBUS communication modules, but also by the connection of I/O via AS-i master modules or links (e.g. IE/PB-Link) |
| Number of DP masters | |
| • Via CM | 8; A maximum of 8 CMs/CPs (PROFIBUS, PROFINET, Ethernet) can be inserted in total |
| Number of IO Controllers | |
| • integrated | 2 |
| • Via CM | 8; A maximum of 8 CMs/CPs (PROFIBUS, PROFINET, Ethernet) can be inserted in total |
| Rack | inscribed in total |
| Modules per rack, max. | 32; CPU + 31 modules; no system power supply (PS) can be used |
| Number of lines, max. | 1 |
| PtP CM | |
| Number of PtP CMs | the number of connectable PtP CMs is only limited by the number of available slots |
| Time of day | |
| Clock | |
| • Type | Hardware clock |
| Backup time | 6 wk; At 40 °C ambient temperature, typically |
| Deviation per day, max. | 10 s; Typ.: 2 s |
| Operating hours counter | |
| Number | 16 |
| Clock synchronization | |
| • supported | Yes |
| • in AS, master | Yes |
| • in AS, slave | Yes |
| on Ethernet via NTP | Yes |
| Interfaces | |
| Number of PROFINET interfaces | 2 |
| 1. Interface | |
| Interface types | |
| • RJ 45 (Ethernet) | Yes; X1 |
| Number of ports | 2 |
| • integrated switch | Yes |
| Protocols | |
| IP protocol | Yes; IPv4 |
| PROFINET IO Controller | Yes |
| PROFINET IO Device | Yes |
| SIMATIC communication | Yes |
| Open IE communication | Yes; Optionally also encrypted |
| Web server | Yes |
| Media redundancy | Yes; MRP Automanager according to IEC 62439-2 Edition 2.0 |
| PROFINET IO Controller | 100, mill 7 laterial ager develoring to 120 02-100-2 Edition 2.0 |
| TROTINE FIO COMIDNE | |

| Services | |
|---|---|
| — PG/OP communication | Yes |
| Isochronous mode | Yes |
| Direct data exchange | Yes; Requirement: IRT and isochronous mode (MRPD optional) |
| — IRT | Yes |
| — PROFlenergy | Yes |
| Prioritized startup | Yes; Max. 32 PROFINET devices |
| Number of connectable IO Devices, max. | 256; In total, up to 1 000 distributed I/O devices can be connected via AS-i, |
| | PROFIBUS or PROFINET |
| — Of which IO devices with IRT, max. | 64 |
| Number of connectable IO Devices for RT, max. | 256 |
| — of which in line, max. | 256 |
| Number of IO Devices that can be simultaneously activated/deactivated, max. | 8; in total across all interfaces |
| Number of IO Devices per tool, max. | 8 |
| — Updating times | The minimum value of the update time also depends on communication share set for PROFINET IO, on the number of IO devices, and on the quantity of |
| | configured user data |
| Update time for IRT | |
| — for send cycle of 250 μs | 250 μ s to 4 ms; Note: In the case of IRT with isochronous mode, the minimum update time of 500 μ s of the isochronous OB is decisive |
| — for send cycle of 500 μs | 500 μs to 8 ms |
| — for send cycle of 1 ms | 1 ms to 16 ms |
| — for send cycle of 2 ms | 2 ms to 32 ms |
| — for send cycle of 4 ms | 4 ms to 64 ms |
| With IRT and parameterization of "odd" send cycles | Update time = set "odd" send clock (any multiple of 125 μs: 375 μs, 625 μs 3 |
| Undata time for DT | 875 μs) |
| Update time for RT | 050 to 400 |
| — for send cycle of 250 μs | 250 μs to 128 ms |
| — for send cycle of 500 μs | 500 μs to 256 ms |
| — for send cycle of 1 ms | 1 ms to 512 ms |
| — for send cycle of 2 ms | 2 ms to 512 ms |
| | |
| — for send cycle of 4 ms | 4 ms to 512 ms |
| PROFINET IO Device | 4 ms to 512 ms |
| PROFINET IO Device Services | |
| PROFINET IO Device Services — PG/OP communication | Yes |
| PROFINET IO Device Services — PG/OP communication — Isochronous mode | Yes No |
| PROFINET IO Device Services — PG/OP communication — Isochronous mode — IRT | Yes No Yes |
| PROFINET IO Device Services — PG/OP communication — Isochronous mode — IRT — PROFIenergy | Yes No Yes Yes; per user program |
| PROFINET IO Device Services — PG/OP communication — Isochronous mode — IRT — PROFlenergy — Shared device | Yes No Yes Yes; per user program Yes |
| PROFINET IO Device Services — PG/OP communication — Isochronous mode — IRT — PROFIenergy — Shared device — Number of IO Controllers with shared device, max. | Yes No Yes Yes; per user program Yes 4 |
| PROFINET IO Device Services — PG/OP communication — Isochronous mode — IRT — PROFIenergy — Shared device — Number of IO Controllers with shared device, max. — Asset management record | Yes No Yes Yes; per user program Yes |
| PROFINET IO Device Services — PG/OP communication — Isochronous mode — IRT — PROFIenergy — Shared device — Number of IO Controllers with shared device, max. — Asset management record 2. Interface | Yes No Yes Yes; per user program Yes 4 |
| PROFINET IO Device Services — PG/OP communication — Isochronous mode — IRT — PROFlenergy — Shared device — Number of IO Controllers with shared device, max. — Asset management record 2. Interface Interface types | Yes No Yes Yes; per user program Yes 4 Yes; per user program |
| PROFINET IO Device Services — PG/OP communication — Isochronous mode — IRT — PROFIenergy — Shared device — Number of IO Controllers with shared device, max. — Asset management record 2. Interface Interface types • RJ 45 (Ethernet) | Yes No Yes Yes; per user program Yes 4 Yes; per user program Yes; per user program |
| PROFINET IO Device Services — PG/OP communication — Isochronous mode — IRT — PROFIenergy — Shared device — Number of IO Controllers with shared device, max. — Asset management record 2. Interface Interface types • RJ 45 (Ethernet) • Number of ports | Yes No Yes Yes; per user program Yes 4 Yes; per user program Yes; A |
| PROFINET IO Device Services — PG/OP communication — Isochronous mode — IRT — PROFlenergy — Shared device — Number of IO Controllers with shared device, max. — Asset management record 2. Interface Interface types • RJ 45 (Ethernet) • Number of ports • integrated switch | Yes No Yes Yes; per user program Yes 4 Yes; per user program Yes; per user program |
| PROFINET IO Device Services — PG/OP communication — Isochronous mode — IRT — PROFlenergy — Shared device — Number of IO Controllers with shared device, max. — Asset management record 2. Interface Interface types • RJ 45 (Ethernet) • Number of ports • integrated switch Protocols | Yes No Yes Yes; per user program Yes 4 Yes; per user program Yes; X2 1 No |
| PROFINET IO Device Services — PG/OP communication — Isochronous mode — IRT — PROFlenergy — Shared device — Number of IO Controllers with shared device, max. — Asset management record 2. Interface Interface types • RJ 45 (Ethernet) • Number of ports • integrated switch Protocols • IP protocol | Yes No Yes Yes; per user program Yes 4 Yes; per user program Yes; X2 1 No Yes; IPv4 |
| PROFINET IO Device Services — PG/OP communication — Isochronous mode — IRT — PROFlenergy — Shared device — Number of IO Controllers with shared device, max. — Asset management record 2. Interface Interface types • RJ 45 (Ethernet) • Number of ports • integrated switch Protocols • IP protocol • PROFINET IO Controller | Yes No Yes Yes; per user program Yes 4 Yes; per user program Yes; X2 1 No Yes; IPv4 Yes |
| PROFINET IO Device Services — PG/OP communication — Isochronous mode — IRT — PROFlenergy — Shared device — Number of IO Controllers with shared device, max. — Asset management record 2. Interface Interface types • RJ 45 (Ethernet) • Number of ports • integrated switch Protocols • IP protocol • PROFINET IO Controller • PROFINET IO Device | Yes No Yes Yes; per user program Yes 4 Yes; per user program Yes; X2 1 No Yes; IPv4 Yes Yes |
| PROFINET IO Device Services — PG/OP communication — Isochronous mode — IRT — PROFlenergy — Shared device — Number of IO Controllers with shared device, max. — Asset management record 2. Interface Interface types • RJ 45 (Ethernet) • Number of ports • integrated switch Protocols • IP protocol • PROFINET IO Controller • PROFINET IO Device • SIMATIC communication | Yes No Yes Yes; per user program Yes 4 Yes; per user program Yes; X2 1 No Yes; IPv4 Yes Yes Yes Yes |
| PROFINET IO Device Services — PG/OP communication — Isochronous mode — IRT — PROFlenergy — Shared device — Number of IO Controllers with shared device, max. — Asset management record 2. Interface Interface types • RJ 45 (Ethernet) • Number of ports • integrated switch Protocols • IP protocol • PROFINET IO Controller • PROFINET IO Device • SIMATIC communication • Open IE communication | Yes No Yes Yes; per user program Yes 4 Yes; per user program Yes; X2 1 No Yes; IPv4 Yes Yes Yes Yes Yes |
| PROFINET IO Device Services — PG/OP communication — Isochronous mode — IRT — PROFlenergy — Shared device — Number of IO Controllers with shared device, max. — Asset management record 2. Interface Interface types • RJ 45 (Ethernet) • Number of ports • integrated switch Protocols • IP protocol • PROFINET IO Controller • PROFINET IO Device • SIMATIC communication • Open IE communication • Web server | Yes No Yes Yes; per user program Yes 4 Yes; per user program Yes; X2 1 No Yes; IPv4 Yes Yes Yes Yes Yes Yes |
| PROFINET IO Device Services — PG/OP communication — Isochronous mode — IRT — PROFlenergy — Shared device — Number of IO Controllers with shared device, max. — Asset management record 2. Interface Interface types • RJ 45 (Ethernet) • Number of ports • integrated switch Protocols • IP protocol • PROFINET IO Controller • PROFINET IO Device • SIMATIC communication • Open IE communication • Web server • Media redundancy | Yes No Yes Yes; per user program Yes 4 Yes; per user program Yes; X2 1 No Yes; IPv4 Yes Yes Yes Yes Yes |
| PROFINET IO Device Services — PG/OP communication — Isochronous mode — IRT — PROFlenergy — Shared device — Number of IO Controllers with shared device, max. — Asset management record 2. Interface Interface Interface types • RJ 45 (Ethernet) • Number of ports • integrated switch Protocols • IP protocol • PROFINET IO Controller • PROFINET IO Device • SIMATIC communication • Open IE communication • Web server • Media redundancy PROFINET IO Controller | Yes No Yes Yes; per user program Yes 4 Yes; per user program Yes; X2 1 No Yes; IPv4 Yes Yes Yes Yes Yes Yes |
| PROFINET IO Device Services — PG/OP communication — Isochronous mode — IRT — PROFlenergy — Shared device — Number of IO Controllers with shared device, max. — Asset management record 2. Interface Interface types • RJ 45 (Ethernet) • Number of ports • integrated switch Protocols • IP protocol • PROFINET IO Controller • PROFINET IO Device • SIMATIC communication • Open IE communication • Web server • Media redundancy PROFINET IO Controller Services | Yes No Yes Yes; per user program Yes 4 Yes; per user program Yes; X2 1 No Yes; IPv4 Yes |
| PROFINET IO Device Services — PG/OP communication — Isochronous mode — IRT — PROFlenergy — Shared device — Number of IO Controllers with shared device, max. — Asset management record 2. Interface Interface types • RJ 45 (Ethernet) • Number of ports • integrated switch Protocols • IP protocol • PROFINET IO Controller • PROFINET IO Device • SIMATIC communication • Open IE communication • Web server • Media redundancy PROFINET IO Controller Services — PG/OP communication | Yes No Yes Yes; per user program Yes 4 Yes; per user program Yes; X2 1 No Yes; IPv4 Yes |
| PROFINET IO Device Services — PG/OP communication — Isochronous mode — IRT — PROFlenergy — Shared device — Number of IO Controllers with shared device, max. — Asset management record 2. Interface Interface types • RJ 45 (Ethernet) • Number of ports • integrated switch Protocols • IP protocol • PROFINET IO Controller • PROFINET IO Device • SIMATIC communication • Open IE communication • Web server • Media redundancy PROFINET IO Controller Services — PG/OP communication — Isochronous mode | Yes No Yes Yes; per user program Yes; per user program Yes; X2 1 No Yes; IPv4 Yes Yes Yes Yes Yes Yes Yes Yes No |
| PROFINET IO Device Services — PG/OP communication — Isochronous mode — IRT — PROFlenergy — Shared device — Number of IO Controllers with shared device, max. — Asset management record 2. Interface Interface types • RJ 45 (Ethernet) • Number of ports • integrated switch Protocols • IP protocol • PROFINET IO Controller • PROFINET IO Device • SIMATIC communication • Open IE communication • Web server • Media redundancy PROFINET IO Controller Services — PG/OP communication — Isochronous mode — Direct data exchange | Yes No Yes Yes; per user program Yes; per user program Yes; X2 1 No Yes; IPv4 Yes Yes Yes Yes Yes Yes No No |
| PROFINET IO Device Services — PG/OP communication — Isochronous mode — IRT — PROFlenergy — Shared device — Number of IO Controllers with shared device, max. — Asset management record 2. Interface Interface types • RJ 45 (Ethernet) • Number of ports • integrated switch Protocols • IP protocol • PROFINET IO Controller • PROFINET IO Device • SIMATIC communication • Open IE communication • Web server • Media redundancy PROFINET IO Controller Services — PG/OP communication — Isochronous mode | Yes No Yes Yes; per user program Yes; per user program Yes; X2 1 No Yes; IPv4 Yes Yes Yes Yes Yes Yes Yes Yes No |

| Prioritized startup | No |
|--|--|
| Number of connectable IO Devices, max. | 32; In total, up to 1 000 distributed I/O devices can be connected via AS-i, PROFIBUS or PROFINET |
| Number of commentable 10 Decision for DT many | |
| Number of connectable IO Devices for RT, max. | 32 |
| — of which in line, max. | 32 |
| Number of IO Devices that can be simultaneously activated/deactivated, max. | 8; in total across all interfaces |
| Number of IO Devices per tool, max. | 8 |
| — Updating times | The minimum value of the update time also depends on communication share |
| opassing since | set for PROFINET IO, on the number of IO devices, and on the quantity of |
| | configured user data |
| Update time for RT | |
| — for send cycle of 1 ms | 1 ms to 512 ms |
| PROFINET IO Device | |
| Services | |
| PG/OP communication | Yes |
| — Isochronous mode | No |
| — IRT | No |
| — PROFlenergy | Yes |
| — Prioritized startup | No |
| — Shared device | Yes |
| Number of IO Controllers with shared device, max. | 4 |
| Asset management record | Yes; per user program |
| Interface types | |
| RJ 45 (Ethernet) | |
| • 100 Mbps | Yes |
| Autonegotiation | Yes |
| Autocrossing | Yes |
| Industrial Ethernet status LED | Yes |
| Protocols | |
| PROFIsafe | Yes |
| Number of connections | |
| Number of connections, max. | 192; via integrated interfaces of the CPU and connected CPs / CMs |
| Number of connections reserved for ES/HMI/web | 10 |
| Number of connections via integrated interfaces | 108 |
| Number of S7 routing paths | 16 |
| Redundancy mode | |
| H-Sync forwarding | Yes |
| Media redundancy | |
| — MRP | Voc. MDD Automonogor con to IEC 62420.2 Edition 2.0: MDD Manager: MDD |
| | TES. MICE AUTOMATIAGE ACC. TO TEC 02459-2 EQUITOR 2.0. MICE MATIAGE. MICE |
| | Yes; MRP Automanager acc. to IEC 62439-2 Edition 2.0; MRP Manager; MRP Client; max. number of devices in the ring: 50 |
| — MRPD | |
| — MRPD — Switchover time on line break, typ. | Client; max. number of devices in the ring: 50 |
| | Client; max. number of devices in the ring: 50 Yes; Requirement: IRT |
| — Switchover time on line break, typ. | Client; max. number of devices in the ring: 50 Yes; Requirement: IRT 200 ms; For MRP, bumpless for MRPD |
| Switchover time on line break, typ. Number of stations in the ring, max. | Client; max. number of devices in the ring: 50 Yes; Requirement: IRT 200 ms; For MRP, bumpless for MRPD |
| — Switchover time on line break, typ. — Number of stations in the ring, max. SIMATIC communication | Client; max. number of devices in the ring: 50 Yes; Requirement: IRT 200 ms; For MRP, bumpless for MRPD 50 |
| — Switchover time on line break, typ. — Number of stations in the ring, max. SIMATIC communication • S7 communication, as server | Client; max. number of devices in the ring: 50 Yes; Requirement: IRT 200 ms; For MRP, bumpless for MRPD 50 Yes |
| — Switchover time on line break, typ. — Number of stations in the ring, max. SIMATIC communication • S7 communication, as server • S7 communication, as client | Client; max. number of devices in the ring: 50 Yes; Requirement: IRT 200 ms; For MRP, bumpless for MRPD 50 Yes Yes |
| — Switchover time on line break, typ. — Number of stations in the ring, max. SIMATIC communication • S7 communication, as server • S7 communication, as client • User data per job, max. | Client; max. number of devices in the ring: 50 Yes; Requirement: IRT 200 ms; For MRP, bumpless for MRPD 50 Yes Yes |
| — Switchover time on line break, typ. — Number of stations in the ring, max. SIMATIC communication • S7 communication, as server • S7 communication, as client • User data per job, max. Open IE communication | Client; max. number of devices in the ring: 50 Yes; Requirement: IRT 200 ms; For MRP, bumpless for MRPD 50 Yes Yes See online help (S7 communication, user data size) |
| — Switchover time on line break, typ. — Number of stations in the ring, max. SIMATIC communication • \$7 communication, as server • \$7 communication, as client • User data per job, max. Open IE communication • TCP/IP | Client; max. number of devices in the ring: 50 Yes; Requirement: IRT 200 ms; For MRP, bumpless for MRPD 50 Yes Yes See online help (S7 communication, user data size) Yes |
| — Switchover time on line break, typ. — Number of stations in the ring, max. SIMATIC communication • \$7 communication, as server • \$7 communication, as client • User data per job, max. Open IE communication • TCP/IP — Data length, max. | Client; max. number of devices in the ring: 50 Yes; Requirement: IRT 200 ms; For MRP, bumpless for MRPD 50 Yes Yes See online help (S7 communication, user data size) Yes 64 kbyte |
| — Switchover time on line break, typ. — Number of stations in the ring, max. SIMATIC communication • \$7 communication, as server • \$7 communication, as client • User data per job, max. Open IE communication • TCP/IP — Data length, max. — several passive connections per port, supported • ISO-on-TCP (RFC1006) | Client; max. number of devices in the ring: 50 Yes; Requirement: IRT 200 ms; For MRP, bumpless for MRPD 50 Yes Yes See online help (S7 communication, user data size) Yes 64 kbyte Yes Yes |
| — Switchover time on line break, typ. — Number of stations in the ring, max. SIMATIC communication • S7 communication, as server • S7 communication, as client • User data per job, max. Open IE communication • TCP/IP — Data length, max. — several passive connections per port, supported • ISO-on-TCP (RFC1006) — Data length, max. | Client; max. number of devices in the ring: 50 Yes; Requirement: IRT 200 ms; For MRP, bumpless for MRPD 50 Yes Yes See online help (S7 communication, user data size) Yes 64 kbyte Yes Yes 64 kbyte |
| — Switchover time on line break, typ. — Number of stations in the ring, max. SIMATIC communication • S7 communication, as server • S7 communication, as client • User data per job, max. Open IE communication • TCP/IP — Data length, max. — several passive connections per port, supported • ISO-on-TCP (RFC1006) — Data length, max. • UDP | Client; max. number of devices in the ring: 50 Yes; Requirement: IRT 200 ms; For MRP, bumpless for MRPD 50 Yes Yes See online help (S7 communication, user data size) Yes 64 kbyte Yes Yes 64 kbyte Yes |
| — Switchover time on line break, typ. — Number of stations in the ring, max. SIMATIC communication • \$7 communication, as server • \$7 communication, as client • User data per job, max. Open IE communication • TCP/IP — Data length, max. — several passive connections per port, supported • ISO-on-TCP (RFC1006) — Data length, max. • UDP — Data length, max. | Client; max. number of devices in the ring: 50 Yes; Requirement: IRT 200 ms; For MRP, bumpless for MRPD 50 Yes Yes See online help (S7 communication, user data size) Yes 64 kbyte Yes Yes 64 kbyte Yes 2 kbyte; 1 472 bytes for UDP broadcast |
| — Switchover time on line break, typ. — Number of stations in the ring, max. SIMATIC communication • \$7 communication, as server • \$7 communication, as client • User data per job, max. Open IE communication • TCP/IP — Data length, max. — several passive connections per port, supported • ISO-on-TCP (RFC1006) — Data length, max. • UDP — Data length, max. — UDP multicast | Client; max. number of devices in the ring: 50 Yes; Requirement: IRT 200 ms; For MRP, bumpless for MRPD 50 Yes Yes See online help (S7 communication, user data size) Yes 64 kbyte Yes Yes 64 kbyte Yes 64 kbyte Yes 64 kbyte Yes 564 kbyte Yes 765 765 766 767 767 767 767 767 767 767 |
| — Switchover time on line break, typ. — Number of stations in the ring, max. SIMATIC communication • \$7 communication, as server • \$7 communication, as client • User data per job, max. Open IE communication • TCP/IP — Data length, max. — several passive connections per port, supported • ISO-on-TCP (RFC1006) — Data length, max. • UDP — Data length, max. — UDP multicast • DHCP | Client; max. number of devices in the ring: 50 Yes; Requirement: IRT 200 ms; For MRP, bumpless for MRPD 50 Yes Yes See online help (S7 communication, user data size) Yes 64 kbyte Yes Yes 64 kbyte Yes 64 kbyte Yes 64 kbyte Yes 7 kbyte; 1 472 bytes for UDP broadcast Yes; Max. 5 multicast circuits No |
| — Switchover time on line break, typ. — Number of stations in the ring, max. SIMATIC communication • S7 communication, as server • S7 communication, as client • User data per job, max. Open IE communication • TCP/IP — Data length, max. — several passive connections per port, supported • ISO-on-TCP (RFC1006) — Data length, max. • UDP — Data length, max. — UDP multicast • DHCP • SNMP | Client; max. number of devices in the ring: 50 Yes; Requirement: IRT 200 ms; For MRP, bumpless for MRPD 50 Yes Yes See online help (S7 communication, user data size) Yes 64 kbyte Yes Yes 64 kbyte Yes 2 kbyte; 1 472 bytes for UDP broadcast Yes; Max. 5 multicast circuits No Yes |
| — Switchover time on line break, typ. — Number of stations in the ring, max. SIMATIC communication • \$7 communication, as server • \$7 communication, as client • User data per job, max. Open IE communication • TCP/IP — Data length, max. — several passive connections per port, supported • ISO-on-TCP (RFC1006) — Data length, max. • UDP — Data length, max. — UDP multicast • DHCP • \$NMP • DCP | Client; max. number of devices in the ring: 50 Yes; Requirement: IRT 200 ms; For MRP, bumpless for MRPD 50 Yes Yes See online help (S7 communication, user data size) Yes 64 kbyte Yes Yes 64 kbyte Yes 2 kbyte; 1 472 bytes for UDP broadcast Yes; Max. 5 multicast circuits No Yes Yes |
| — Switchover time on line break, typ. — Number of stations in the ring, max. SIMATIC communication • S7 communication, as server • S7 communication, as client • User data per job, max. Open IE communication • TCP/IP — Data length, max. — several passive connections per port, supported • ISO-on-TCP (RFC1006) — Data length, max. • UDP — Data length, max. — UDP multicast • DHCP • SNMP | Client; max. number of devices in the ring: 50 Yes; Requirement: IRT 200 ms; For MRP, bumpless for MRPD 50 Yes Yes See online help (S7 communication, user data size) Yes 64 kbyte Yes Yes 64 kbyte Yes 2 kbyte; 1 472 bytes for UDP broadcast Yes; Max. 5 multicast circuits No Yes |

| • HTTP | Yes; Standard and user pages |
|--|---|
| • HTTPS | Yes; Standard and user pages |
| OPC UA | · · |
| Runtime license required | Yes |
| OPC UA Client | Yes |
| — Application authentication | Yes |
| — Security policies | Available security policies: None, Basic128Rsa15, Basic256Rsa15, Basic256Sha256 |
| User authentication | "anonymous" or by user name & password |
| Number of connections, max. | 10 |
| Number of nodes of the client interfaces, recommended max. | 2 000 |
| Number of elements for one call of OPC_UA_NodeGetHandleList/OPC_UA_ReadList/OPC_I max. | 300 |
| Number of elements for one call of OPC_UA_NameSpaceGetIndexList, max. | 20 |
| Number of elements for one call of OPC_UA_MethodGetHandleList, max. | 100 |
| Number of simultaneous calls of the client instructions for session management, per connection, max. | 1 |
| Number of simultaneous calls of the client instructions for data access, per connection, max. | 5 |
| Number of registerable nodes, max. | 5 000 |
| Number of registerable method calls of OPC_UA_MethodCall, max. | 100 |
| Number of inputs/outputs when calling OPC_UA_MethodCall, max. | 20 |
| OPC UA Server | Yes; Data access (read, write, subscribe), method call, custom address space |
| Application authentication | Yes |
| — Security policies | Available security policies: None, Basic128Rsa15, Basic256Rsa15, Basic256Sha256 |
| — User authentication | "anonymous" or by user name & password |
| Number of sessions, max. | 48 |
| Number of accessible variables, max. | 100 000 |
| Number of registerable nodes, max. | 20 000 |
| Number of subscriptions per session, max. | 20 |
| — Sampling interval, min. | 100 ms |
| — Publishing interval, min. | 200 ms |
| Number of server methods, max. | 50 |
| Number of inputs/outputs per server method, max. | 20 |
| Number of monitored items, recommended max. | 2 000; for 1 s sampling interval and 1 s send interval |
| Number of server interfaces, max. | 10 |
| Number of nodes for user-defined server interfaces, max. | 5 000 |
| Further protocols | |
| • MODBUS | Yes; MODBUS TCP |
| ochronous mode | |
| Equidistance | Yes |
| 7 message functions | |
| Number of login stations for message functions, max. | 32 |
| Program alarms | Yes |
| Number of configurable program messages, max. | 10 000; Program messages are generated by the "Program_Alarm" block, ProDiag or GRAPH |
| Number of loadable program messages in RUN, max. | 5 000 |
| Number of simultaneously active program alarms | |
| Number of program alarms | 800 |
| Number of alarms for system diagnostics | 200 |
| Number of alarms for motion technology objects | 160 |
| est commissioning functions | |
| Joint commission (Team Engineering) | Yes; Parallel online access possible for up to 8 engineering systems |
| Status block | Yes; Up to 8 simultaneously (in total across all ES clients) |
| Single step | No |
| Number of breakpoints | 8 |
| | |

| Status/control | |
|---|--|
| Status/control variable | Yes |
| Variables | Inputs/outputs, memory bits, DBs, distributed I/Os, timers, counters |
| Number of variables, max. | |
| of which status variables, max. | 200; per job |
| — of which control variables, max. | 200; per job |
| Forcing | |
| Forcing, variables | Peripheral inputs/outputs |
| Number of variables, max. | 200 |
| Diagnostic buffer | |
| • present | Yes |
| Number of entries, max. | 3 200 |
| — of which powerfail-proof | 500 |
| Traces | |
| Number of configurable Traces | 4; Up to 512 KB of data per trace are possible |
| Interrupts/diagnostics/status information | |
| Diagnostics indication LED | |
| RUN/STOP LED | Yes |
| • ERROR LED | Yes |
| MAINT LED | Yes |
| STOP ACTIVE LED | Yes |
| Connection display LINK TX/RX | Yes |
| Supported technology objects | |
| Motion Control | Yes; Note: The number of axes affects the cycle time of the PLC program; |
| | selection guide via the TIA Selection Tool or SIZER |
| Number of available Motion Control resources for technology objects | 2 400 |
| Required Motion Control resources | |
| — per speed-controlled axis | 40 |
| — per positioning axis | 80 |
| — per synchronous axis | 160 |
| — per external encoder | 80 |
| — per output cam | 20 |
| — per cam track | 160 |
| — per probe | 40 |
| Positioning axis | |
| Number of positioning axes at motion control cycle of 4 ms (typical value) | 7 |
| Number of positioning axes at motion control cycle of 8 ms (typical value) | 14 |
| Controller | |
| PID_Compact | Yes; Universal PID controller with integrated optimization |
| • PID_3Step | Yes; PID controller with integrated optimization for valves |
| • PID-Temp | Yes; PID controller with integrated optimization for temperature |
| Counting and measuring | - 1-1, 2 contraint intermitted optimization for temperature |
| High-speed counter | Yes |
| Isolation | |
| Isolation tested with | 750 V DC (type test) and according to EN 50155 (routing test) |
| | 750 V DC (type test) and according to EN 50155 (routine test) |
| Standards, approvals, certificates | |
| Highest safety class achievable in safety mode | Dia |
| Performance level according to ISO 13849-1 | PLe |
| • SIL acc. to IEC 61508 | SIL 3 |
| • SIL in accordance with EN 50126, 50128, 50129 | SIL 2; a higher safety integrity level is possible if tested and approved for the specific application under consideration of all local regulations. |
| Probability of failure (for service life of 20 years and repair time | · · · · · · · · · · · · · · · · · · · |
| Low demand mode: PFDavg in accordance with SIL3 | < 2.00E-05 |
| High demand/continuous mode: PFH in accordance with SIL3 | < 1.00E-09 |
| Railway application | |
| • EN 50121-3-2 | Yes; EMC for rail vehicles |
| ● EN 50121-4 | Yes; EMC for signal and telecommunications systems |
| ● EN 50124-1 | Yes: Railway applications - overvoltage category OV2: pollution degree PD2: |

| | rated surge voltage UNi = 0.5 kV; UNm = 24 V DC |
|---|---|
| • EN 50125-1 | Yes; Rail vehicles - see ambient conditions |
| ● EN 50125-2 | Yes; Stationary electrical equipment - see ambient conditions |
| ● EN 50125-3 | Yes; Signal and telecommunications systems - see ambient conditions; vibrations and shocks: Application point outside of tracks (1 m to 3 m away from track) |
| • EN 50155 | Yes; Rail vehicles - temperature class OT4, ST1/ST2, horizontal mounting position |
| • EN 61373 | Yes; Rail vehicles - vibrations and shocks: Category 1 Class A/B |
| • Fire protection acc. to EN 45545-2 | Yes; For proof of conformity, see Service & Support |
| Ambient conditions | |
| Ambient temperature during operation | |
| horizontal installation, min. | -40 °C; = Tmin (incl. condensation/frost) |
| horizontal installation, max. | 70 °C; = Tmax; +85 °C for 10 min (OT4, ST1/ST2 acc. to EN 50155); display: 50 °C, the display is switched off at an operating temperature of typically 50 °C |
| • vertical installation, min. | -40 °C; = Tmin |
| vertical installation, max. | 40 °C; = Tmax; display: 40 °C, at an operating temperature of typically 40 °C, the display is switched off |
| Ambient temperature during storage/transportation | |
| • min. | -40 °C |
| • max. | 70 °C |
| Altitude during operation relating to sea level | |
| Installation altitude above sea level, max. | 2 000 m |
| Ambient air temperature-barometric pressure-altitude | Tmin Tmax at 1 140 hPa 795 hPa (-1 000 m +2 000 m) |
| Relative humidity | |
| With condensation, tested in accordance with IEC 60068- | 100 %; RH incl. condensation / frost (no commissioning in bedewed state), |
| 2-38, max. | horizontal installation |
| Resistance | |
| Coolants and lubricants | |
| Resistant to commercially available coolants and lubricants | Yes; Incl. diesel and oil droplets in the air |
| Use in stationary industrial systems | |
| — to biologically active substances according to EN 60721-3-3 | Yes; Class 3B2 mold, fungus and dry rot spores (with the exception of fauna); Class 3B3 on request |
| to chemically active substances according to EN 60721-3-3 | Yes; Class 3C4 (RH < 75 %) incl. salt spray acc. to EN 60068-2-52 (severity degree 3); * |
| to mechanically active substances according to EN 60721-3-3 | Yes; Class 3S4 incl. sand, dust, * |
| Use on land craft, rail vehicles and special-purpose vehicles | |
| — to biologically active substances according to EN 60721-3-5 | Yes; Class 5B2 mold, fungus and dry rot spores (with the exception of fauna); Class 5B3 on request |
| to chemically active substances according to EN 60721-3-5 | Yes; Class 5C3 (RH < 75 %) incl. salt spray acc. to EN 60068-2-52 (severity degree 3); * |
| to mechanically active substances according to EN 60721-3-5 | Yes; Class 5S3 incl. sand, dust; * |
| Usage in industrial process technology | |
| Against chemically active substances acc. to EN 60654-4 | Yes; Class 3 (excluding trichlorethylene) |
| Environmental conditions for process, measuring and control systems acc. to ANSI/ISA-71.04 | Yes; Level GX group A/B (excluding trichlorethylene; harmful gas concentrations up to the limits of EN 60721-3-3 class 3C4 permissible); level LC3 (salt spray) and level LB3 (oil) |
| Remark | |
| Note regarding classification of environmental conditions acc. to EN 60721, EN 60654-4 and ANSI/ISA-71.04 | * The supplied plug covers must remain in place over the unused interfaces during operation! |
| Conformal coating | |
| Coatings for printed circuit board assemblies acc. to EN 61086 | Yes; Class 2 for high reliability |
| Protection against fouling acc. to EN 60664-3 | Yes; Type 1 protection |
| Electronic equipment on rolling stock acc. to EN 50155 | Yes; Class PC2 protective coating acc. to EN 50155:2017 |
| Military testing according to MIL-I-46058C, Amendment 7 | Yes; Discoloration of coating possible during service life |
| Qualification and Performance of Electrical Insulating Compound for Printed Board Assemblies according to IPC-CC-830A | Yes; Conformal coating, Class A |
| configuration / header | |
| configuration / programming / header | |
| Programming language | |

| — LAD | Yes; incl. failsafe |
|---|--|
| — FBD | Yes; incl. failsafe |
| — STL | Yes |
| — SCL | Yes |
| — GRAPH | Yes |
| Know-how protection | |
| User program protection/password protection | Yes |
| Copy protection | Yes |
| Block protection | Yes |
| Access protection | |
| Password for display | Yes |
| Protection level: Write protection | Yes; Specific write protection both for Standard and for Failsafe |
| Protection level: Read/write protection | Yes |
| Protection level: Complete protection | Yes |
| programming / cycle time monitoring / header | |
| lower limit | adjustable minimum cycle time |
| • upper limit | adjustable maximum cycle time |
| Dimensions | |
| Width | 105 mm |
| Height | 147 mm |
| Depth | 129 mm |
| Weights | |
| Weight, approx. | 820 g |
| Other | |
| Note: | for use in railway applications, also observe the product information "SIPLUS extreme RAIL" A5E37661960A, Online Support article 109736776 |

last modified:

8/11/2023