## **SIEMENS**

## **Data sheet**

SIMATIC IFP1900 V2 PRO, 19 multi-touch display (16:9) with 1920x1080 pixel resolution, PRO variant stand, for 24 V DC, DisplayPort, can be placed up to 100 m away HDBaseT, USB on the rear side, standard design



Figure similar

General information	JED 1000 VID DDO		
Product type designation	IFP1900 V2 PRO		
Short designation	Flat Panel 19" PRO multi-touch ext.		
Display			
Design of display	TFT widescreen display, LED backlighting		
Screen diagonal	18.5 in; 19"		
Screen diagonal [cm]	47 cm		
Display width	408.96 mm		
Display height	230.04 mm		
On Screen Display (OSD) configuration	No; Adjustable by means of software		
Number of colors	16 777 216; 24 bit		
Viewing angle	178° x 178°		
Resolution (pixels)			
<ul> <li>Image resolution</li> </ul>	1 920 x 1 080		
<ul> <li>Horizontal image resolution</li> </ul>	1 920 pixel		
<ul> <li>Vertical image resolution</li> </ul>	1 080 pixel		
<ul> <li>Pixel size, horizontal</li> </ul>	0.213 mm		
Pixel size, vertical	0.213 mm		
General features			
<ul> <li>Brightness/contrast</li> </ul>	350 cd/m <sup>2</sup> / 1 000:1		
<ul> <li>non-reflective and tempered mineral glass screen</li> </ul>	Yes		
<ul> <li>Detachable from computer unit</li> </ul>	100 m; HDBaseT protocol		
Luminance	350 cd/m <sup>2</sup>		
Backlighting			
<ul> <li>Type of backlighting</li> </ul>	LED		
<ul> <li>MTBF backlighting (at 25 °C)</li> </ul>	50 000 h; At 25°C		
Backlight dimmable	Yes; 0-100 %		
Control elements			
Control elements	multi-touch screen		
Input device			
<ul> <li>Integrated mouse cursor control</li> </ul>	Yes; Also externally via USB		
Touch operation			
Design as touch screen	Yes; Projective-capacitive		
Design as multi-touch screen	Yes; Projective-capacitive		
Monitor keyboard	Yes		
Installation type/mounting			
Design	Pedestal mounting		
Front mounting	No		
Support arm mounting	No		

	V		
Stand mounting	Yes		
VESA mounting	Yes; VESA 100 x 100 integrated		
maximum permitted forward tilt angle from vertical	45°		
maximum permitted backward tilt angle from vertical	45°		
Supply voltage			
Type of supply voltage	DC		
Rated value (DC)	24 V; PELV / SELV floating		
permissible range, lower limit (DC)	19.2 V		
permissible range, upper limit (DC)	28.8 V		
Input current	<u></u>		
Current consumption (rated value)	1.2 A		
Current consumption, max.	1.5 A		
Starting current inrush I2t	0.5 A <sup>2</sup> ·s		
Power loss			
Power loss, typ.	29 W		
Power loss, max.	36 W		
Interfaces			
Number of USB interfaces	2; USB 2.0 type A		
USB on the rear	Yes; 2x onboard		
Connection for keyboard/mouse	USB		
Video interfaces			
DisplayPort	Yes; Display port V1.2		
Touch interfaces	,,		
• USB	Yes		
Degree and class of protection			
IP (at the front)	IP65		
IP (rear)	IP65		
	1F03		
NEMA (front)	Yes		
Enclosure Type 4 at the front     Findance Type 4 at the front	Yes		
Enclosure Type 4x at the front	res		
Standarda annivavala cortificates			
Standards, approvals, certificates  Certificate of suitability	hazardous zone 2/22: shiphuilding		
Certificate of suitability	hazardous zone 2/22; shipbuilding		
Certificate of suitability CE mark	Yes		
Certificate of suitability CE mark UL approval	Yes Yes		
Certificate of suitability CE mark UL approval cULus	Yes Yes; Corresponds to UL 508		
Certificate of suitability CE mark UL approval cULus FM approval	Yes Yes Yes; Corresponds to UL 508 in preparation		
Certificate of suitability CE mark UL approval cULus FM approval RCM (formerly C-TICK)	Yes Yes Yes; Corresponds to UL 508 in preparation Yes		
Certificate of suitability CE mark UL approval cULus FM approval RCM (formerly C-TICK) EAC (formerly Gost-R)	Yes Yes Yes; Corresponds to UL 508 in preparation Yes Yes		
Certificate of suitability CE mark UL approval cULus FM approval RCM (formerly C-TICK) EAC (formerly Gost-R) EMC	Yes Yes Yes; Corresponds to UL 508 in preparation Yes		
Certificate of suitability CE mark UL approval cULus FM approval RCM (formerly C-TICK) EAC (formerly Gost-R) EMC Use in hazardous areas	Yes Yes; Corresponds to UL 508 in preparation Yes Yes CE, EN 55011, EN 61000-6-4, EN 61000-6-2		
Certificate of suitability CE mark UL approval cULus FM approval RCM (formerly C-TICK) EAC (formerly Gost-R) EMC Use in hazardous areas  • ATEX Zone 2	Yes Yes Yes; Corresponds to UL 508 in preparation Yes Yes CE, EN 55011, EN 61000-6-4, EN 61000-6-2 Yes		
Certificate of suitability CE mark UL approval cULus FM approval RCM (formerly C-TICK) EAC (formerly Gost-R) EMC Use in hazardous areas  • ATEX Zone 2 • ATEX Zone 22	Yes Yes; Corresponds to UL 508 in preparation Yes Yes CE, EN 55011, EN 61000-6-4, EN 61000-6-2  Yes Yes		
Certificate of suitability CE mark UL approval cULus FM approval RCM (formerly C-TICK) EAC (formerly Gost-R) EMC Use in hazardous areas  • ATEX Zone 2 • ATEX Zone 22 • IECEx Zone 2	Yes Yes; Corresponds to UL 508 in preparation Yes Yes CE, EN 55011, EN 61000-6-4, EN 61000-6-2  Yes Yes Yes Yes		
Certificate of suitability CE mark UL approval cULus FM approval RCM (formerly C-TICK) EAC (formerly Gost-R) EMC Use in hazardous areas  • ATEX Zone 2 • IECEx Zone 2 • IECEx Zone 22	Yes Yes; Corresponds to UL 508 in preparation Yes Yes CE, EN 55011, EN 61000-6-4, EN 61000-6-2  Yes Yes Yes Yes Yes Yes		
Certificate of suitability CE mark UL approval cULus FM approval RCM (formerly C-TICK) EAC (formerly Gost-R) EMC Use in hazardous areas  • ATEX Zone 2 • ATEX Zone 22 • IECEx Zone 22 • IECEx Zone 22 • FM Class I Division 2	Yes Yes; Corresponds to UL 508 in preparation Yes Yes CE, EN 55011, EN 61000-6-4, EN 61000-6-2  Yes Yes Yes Yes		
Certificate of suitability CE mark UL approval cULus FM approval RCM (formerly C-TICK) EAC (formerly Gost-R) EMC Use in hazardous areas  • ATEX Zone 2 • IECEx Zone 2 • IECEx Zone 22	Yes Yes; Corresponds to UL 508 in preparation Yes Yes CE, EN 55011, EN 61000-6-4, EN 61000-6-2  Yes Yes Yes Yes Yes Yes		
Certificate of suitability CE mark UL approval cULus FM approval RCM (formerly C-TICK) EAC (formerly Gost-R) EMC Use in hazardous areas  • ATEX Zone 2 • ATEX Zone 22 • IECEx Zone 22 • IECEx Zone 22 • FM Class I Division 2	Yes Yes; Corresponds to UL 508 in preparation Yes Yes CE, EN 55011, EN 61000-6-4, EN 61000-6-2  Yes Yes Yes Yes Yes Yes		
Certificate of suitability CE mark UL approval cULus FM approval RCM (formerly C-TICK) EAC (formerly Gost-R) EMC Use in hazardous areas  • ATEX Zone 2 • ATEX Zone 22 • IECEx Zone 2 • IECEx Zone 22 • FM Class I Division 2  Ambient conditions	Yes Yes; Corresponds to UL 508 in preparation Yes Yes CE, EN 55011, EN 61000-6-4, EN 61000-6-2  Yes Yes Yes Yes Yes Yes		
Certificate of suitability CE mark UL approval cULus FM approval RCM (formerly C-TICK) EAC (formerly Gost-R) EMC Use in hazardous areas • ATEX Zone 2 • ATEX Zone 22 • IECEx Zone 2 • IECEx Zone 22 • FM Class I Division 2  Ambient conditions Ambient temperature during operation	Yes Yes; Corresponds to UL 508 in preparation Yes Yes CE, EN 55011, EN 61000-6-4, EN 61000-6-2  Yes Yes Yes Yes Yes Yes Yos No		
Certificate of suitability CE mark UL approval cULus FM approval RCM (formerly C-TICK) EAC (formerly Gost-R) EMC Use in hazardous areas  • ATEX Zone 2 • ATEX Zone 22 • IECEx Zone 22 • IECEx Zone 22 • FM Class I Division 2  Ambient conditions  Ambient temperature during operation • min.	Yes Yes; Corresponds to UL 508 in preparation Yes Yes CE, EN 55011, EN 61000-6-4, EN 61000-6-2  Yes Yes Yes Yes Yes Yes Yes Your Carresponds to UL 508 In preparation Yes Yes Yes Yes Yes Your Carresponds to UL 508 In preparation Yes Yes Yes Yes Your Carresponds to UL 508 In preparation Yes Yes Yes Your Carresponds to UL 508 In preparation Yes Yes Yes Yes Your Carresponds to UL 508 In preparation Yes Yes Yes Yes Yes Yes Yes Yes Yes No		
Certificate of suitability CE mark UL approval cULus FM approval RCM (formerly C-TICK) EAC (formerly Gost-R) EMC Use in hazardous areas  • ATEX Zone 2 • ATEX Zone 22 • IECEx Zone 22 • IECEx Zone 22 • FM Class I Division 2  Ambient conditions  Ambient temperature during operation • min. • max.	Yes Yes; Corresponds to UL 508 in preparation Yes Yes CE, EN 55011, EN 61000-6-4, EN 61000-6-2  Yes Yes Yes Yes Yes Yes Yes Your Carresponds to UL 508 In preparation Yes Yes Yes Yes Yes Your Carresponds to UL 508 In preparation Yes Yes Yes Yes Your Carresponds to UL 508 In preparation Yes Yes Yes Your Carresponds to UL 508 In preparation Yes Yes Yes Yes Your Carresponds to UL 508 In preparation Yes Yes Yes Yes Yes Yes Yes Yes Yes No		
Certificate of suitability CE mark UL approval cULus FM approval RCM (formerly C-TICK) EAC (formerly Gost-R) EMC Use in hazardous areas  • ATEX Zone 2 • ATEX Zone 22 • IECEx Zone 2 • IECEx Zone 22 • IECEx Zone 22 • FM Class I Division 2  Ambient conditions  Ambient temperature during operation • min. • max.  Ambient temperature during storage/transportation	Yes Yes; Corresponds to UL 508 in preparation Yes Yes CE, EN 55011, EN 61000-6-4, EN 61000-6-2  Yes Yes Yes Yes Yes Yes Yes Yes Yes Ye		
Certificate of suitability CE mark UL approval cULus FM approval RCM (formerly C-TICK) EAC (formerly Gost-R) EMC Use in hazardous areas • ATEX Zone 2 • ATEX Zone 22 • IECEx Zone 2 • IECEx Zone 22 • FM Class I Division 2  Ambient conditions Ambient temperature during operation • min. • max.  Ambient temperature during storage/transportation • min.	Yes Yes; Corresponds to UL 508 in preparation Yes Yes CE, EN 55011, EN 61000-6-4, EN 61000-6-2  Yes Yes Yes Yes Yes Yes Yes Yes Yes Ye		
Certificate of suitability CE mark UL approval cULus FM approval RCM (formerly C-TICK) EAC (formerly Gost-R) EMC Use in hazardous areas	Yes Yes; Corresponds to UL 508 in preparation Yes Yes CE, EN 55011, EN 61000-6-4, EN 61000-6-2  Yes Yes Yes Yes Yes Yes Yes Yes Yes Ye		
Certificate of suitability CE mark UL approval cULus FM approval RCM (formerly C-TICK) EAC (formerly Gost-R) EMC Use in hazardous areas  • ATEX Zone 2 • ATEX Zone 22 • IECEx Zone 22 • IECEx Zone 22 • FM Class I Division 2  Ambient conditions  Ambient temperature during operation • min. • max.  Ambient temperature during storage/transportation • min. • max.  Relative humidity	Yes Yes; Corresponds to UL 508 in preparation Yes Yes CE, EN 55011, EN 61000-6-4, EN 61000-6-2  Yes Yes Yes Yes Yes Yes Yes Yes Yes Ye		
Certificate of suitability CE mark UL approval cULus FM approval RCM (formerly C-TICK) EAC (formerly Gost-R) EMC Use in hazardous areas  • ATEX Zone 2 • ATEX Zone 22 • IECEx Zone 22 • IECEx Zone 22 • FM Class I Division 2  Ambient conditions  Ambient temperature during operation • min. • max.  Ambient temperature during storage/transportation • min. • max.  Relative humidity • Operation, max.	Yes Yes; Corresponds to UL 508 in preparation Yes Yes CE, EN 55011, EN 61000-6-4, EN 61000-6-2  Yes Yes Yes Yes Yes Yes Yes Yes Yes Ye		
Certificate of suitability CE mark UL approval cULus FM approval RCM (formerly C-TICK) EAC (formerly Gost-R) EMC Use in hazardous areas  • ATEX Zone 2 • IECEx Zone 22 • IECEx Zone 22 • FM Class I Division 2  Ambient conditions Ambient temperature during operation • min. • max.  Ambient temperature during storage/transportation • min. • max.  Relative humidity • Operation, max.  Vibrations	Yes Yes; Corresponds to UL 508 in preparation Yes Yes CE, EN 55011, EN 61000-6-4, EN 61000-6-2  Yes Yes Yes Yes Yes Yes No  0 °C 45 °C  -20 °C 60 °C  95 %; no condensation		
Certificate of suitability CE mark UL approval cULus FM approval RCM (formerly C-TICK) EAC (formerly Gost-R) EMC Use in hazardous areas	Yes Yes Yes; Corresponds to UL 508 in preparation Yes Yes CE, EN 55011, EN 61000-6-4, EN 61000-6-2  Yes Yes Yes Yes Yes Yes Yes Yos No  0 °C 45 °C  -20 °C 60 °C  95 %; no condensation		
Certificate of suitability CE mark UL approval cULus FM approval RCM (formerly C-TICK) EAC (formerly Gost-R) EMC Use in hazardous areas	Yes Yes Yes; Corresponds to UL 508 in preparation Yes Yes CE, EN 55011, EN 61000-6-4, EN 61000-6-2  Yes Yes Yes Yes Yes Yes Yes Yos No  0 °C 45 °C  -20 °C 60 °C  95 %; no condensation		
Certificate of suitability CE mark UL approval cULus FM approval RCM (formerly C-TICK) EAC (formerly Gost-R) EMC Use in hazardous areas	Yes Yes; Corresponds to UL 508 in preparation Yes Yes CE, EN 55011, EN 61000-6-4, EN 61000-6-2  Yes Yes Yes Yes Yes Yes Yes Yes Yes Ye		

Mechanics/material				
Enclosure material (front)	In standard design			
Aluminum	Yes			
<ul> <li>Aluminum casting</li> </ul>	Yes			
Glass	Yes; at front			
Enclosure material (rear)	aluminum			
Dimensions				
Width of the housing front	462 mm			
Height of housing front	292 mm			
Weights				
Weight (without packaging)	6.3 kg			
Weight (with packaging)	7 kg			

Classifications

	Version	Classification
eClass	14	19-20-02-01
eClass	12	19-20-02-01
eClass	9.1	19-20-02-01
eClass	9	19-20-02-01
eClass	8	19-20-02-01
eClass	7.1	19-20-02-01
eClass	6	19-20-02-01
ETIM	9	EC001428
ETIM	8	EC001428
ETIM	7	EC001428
IDEA	4	6675
UNSPSC	15	43-21-19-02

## Approvals / Certificates

## **General Product Approval**

**Miscellaneous** 

Manufacturer Declara-<u>tion</u>









General Product Approval

EMV

For use in hazardous locations

**BIS CRS** 









Miscellaneous

For use in hazardous locations

Marine / Shipping

Environment



NK / Nippon Kaiji Ky-okai



last modified:

8/8/2024

