



AGA CERTIFIED PRODUCT

Certificate Holder: **KARL DUNGS GMBH & CO. KG**

ABN/ACN No. (if applicable): N/A

Manufacturer: **KARL DUNGS GMBH & CO. KG**

Agent (if applicable): **Techrite Controls Australia Pty Ltd**

Type of Component: **COMBINATION CONTROL VALVES**

Model No. & Description: **DUNGS**
(Refer www.aga.asn.au for more details) **MB-VEF 407, 412, 415, 420, 425**
S10/S12 and S30/S32
MWP S10/S12 – 10 kPa
MWP S30/S32 – 36 kPa
Class 1 – AS 4629

Relevant Standard(s): **AS 4624 – 2005 (Amdt 1)**

This is to certify that the particular **COMPONENT** specifically described herein and supplied to The Australian Gas Association (hereafter called the AGA) by the Certificate Holder named above has been subject to "type-testing" and assessed by the AGA to comply with the requirements of the AGA's Product Certification Scheme for Type Tested Gas Products.

This Certificate is issued on the express conditions that:

- (i) The Certificate Holder undertakes to comply with the Rules Governing The AGA's Product Certification Scheme (hereafter called the Rules Governing);
- (ii) This Certificate remains the property of the AGA; and
- (iii) The AGA reserves the right to cancel this Certificate in accordance with the Rules Governing, and in such an event the Certificate Holder undertakes to surrender the Certificate to the AGA upon request.




Client Manger


Certificate Authorised

Certificate first issued: **31 January 1997**

Certificate No: **5512**

This copy valid from: **28 February 2019**

Refer specification issue: **03**