

EU-Type Examination Certificate

No. C5A 022629 0013 Rev. 01

Holder of Certificate: **Karl Dungs GmbH & Co. KG**

Karl-Dungs-Platz 1
73660 Urbach
GERMANY

Product:

Fittings (Gas)
Control unit for valve proving systems

VPM-VC


CE-0123CT1102

The Certification Body of TÜV SÜD Product Service GmbH confirms according to Annex III (Module B) that the listed product complies with the relevant provisions according to Annex I of Regulation (EU) 2016/426 on appliances burning gaseous fuels. It refers only to the sample submitted for testing and certification and on its technical documentation. For details see: www.tuvsud.com/ps-cert

Test report no.: C-P 1466-09/25

Valid until: 2028-03-25

Date, 2025-05-20



(Johannes Steiglechner)

EU-Type Examination Certificate

No. C5A 022629 0013 Rev. 01

Model(s): **VPM-VC (V1.0)**
VPM-VC (V1.1)

Technical data / range of application

Supply voltage:	230 V AC, 50/60 Hz 115 V AC, 50/60 Hz (optional)
Ambient temperature:	-20°C... +60°C
Degree of protection	VPM-VC (V1.0): IP42 VPM-VC (V1.1): IP54

The conditions and requirements mentioned in annex Z of test report no. C-P 1466-09/25 shall be considered for installation, configuration, commissioning and operation.

Further details / remarks:

The control unit for valve proving systems also conforms to the requirements of

- ISO 23551-4:2018-04 and ISO 23550:2018-04 for EU and JP, and of
- DIN EN 61508:2011, parts 1–3, up to safety integrity level SIL 2.

Tested according to: **DIN EN 1643:2014**
DIN EN 13611:2011
DIN EN 13611:2016

EU-Baumusterprüfbescheinigung

Nr. C5A 022629 0013 Rev. 01

Zertifikatsinhaber: **Karl Dungs GmbH & Co. KG**
Karl-Dungs-Platz 1
73660 Urbach
DEUTSCHLAND

Produkt: **Ausrüstungen (Gas)**
Steuergerät für
Ventilüberwachungssysteme

VPM-VC


CE-0123CT1102

Die Zertifizierstelle von TÜV SÜD Product Service GmbH bestätigt gemäß Anhang III (Modul B) die Übereinstimmung des bezeichneten Produktes mit den wesentlichen Anforderungen gemäß Anhang I der Verordnung (EU) 2016/426 über Geräte zur Verbrennung gasförmiger Brennstoffe. Prüfgrundlage ist ausschließlich das zur Prüfung und Zertifizierung vorgestellte Prüfmuster sowie dessen technische Dokumentation. Details siehe bitte: www.tuvsud.com/ps-zert

Prüfbericht Nr.: C-P 1466-09/25

Gültig bis: 2028-03-25

Datum, 2025-05-20



(Johannes Steiglechner)

EU-Baumusterprüfbescheinigung

Nr. C5A 022629 0013 Rev. 01

Modell(e): VPM-VC (V1.0)
VPM-VC (V1.1)

Technische Daten / Verwendungsbereich

Elektrische Anschlussdaten:	230 V AC, 50/60 Hz 115 V AC, 50/60 Hz (wahlweise)
Umgebungstemperatur:	-20°C... +60°C
Schutzgrad:	VPM-VC (V1.0): IP42 VPM-VC (V1.1): IP54

Die im Anhang Z des Prüfberichtes Nr. C-P 1466-09/25 genannten Bedingungen und Anforderungen sind bei der Installation, der Konfiguration, der Einstellung und im Betrieb zu berücksichtigen.

Weitere Angaben / Anmerkungen:

Das Steuergerät für Ventilüberwachungssysteme entspricht auch den Anforderungen von

- ISO 23551-4:2018-04 und ISO 23550:2018-04 für EU und JP, und von
- DIN EN 61508:2011, Teile 1–3, bis Sicherheits-Integritätslevel SIL 2.

Geprüft nach: DIN EN 1643:2014
DIN EN 13611:2011
DIN EN 13611:2016