



# Certificate of Compliance

**Certificate:** 1350312 **Master Contract:** 157406 (112901\_0\_000)  
**Project:** 70107997 **Date Issued:** 2017-02-15  
**Issued to:** **Karl Dungs Inc**  
**3890 Pheasant Ridge Dr NE**  
**Blaine, Minnesota 55449**  
**USA**  
**Attention: Jerome Bosc**

*The products listed below are eligible to bear the CSA Mark shown with adjacent indicators 'C' and 'US' for Canada and US or with adjacent indicator 'US' for US only or without either indicator for Canada only.*



**Issued by:** *Michael Bodish*  
Michael Bodish

## PRODUCTS

CLASS - C337103 - VALVES (GAS)-Automatic - For Gas Appliances

CLASS - C337183 - VALVES (GAS)-Automatic-For Gas Appliances-Certified to U.S. Standards

Model Number	Capacity	Inlet Size	Outlet Size	PSIG
•For Use with Natural, Liquefied Petroleum or Propane Gas				
Automatic Valves				
Trade Name: DUNGS				
(SV,SV-D,SV-DLE)205/6(0,1)(2,4)	940,000	1/2	1/2	2
(SV,SV-D,SV-DLE)505/6(0,1)(2,4)	1,500,000	1/2	1/2	5
(SV,SV-D,SV-DLE)1005/6(0,1)(2,4)	2,100,000	1/2	1/2	10
(SV,SV-D,SV-DLE)207/6(0,1)(2,4)	1,400,000	3/4	3/4	2
(SV,SV-D,SV-DLE)507/6(0,1)(2,4)	2,200,000	3/4	3/4	5
(SV,SV-D,SV-DLE)1007/6(0,1)(2,4)	3,100,000	3/4	3/4	10
(SV,SV-D,SV-DLE)210/6(0,1)(2,4)	2,800,000	1	1	2
(SV,SV-D,SV-DLE)510/6(0,1)(2,4)	4,500,000	1	1	5
(SV,SV-D,SV-DLE)1010/6(0,1)(2,4)	6,400,000	1	1	10
(SV,SV-D,SV-DLE)212/6(0,1)(2,4)	3,800,000	1-1/4	1-1/4	2



**Certificate:** 1350312  
**Project:** 70107997

**Master Contract:** 157406  
**Date Issued:** 2017-02-15

(SV,SV-D,SV-DLE)512/6(0,1)(2,4)	6,000,000	1-1/4	1-1/4	5
(SV,SV-D,SV-DLE)1012/6(0,1)(2,4)	8,500,000	1-1/4	1-1/4	10
(SV,SV-D,SV-DLE)215/6(0,1)(2,4)	4,700,000	1-1/2	1-1/2	2
(SV,SV-D,SV-DLE)515/6(0,1)(2,4)	7,500,000	1-1/2	1-1/2	5
(SV,SV-D,SV-DLE)1015/6(0,1)(2,4)	10,500,000	1-1/2	1-1/2	10
(SV,SV-D,SV-DLE)220/6(0,1)(2,4)	6,600,000	2	2	2
(SV,SV-D,SV-DLE)520/6(0,1)(2,4)	10,800,000	2	2	5
(SV,SV-D,SV-DLE)1020/6(0,1)(2,4)	15,300,000	2	2	10

The SV Series valves are certified for operation at a temperature of minus 40°F to plus 160°F.

The following valves are certified at the electrical ratings shown below:

SV Series: 24 V dc or 24 V ac, 60 Hz, 25 - 50VA  
120 V ac, 60 Hz, 25 - 50VA

### **APPLICABLE REQUIREMENTS**

ANSI Z21.21-2015•CSA 6.5-2015 Automatic Valves for Gas Appliances

### **MARKINGS**

The products listed are eligible to bear the CSA Mark shown with adjacent indicators 'C' and 'US' for Canada and US (indicating that products have been manufactured to the requirements of both Canadian and U.S. Standards) or with adjacent indicator 'US' for US only or without either indicator for Canada only.



## *Supplement to Certificate of Compliance*

**Certificate:** 1350312

**Master Contract:** 157406 (112901\_0\_000)

*The products listed, including the latest revision described below,  
are eligible to be marked in accordance with the referenced Certificate.*

### **Product Certification History**

---

<b>Project</b>	<b>Date</b>	<b>Description</b>
70107997	2017-02-15	Update CSA Certificate #1350312 with new drawings associated with the alternate laser welding process.
2421734	2011-05-24	Added CPI 400/401 proof of closure switches.
1687626	2005-06-30	Update drawings.
1633495	2005-01-25	Update to ANSI Z21.21b-2004.