



Type Examination Certificate

No. C5AUK 022629 0049 Rev. 00

Holder of Certificate: **Karl Dungs GmbH & Co. KG**

Karl-Dungs-Platz 1
73660 Urbach
GERMANY

Product:

Fittings (Gas)

Closed position indicator switch

K01/1

The Approved Body of TUV SUD BABT Unlimited confirms according to the Gas Appliances (Enforcement) and Miscellaneous Amendment Regulations, UKSI 2018:389 (as amended by UKSI 2019:696), that in the conformity assessment procedure in accordance with Article 14 the listed product has been assessed in a type examination (module B - production type) and complies with the relevant provisions according to Annex I on appliances burning gaseous fuels. It refers only to the sample submitted for testing and certification and on its technical documentation. See also notes overleaf.

Test report no.: V 1688-00/22

Valid until: 2032-06-28

Date, 2022-06-30

(Norbert Hörmann)



Type Examination Certificate

No. C5AUK 022629 0049 Rev. 00

Model(s): K01/1 "IP 54"
K01/1 "IP 65"

Technical data / range of application

Gas family	all gases of 1 st , 2 nd and 3 rd gas family
Max. operating pressure	500 mbar / 50 kPa
Ambient temperature	-15°C to +70°C
Rated voltage	AC 250 V
Contact load	max. 5 A, $\cos \varphi = 1$
Degree of protection	IP 54 resp. IP 65 (see models)
Installation position	push rod in vertical to horizontal position

Tested according to: DIN EN 161:2013
DIN EN 13611:2022