



# Type Examination Certificate

No. C5AUK 022629 0045 Rev. 01

**Holder of Certificate:** **Karl Dungs GmbH & Co. KG**  
Karl-Dungs-Platz 1  
73660 Urbach  
GERMANY

**Product:** **Fittings (Gas)**  
**Automatic vent valve**

**LGV**

The Approved Body of TUV SUD BABT Unlimited confirms according to the Gas Appliances (Enforcement) and Miscellaneous Amendment Regulations, UKSI 2018:389 (as amended by UKSI 2019:696), that in the conformity assessment procedure in accordance with Article 14 the listed product has been assessed in a type examination (module B - production type) and complies with the relevant provisions according to Annex I on appliances burning gaseous fuels. It refers only to the sample submitted for testing and certification and on its technical documentation. See also notes overleaf.

**Test report no.:** V-A 1686-01/24

**Valid until:** 2032-05-30

**Date,** 2024-08-09

( Johannes Steiglechner )



# Type Examination Certificate

No. C5AUK 022629 0045 Rev. 01

Model(s): **LGV 507/5**

## Technical data / range of application

gas family	all gases of 1 <sup>st</sup> , 2 <sup>nd</sup> and 3 <sup>rd</sup> gas family
group according to DIN EN 16304	2
max. operating pressure	500 mbar / 50 kPa
ambient temperature	-15°C to +60°C
rated voltages	DC 24-28 V, AC 110 V, AC 230 V

Tested according to: **DIN EN 16304:2024**  
**DIN EN 13611:2022**