



CERTIFICATE

valid until: 17.05.2032

Type examination (Module B) - production type

Certificate No.: Z-IS-TAF-MUC-22-05-2652066-24100302

Name and address of manufacturer: Karl Dungs GmbH & Co. KG
Karl-Dungs-Platz 1
73660 Urbach

We herewith certify that the production type mentioned below meets the requirements of the Pressure Equipment (Safety) Regulations 2016 no.1105 as amended by the Product Safety and Metrology etc. (Amendment etc.) (EU Exit) Regulations 2019 no.696.

Certification based on report No.: P-IS-TAF-MUC-V 1679-00/22


Scope of certification: Safety shut-off device
type SAV
as safety accessory
models see page 3

Manufacturing plant: Karl Dungs GmbH & Co. KG
Karl-Dungs-Platz 1
73660 Urbach

18.05.2022
(Date of issue)

Verification of Certificate by TÜV SÜD App Verify

TUV SUD BABT Unlimited
Approved Body for pressure equipment


Johannes Steiglechner
Name of certifier

Approved Body 0168
TUV SUD BABT Unlimited
Octagon House, Concorde Way
Fareham, Hampshire, PO 15 5RL
United Kingdom

Document ID: 2652066Yc997b

feuerung@tuvsud.com





Details of manufacturer:

Karl Dungs GmbH & Co. KG, Karl-Dungs-Platz 1, 73660 Urbach

Notes on the certificate

The right to use the symbol depicted in the certificate only applies to the product named in the certificate.

All necessary operating and safety instructions according to Schedule 2, Paragraph 21 and 22. have to be supplied with each product. For transportation purposes, the approved body may allow the holder of the certificate to disassemble the products marked with the symbol in such a way as is usual for product assembly in an installation.

The holder of the certificate is obliged to monitor the fabrication of the products marked with the symbol in order to ensure that production is carried out in accordance with the examination specifications. The holder of the certificate is particularly obliged to carry out monitoring examinations which are laid down in the examination specifications or required by the approved body.

If this certificate expires or is declared invalid it has to be returned to the approved body immediately.

A certificate can be declared invalid or terminated by the approved body, if any flaws appear after the examination which were not detectable or not found during the examination, or if the symbol is used for the purpose of misleading or in any other way illicit advertising, or due to facts which were not clearly detectable at the time of certification, further use of the symbol is not justifiable.

The holder of the certificate is obliged to report any damage to or incurred by certified products to the approved body.

The holder of the certificate is only allowed to pass on examination reports and certificates by using the full text and by stating the date of issue. Publication of excerpts or duplication of the documents requires prior consent by the approved body.

With the certificate holder's consent, the approved body reserves the right to publish a list of certified products for the purpose of consumer information.

page 3 of certificate no. Z-IS-TAF-MUC-22-05-2652066-24100302

Basis of examination:

Pressure Equipment Safety Regulations, UKSI 2016:1105 (as amended by UKSI 2019:696)
DIN EN 14382:2019-11

Models:

designation	max. operating pressure	pressure ranges (addition to designation)	nominal width, connections standard / option "NPT" or "ANSI"
SAV 10010	10 bar / 1000 kPa	ND, MD or HD	thread G 1" / thread NPT 1"
SAV 10015	10 bar / 1000 kPa	ND, MD or HD	thread G 1 1/2" / thread NPT 1 1/2"
SAV 10020	10 bar / 1000 kPa	ND, MD or HD	thread G 2" / thread NPT 2"
SAV 25010	25 bar / 2500 kPa	ND, MD, HD or UHD	thread G 1" / thread NPT 1"
SAV 25015	25 bar / 2500 kPa	ND, MD, HD or UHD	thread G 1 1/2" / thread NPT 1 1/2"
SAV 25020	25 bar / 2500 kPa	ND, MD, HD or UHD	thread G 2" / thread NPT 2"
SAV 100025	10 bar / 1000 kPa	ND, MD or HD	flange DN 25 PN 25 / flange 1" ANSI 150lbs
SAV 100040	10 bar / 1000 kPa	ND, MD or HD	flange DN 40 PN 25 / flange 1 1/2" ANSI 150lbs
SAV 100050	10 bar / 1000 kPa	ND, MD or HD	flange DN 50 PN 25 / flange 2" ANSI 150lbs
SAV 100065	10 bar / 1000 kPa	MD or HD	flange DN 65 PN 25 / flange 2 1/2" ANSI 150lbs
SAV 100080	10 bar / 1000 kPa	MD or HD	flange DN 80 PN 25 / flange 3" ANSI 150lbs
SAV 250025	25 bar / 2500 kPa	ND, MD, HD or UHD	flange DN 25 PN 25 / flange 1" ANSI 150lbs
SAV 250040	25 bar / 2500 kPa	ND, MD, HD or UHD	flange DN 40 PN 25 / flange 1 1/2" ANSI 150lbs
SAV 250050	25 bar / 2500 kPa	ND, MD, HD or UHD	flange DN 50 PN 25 / flange 2" ANSI 150lbs
SAV 250065	25 bar / 2500 kPa	MD, HD or UHD	flange DN 65 PN 25 / flange 2 1/2" ANSI 150lbs
SAV 250080	25 bar / 2500 kPa	MD, HD or UHD	flange DN 80 PN 25 / flange 3" ANSI 150lbs

If necessary, possible hazards resulting from external fire or from traffic, wind and earthquake loading shall be examined separately depending on the installation situation of the pressure equipment.