



Type Examination Certificate

No. C5AUK 022629 0053 Rev. 00

Holder of Certificate: **Karl Dungs GmbH & Co. KG**

Karl-Dungs-Platz 1
73660 Urbach
GERMANY

Product:

Fittings (Gas)

Control unit for valve proving systems

VPM-VC 24VDC

The Approved Body of TUV SUD BABT Unlimited confirms according to the Gas Appliances (Enforcement) and Miscellaneous Amendment Regulations, UKSI 2018:389 (as amended by UKSI 2019:696), that in the conformity assessment procedure in accordance with Article 14 the listed product has been assessed in a type examination (module B - production type) and complies with the relevant provisions according to Annex I on appliances burning gaseous fuels. It refers only to the sample submitted for testing and certification and on its technical documentation. See also notes overleaf.

Test report no.: C-P 1683-00/22

Valid until: 2032-06-28

Date, 2022-07-03

(Johannes Steiglechner)



Type Examination Certificate

No. C5AUK 022629 0053 Rev. 00

Model(s): VPM-VC 24VDC

Technical data / range of application

Supply voltage	24 V DC, $\pm 30\%$
Ambient temperature	$-30^{\circ}\text{C} \dots +60^{\circ}\text{C}$
Degree of protection	IP54

Tested according to: DIN EN 1643:2014
DIN EN 13611:2011
DIN EN 13611:2022