



Type Examination Certificate

No. C5AUK 022629 0052 Rev. 01

Holder of Certificate: **Karl Dungs GmbH & Co. KG**

Karl-Dungs-Platz 1
73660 Urbach
GERMANY

Product:

Fittings (Gas)

Control unit for valve proving systems

VPM-VC

The Approved Body of TUV SUD BABT Unlimited confirms according to the Gas Appliances (Enforcement) and Miscellaneous Amendment Regulations, UKSI 2018:389 (as amended by UKSI 2019:696), that in the conformity assessment procedure in accordance with Article 14 the listed product has been assessed in a type examination (module B - production type) and complies with the relevant provisions according to Annex I on appliances burning gaseous fuels. It refers only to the sample submitted for testing and certification and on its technical documentation. See also notes overleaf.

Test report no.: C-P 1681-01/25

Valid until: 2032-06-28

Date, 2025-05-20

(Johannes Steiglechner)



Type Examination Certificate

No. C5AUK 022629 0052 Rev. 01

Model(s): VPM-VC (V1.0)
VPM-VC (V1.1)

Technical data / range of application

Supply voltage	230 V AC, 50/60 Hz 115 V AC, 50/60 Hz (optional)
Ambient temperature	-20°C... +60°C
Degree of protection	VPM-VC (V1.0): IP42 VPM-VC (V1.1): IP54

The conditions and requirements mentioned in annex C of test report no. C-P 1681-01/25 shall be considered for installation, configuration, commissioning and operation.

Further details / remarks:

The control unit for valve proving systems also conforms to the requirements of

- ISO 23551-4:2018-04 and ISO 23550:2018-04 for EU and JP, and of
- DIN EN 61508:2011, parts 1–3, up to safety integrity level SIL 2.

Tested according to: DIN EN 1643:2014
DIN EN 13611:2011
DIN EN 13611:2016