Product data sheet Characteristics

LC1K120047F7

TeSys K contactor - 4P(4 NO) - AC-1 - <= 440 V 20 A - 110 V AC coil



Main

Range	TeSys
Product name	TeSys K
Device short name	LC1K
Contactor application	Resistive load
Utilisation category	AC-1
Power pole contact composition	4 NO
[le] rated operational current	16 A (<= 70 °C) at 690 V AC AC-1 for power circuit 20 A (<= 50 °C) at <= 440 V AC AC-1 for power circuit
Control circuit type	AC 50/60 Hz
Control circuit voltage	110 V AC 50/60 Hz
Overvoltage category	III
[lth] conventional free air thermal current	20 A at <= 50 °C for power circuit
Irms rated making ca- pacity	144 A AC for power circuit conforming to IEC 60947 144 A AC for power circuit conforming to NF C 63-110
Rated breaking capacity	70 A at 660690 V conforming to IEC 60947 80 A at 500 V conforming to IEC 60947 110 A at 440 V conforming to IEC 60947
Associated fuse rating	25 A aM for power circuit 25 A gG at <= 440 V for power circuit
Average impedance	3 mOhm at 50 Hz - Ith 20 A for power circuit
Product certifications	CSA UL
Operating time	1020 ms coil energisation and NO closing 1020 ms coil de-energisation and NO opening
Safety reliability level	B10d = 20000000 cycles contactor with mechanical load conforming to EN/ISO 13849-1 B10d = 1369863 cycles contactor with nominal load conforming to EN/ISO 13849-1
Operating rate	3600 cyc/h

Complementary

0.20.75 Uc at <= 50 °C drop-out 0.81.15 Uc at <= 50 °C operational	
30 VA at 20 °C	
4.5 VA at 20 °C	
1.3 W	
<= 400 Hz	
	0.81.15 Uc at <= 50 °C operational 30 VA at 20 °C 4.5 VA at 20 °C 1.3 W

Environment

Destant a transfer of	TO 22 (Carrier to DIN 50040
Protective treatment	TC conforming to DIN 50016
	TC conforming to IEC 60068
Operating altitude	2000 m without derating in temperature
Flame retardance	Requirement 2 conforming to NF F 16-102
	Requirement 2 conforming to NF F 16-101
	V1 conforming to UL 94
Mechanical robustness	Vibrations contactor opened 2 Gn, 5300 Hz IEC 60068-2-6
	Vibrations contactor closed 4 Gn, 5300 Hz IEC 60068-2-6
	Shocks contactor opened, on Z axis 10 Gn for 11 ms IEC 60068-2-27
	Shocks contactor opened, on Y axis 10 Gn for 11 ms IEC 60068-2-27
	Shocks contactor opened, on X axis 6 Gn for 11 ms IEC 60068-2-27
	Shocks contactor closed, on Z axis 15 Gn for 11 ms IEC 60068-2-27
	Shocks contactor closed, on Y axis 15 Gn for 11 ms IEC 60068-2-27
	Shocks contactor closed, on X axis 10 Gn for 11 ms IEC 60068-2-27

