# Product datasheet Characteristics

## LV429082

trip unit Micrologic 2.2 for Compact NSX 100/160/250 circuit breakers, electronic, rating 40A, 4 poles 4d





### Main

Iviairi		
Range of product	NSX100250	
Product or component type	Control unit	
Range compatibility	Compact NSX100 Compact NSX160 Compact NSX250	
Device application	Distribution	
Poles description	4P	
Protected poles description	3t 3t + N/2 4t	
Neutral position	Left	
Network type	AC	
Network frequency	50/60 Hz	
Trip unit name	Micrologic 2.2	
Trip unit technology	Electronic	
Trip unit protection functions	LSoI	
Protection type	L : for overload protection (long time) So : for short time short-circuit protection with fixed delay I : for instantaneous short-circuit protection	
Trip unit rating	40 A at 40 °C	

#### Complementary

Mounting mode	Fixed	
[Ue] rated operational voltage	690 V AC 50/60 Hz	
Neutral protection setting	0.5 x lr (3t + N/2) 1 x lr (4t) No protection (3t)	This doctor
Long time pick-up adjustment type Ir	Adjustable 9 settings	i E

[Ir] long time pick-up adjustment range	0.91 x lo
Long time delay adjustment type	Fixed
[Tr] long-time delay adjustment range	11 s at 7.2 x lr 16 s at 6 x lr 400 s at 1.5 x lr
Thermal memory	20 minutes before and after tripping
Short-time pick-up adjustment type Isd	Adjustable 9 settings
[lsd] short-time pick-up adjustment range	1.510 x lr
Short-time delay adjustment type	Fixed
[Tsd] short-time delay adjustment range	0.02 s
Instantaneous pick-up adjustment type li	Fixed
[li] instantaneous pick-up adjustment range	600 A

#### Environment

<del></del>				
Standards	UL 508 EN/IEC 60947-2			
Product certifications	Marine CCC EAC			
Ambient air temperature for operation	-2570 °C			
Ambient air temperature for storage	-5085 °C			

#### Offer Sustainability

Green Premium product	
Compliant EU RoHS Declaration	
Yes	
Yes	
China RoHS declaration Product out of China RoHS scope. Substance declaration for your information	
Product Environmental Profile	
End of Life Information	

#### Contractual warranty

Warranty	18 months	